



1 WALL SECTION
A303 SCALE: 3/8"=1'-0"

2 WALL SECTION
A303 SCALE: 3/8"=1'-0"

3 WALL SECTION
A303 SCALE: 3/8"=1'-0"

4 WALL SECTION
A303 SCALE: 3/8"=1'-0"

- WALL SECTIONS KEY SCHEDULE:
- WELL COMPACTED SOIL AS CALLED BY GEO-TECH REPORT.
 - CONCRETE BASEMENT WALL FOOTING ON WELL COMPACTED SOIL AS CALLED BY THE GEO-TECH REPORT. FOR FOOTING DETAILS SEE STRUCTURAL DRAWINGS.
 - 4" CONTINUOUS PERFORATED DRAIN PIPE SLOPED TO DAYLIGHT OR TO STORM SEWER. COVER PIPE WITH 2" GF 51 STONE WRAP WITH FILTER FABRIC.
 - CONCRETE BASEMENT WALL. SEE STRUCTURAL DRAWINGS FOR DETAILS.
 - BASEMENT WALL WATER PROOFING PER CODE.
 - LEDGE IN BASEMENT WALL FOR CONCRETE SIDEWALK FOOTING. SEE STRUCTURAL DRAWINGS FOR DETAILS.
 - FIRE-FORMED EXPANSION JOINT MATERIAL. SEE MANUFACTURER'S SPECS.
 - 4" THICK CONCRETE SIDEWALK SLOPED MIN. 1/4" AWAY FROM BUILDING. COVER OPTIONAL 2" CLEAN SAND OVER 6 MIL. VAPOR BARRIER OVER 4" GRAVEL. BASE ON WELL COMPACTED SOIL AS CALLED BY GEO-TECH REPORT.
 - CORROSION RESISTANT CONTINUOUS STEEL ANGLE AND STEEL BRACKET WITH CONTINUOUS FLASHING. SEE STRUCTURAL AND MANUFACTURER'S DETAILS. PROVIDE A MINIMUM 1" GAP BETWEEN THE CONCRETE SIDEWALK AND THE BOTTOM SURFACE OF THE STEEL ANGLE.
 - STONE VENEER MASONRY SYSTEM ON CMU BLOCK WALL OR STEEL STUD WALL. SEE WALL SECTIONS FOR DETAILS. ARRISCRAPT RENAISSANCE SERIES ROCKED OR STAIN FINISH MASONRY. SEE MANUFACTURER'S DETAILS AND SPECS.
 - ADJUSTABLE WALL TIE # 24" ON-CENTER EACH WAY. SEE MANUFACTURER'S SPECS FOR DETAILS.
 - MORTAR DROP CONTROL.
 - EXTERIOR WALL SYSTEMS WITH 5/8" GYP. GILD EXTERIOR GRADE SHEATHING 5/8" LITE GAGE METAL STUDS # 16" ON-CENTER TO THE BLOCKING. SEE MANUFACTURER'S DETAILS. FILL CAVITY WITH BATT INSULATION. PROVIDE WRAP AS PER CODE. 1/2" THICK GYP. BD. ON THE INTERIOR SIDE. PROVIDE WALL JOINT COMPOUND AND PAPER PER MANUFACTURER'S SPECS.
 - UNDER BILL FLASHING MEMBRANE. AT END DIPS, INSTALL TUBE VENTS AT CENTER OF BILL UNIT. VENTS TO BE AT 24" ON-CENTER. SEE STONE MASONRY MANUFACTURER'S DETAILS.
 - ALUMINUM WINDOW SYSTEM.
 - CONTINUOUS COMPRESSIBLE DUCKER ROD AND SEALANT.
 - CONTINUOUS METAL FLASHING WITH WEEDS # 24" ON-CENTER AND VENTS (TYPICAL).
 - EIFS FINISH SYSTEM OVER MIN. 2" EPS. SEE MANUFACTURER'S SPECS FOR DETAILS AND SELECTION BY COLOR.
 - EIFS SPECIAL BUILDING WRAP. OVERLAP ALL HORIZONTAL AND VERTICAL BEAMS BY 6" MINIMUM TAPE AND SEAL ALL BEAMS, BOTH VERTICAL AND HORIZONTAL AS APPROVED BY AIR AND MOISTURE BARRIER MANUFACTURER.
 - R-13 MIN. CONTINUOUS CAVITY INSULATION.
 - PROVIDE SOLID BLOCKING AND HAT CHANNELS AS REQUIRED.
 - EXPANSION JOINT IN EIFS. SEE MANUFACTURER'S SPECS. AND DETAILS.
 - STEEL ANGLE POUR STOP. SEE STRUCTURAL DRAWINGS FOR DETAILS.
 - SCREW TO SECURE FLOOR RUNNER. SEE MANUFACTURER'S SPECS.
 - METAL STUD FLOOR CHANNEL FOR 5/8" METAL STUDS. SECURE TO CONCRETE SLAB OR OTHER STRUCTURAL ELEMENT PER MANUFACTURER'S SPECS.
 - TYPICAL WINDOW SILL WATER TABLE SYSTEM. SEE WALL SECTION DETAILS.
 - COMMERCIAL INSULATED WINDOW UNIT. SEE DOOR WINDOW SCHEDULE.
 - EIFS CORNICE ON FOAM PROFILE. SEE ENLARGED DETAILS.
 - FULLY ADHERED WATER ROOFING MEMBRANE TO PARAPET WALL. OVERLAP ALL JOINTS AND BEAMS BY MIN. 6" (TYP.).
 - GALV. METAL COPING. SEE COLOR IN ELEVATIONS. (TYP.) FRONT ATTACH TO CONTINUOUS HOLD DOWN CLIP. REAR W/ NAILS GROMMET W/ NEOPRENE WASHERS # 24" ON-CENTER. PROVIDE CONT. BACKER ROD AND SEALANT AT ENDS.
 - CONT. P.T. PLY WOOD LAID TO SLOPE INWARDS.
 - PARAPET STRUCTURAL BEAM. PROVIDE 3"x3"x1/2" HORIZONTAL METAL TUBE STEEL WITH 3"x3"x1/2" VERTICAL POST AT EVERY 48" ON CENTER WELD THE BOTTOM OF THE VERTICAL POST TO THE ROOF BEAM. FILL THE VOID SPACES BETWEEN THE POST WITH STUD PARAPET WALLS.
 - 2X7 CONT. NAILER AS REQUIRED.
 - LITE GAGE METAL STUDS SECURED TO PARAPET STEEL BEAM. SEE STRUCTURAL.
 - OVERLAP WATER PROOFING MEMBRANE AT BENDS. MINIMUM OVERLAP 6".
 - 4" CONTINUOUS CANT.
 - MIN. 4" THICK R-30 GYP. POLYISO RIGID INSULATION SECURED TO ROOF DECK. INSTALL PER MANUFACTURER'S SPECS.
 - METAL DECK ROOF SYSTEM. SEE MANUFACTURER AND STRUCTURAL DETAILS.
 - STRUCTURAL STEEL BEAM. SEE STRUCTURAL DRAWINGS.
 - CONTINUOUS STEEL STUD BLOCKING AT EIFS EXPANSION JOINT. AIR SEAL. ALL CAVITY WITH SPRAY APPLIED FOAM INSULATION (TYP.).
 - 1/2" THICK GYP. BD. ON INTERIOR SIDE. PROVIDE WALL JOINT COMPOUND AND PAPER PER MANUFACTURER'S SPECS.
 - LITE GAGE 5/8" METAL STUDS AT 16" ON-CENTER. SEE MANUFACTURER'S DETAILS.
 - ACOUSTICAL LAY IN CEILING OR GYP. CEILING INSTALLED PER MANUFACTURER'S SPECS. SEE PLAN FOR CEILING TYPE.
 - TYPICAL WINDOW HEADER SYSTEM. SEE STRUCTURAL DRAWINGS AND MANUFACTURER'S SPECS FOR DETAILS.
 - FULLY ADHERED 60 MIL. EPDM/DURO-LAST/PO ROOF MEMBRANE OVER MIN. 4" THICK R-30 POLYISO RIGID INSULATION.
 - WOOD FLOOR BASE AS APPROVED.
 - 35" THICK LIGHT WEIGHT CONCRETE FLOOR SLAB ON METAL DECK. SEE STRUCTURAL FOR DETAILS.
 - METAL DECK FLOOR SYSTEM. SEE MANUFACTURER AND STRUCTURAL DETAILS.
 - STRUCTURAL STEEL FLOOR/ROOF SYSTEM. SEE STRUCTURAL FRAMING PLANS FOR DETAILS.
 - INTERIOR FINISH WALL SYSTEM 5/8" GYPSUM WALL BOARD OVER 3/8" METAL STUDS # 24" O.C. WITH MID-HEIGHT BLOCKING. FILL CAVITY W/ R-13 BATT INSULATION. BASEMENT GRADE WALLS NEED NOT TO BE FILLED WITH INSULATION.
 - 4" THICK CONCRETE SLAB (COVER OPTIONAL 2" CLEAN SAND) OVER 6 MIL. POLY VAPOR BARRIER OVER 4" GRAVEL. BASE ON WELL COMPACTED SOIL AS CALLED BY GEO-TECH REPORT.
 - 6 MIL. POLY VAPOR BARRIER.
 - REVEAL IN EIFS. SEE MANUFACTURER'S DETAILS AND SPECS.
 - SLOPED WINDOW SILL. CAST STONE MASONRY UNIT. MASONRY TIE OR MECHANICAL ANCHOR IN HEAD JOINT. RAKE BACK MORTAR BETWEEN UNITS APPROX. 1" DEEP. COVER WITH BACKER ROD AND SEALANT TO PROTECT MORTAR.
 - 8" STANDARD CMU (ADJUST COURSES TO SUIT FIELD CONDITIONS) WITH HORIZONTAL AND VERTICAL REINFORCEMENT PER STRUCTURAL DRAWINGS.
 - SOLID FILL WITH HIGH SLUMP MASONRY GROUT.
 - CONCRETE BASEMENT WALL FOOTING FOR CMU BLOCK WALL ON WELL COMPACTED SOIL AS CALLED BY THE GEO-TECH REPORT. FOR FOOTING DETAILS SEE STRUCTURAL DRAWINGS.
 - SILL BOND BEAM. SEE STRUCTURAL DRAWINGS.
 - LINTEL BOND BEAM. SEE STRUCTURAL DRAWINGS.
 - TYPICAL FLOOR SHELF ANGLE FOR STONE VENEER MASONRY. SEE STRUCTURAL DRAWINGS FOR DETAILS.
 - BOND BEAM # FLOOR JOIST BEARING. SEE STRUCTURAL DRAWINGS.
 - METAL ANGLE LINTEL. SEE STRUCTURAL.
 - ALUMINUM ALING SYSTEM BY OTHERS.
 - GYP. BD CEILING WITH COVE LIGHTS. SEE REFLECTED CEILING PLANS. PROVIDE LITE GAGE FRAMING AS REQUIRED TO PROFILE AND SECURE THE FALSE CEILING.
 - 51 STONE ON WELL COMPACTED SOIL. SEE GEO-TECH REPORT FOR SOIL PREPARATION AND RECOMMENDATIONS.
 - LITE GAGE FRAMING/BRACING AS REQUIRED FOR PORCH.
 - FOAM INSULATION ARE REQUIRED TO FILL ANNULAR SPACES.
 - METAL ANGLE SHELF ANGLE. SEE STRUCTURAL DRAWINGS.
 - METAL ANGLE FRAMING AS REQUIRED. SEE STRUCTURAL DRAWINGS.
 - DRIP EDGE IN EIFS. PROVIDE AT ALL PLACES WHERE EIFS OVERLAPS.
 - EIFS ON FOAM PROFILE. SEE ELEVATION FOR DETAILS.

DESIGN BUILD
BLACKWATER CONSTRUCTION GROUP, LLC
 2200 SATELLITE BLVD, DULUTH GA 30092
 TEL: (404) 251-5569

DESIGN CONSULTANTS
DESIGN SOLUTIONS LLC
 1180 BOND STREET, SUITE 111
 ATLANTA, GA 30309
 Phone: 404-740-7589

ARCHITECT OF RECORD
ROBERT J LARA, AIA
 8450 SW 291 ST.
 CUTLER BAY, FL 33189

STATE OF GEORGIA
 REGISTERED ARCHITECT
 ROBERT JERRY LARA
 LICENSE NO. 10000
 Nov 9 2014

STRUCTURAL
ENGQUEST
 1550 ENGINEERING DRIVE, SUITE 115
 PEACHTREE CORNERS, GA 30092
 TEL: (404) 506-4670
 www.engquest.com

MEP
ENGQUEST
 1550 ENGINEERING DRIVE, SUITE 115
 PEACHTREE CORNERS, GA 30092
 TEL: (404) 506-4670
 www.engquest.com

NOTES:

REVISION #	DATE	REMARKS

ISSUE DATE: 10-22-2014 | ISSUED TO: COUNTY | ISSUED FOR: PERMITS

PROJECT ADDRESS:
MASJID AL-MOMINEEN
 837 NORTH INDIAN CREEK DRIVE
 CLARKSTON, DEKALB COUNTY
 GEORGIA, 30021

LAYOUT:
REAR ELEVATION

PAPER SIZE: 24x36 (ARCH D)
 SCALE: AS NOTED

SHEET NUMBER:
A303