

LIGHTING GENERAL NOTES:

- A. THE ELECTRICAL CONTRACTOR SHALL REFER TO CIVIL, ARCHITECTURAL, STRUCTURAL, MECHANICAL AND PLUMBING DRAWING FOR THE EXACT BUILDING AND ROOM LAYOUTS. ALL DIMENSIONS, SECTIONS, DETAILS, AND ELEVATIONS, POWER AND VOLTAGE REQUIREMENTS AND PHYSICAL SIZE OF ALL EQUIPMENT FURNISHED BY OTHER TRADES. COORDINATE AND ADJUST ELECTRICAL INSTALLATION ACCORDINGLY.
- B. REFER TO DRAWING E-1.0 FOR LIGHTING FIXTURE SCHEDULE.
- C. UPPER CASE ALPHA CHARACTER INSIDE/ADJACENT TO LIGHT FIXTURE INDICATES LUMINAIRE TYPE.
- D. LOWER CASE ALPHA CHARACTER INSIDE/ADJACENT TO LUMINAIRE INDICATES ASSOCIATED SWITCH CONTROLLING LIGHTING BRANCH CIRCUIT.
- E. FIXTURES SHOWN WITH DESIGNATION 'NL' ARE TO BE USED AS NIGHT LIGHT. CONNECT TO UNSWITCHED "HOT-LEG" OF RESPECTIVE LIGHTING CIRCUIT.
- F. CONNECT ALL EMERGENCY BALLAST AND EXIT LIGHTS TO UNSWITCHED "HOT-LEG" OF RESPECTIVE LIGHTING CIRCUIT.
- G. ALL PENETRATION THRU FIRE RATED WALL AND CEILING SHALL BE SEALED IN ACCORDANCE WITH NATIONAL ELECTRICAL CODE ARTICLE 300-21.
- H. INSTALL A FULL SIZE NEUTRAL FOR EACH LIGHT GROUP.
- I. HOMERUN CONDUCTOR SHALL BE #10 AWG COP, WHEN LENGTH EXCEEDS 80 FT.
- J. COORDINATE WITH OWNER FOR APPROVAL OF LIGHTING FIXTURE PRIOR TO INSTALL.

KEY NOTES:

- ① ALL STAIR LIGHTS SHALL BE ON SWITCH AND REMAIN ON ALL THE TIME.
- ② ALL EXHAUST FAN IN REST ROOM SHALL BE INTERLOCK WITH LIGHTING SWITCH.
- ③ CONNECT TO SWITCH LOCATED ON FIRST FLOOR LEVEL.

DESIGN BUILD
BLACKWATER CONSTRUCTION GROUP, LLC
 2200 SATELLITE BLVD, DULUTH GA 30092
 TEL: (770) 455-5569

DESIGN CONSULTANTS
DESIGN SOLUTIONS LLC
 1000 S. GOSWORTHY BLVD, SUITE 100, DULUTH GA 30092
 TEL: (770) 455-5569

ARCHITECT OF RECORD
ROBERT J LARA, AIA
 8450 SW 201 ST.
 CUTLER BAY, FL 33189

STRUCTURAL
ENGQUEST
 3550 ENGINEERING DRIVE, SUITE 175
 PEACHTREE CORNERS, GA 30092
 TEL: (770) 906-4670
 www.engquest.com

MEP
ENGQUEST
 3550 ENGINEERING DRIVE, SUITE 175
 PEACHTREE CORNERS, GA 30092
 TEL: (770) 906-4670
 www.engquest.com

Robert J. Lara
 PE032226
 PROFESSIONAL ENGINEER
 CIVIL
 12/05/2014

NOTES:

REVISION #	DATE	REMARKS

ISSUE DATE	ISSUED TO:	ISSUED FOR:
10-02-2014	COUNTY	PERMITS

PROJECT ADDRESS:
MASJID AL-MOMINEEN
 837 NORTH INDIAN CREEK DRIVE
 CLARKSTON, DEKALB COUNTY
 GEORGIA, 30021


LAYOUT:
ELECTRICAL 2ND FLOOR LIGHTING PLAN

PAPER SIZE: 24X36 (ARCH D)
SCALE: AS NOTED

SHEET NUMBER:

E303

1 ELECTRICAL LIGHTING 2ND FLOOR PLAN
 E303 SCALE: 1/8" = 1'-0"



Order Plans