



- GENERAL NOTES:**
- A. FIRE ALARM CONTRACTOR TO COORDINATE EXACT NUMBER AND LOCATIONS OF DUCT SMOKE DETECTORS.
  - B. FIRE ALARM SIGNALING LINE CIRCUITS SHALL COMPLY WITH NFPA 72, CLASS B, STYLE 4. NOTIFICATION-APPLIANCE CIRCUITS SHALL COMPLY WITH NFPA 72, CLASS A, STYLE Z.
  - C. WIRE AND CABLE FOR FIRE ALARM SYSTEM SHALL BE UL LISTED AND LABELED AS COMPLYING WITH NFPA 70, ARTICLE 760. SIGNALING LINE CIRCUITS SHALL BE COMPRISED OF CIRCUIT INTEGRITY CABLE, TWISTED SHIELDED PAIR, NFPA 70, ARTICLE 760, CLASSIFICATION CI, FOR POWER-LIMITED FIRE ALARM SIGNAL SERVICE, UL LISTED AS TYPE FPL, AND COMPLYING WITH REQUIREMENTS IN UL 1424 AND IN UL 2196 FOR A 2-HOUR RATING.
  - D. FIRE ALARM CONTROL PANEL SHALL BE INTERLOCKED WITH SPRINKLE SYSTEM.
  - E. REFERENCE MECHANICAL DRAWINGS FOR EXACT LOCATIONS OF DAMPERS & DUCT DETECTORS. PROVIDE LOW VOLTAGE WIRING AS REQUIRED.
  - F. REFER TO DRAWING EB01 FOR FIRE ALARM LEGEND AND RISER DIAGRAM.

- FIRE ALARM PLAN KEY NOTES:**
- ① COORDINATE WITH SPRINKLER DRAWING FOR QUANTITY AND LOCATION OF TAMPER AND FPL SWITCH.
  - ② FIRE ALARM CONTROL PANEL LOCATION TO BE VERIFIED WITH OWNER PRIOR TO INSTALL.
  - ③ FIRE ALARM REMOTE ANNUNCIATOR PANEL.

**DESIGN BUILD**  
**BLACKWATER CONSTRUCTION GROUP, LLC**  
 2200 SATELLITE BLVD, DULUTH GA 30092  
 TEL: (770) 455-3569

**DESIGN CONSULTANTS**  
**DESIGN SOLUTIONS LLC**  
 1100 S. GOSWORTHY BLVD, SUITE 100, ATLANTA, GA 30329  
 TEL: (404) 740-7587

**ARCHITECT OF RECORD**  
**ROBERT J LARA, AIA**  
 8450 SW 201 ST.  
 CUTLER BAY, FL 33189

**STRUCTURAL**  
**ENGQUEST**  
 3550 ENGINEERING DRIVE, SUITE 175  
 PEACHTREE CORNERS, GA 30092  
 TEL: (678) 906-4670  
 www.engquest.com

**MEP**  
**ENGQUEST**  
 3550 ENGINEERING DRIVE, SUITE 175  
 PEACHTREE CORNERS, GA 30092  
 TEL: (678) 906-4670  
 www.engquest.com

*Professional Engineer Seal:*  
 Robert J. Lara  
 PE032226  
 PROFESSIONAL ENGINEER  
 GEORGIA  
 12/09/2014

**NOTES:**

REVISION #	DATE	REMARKS

ISSUE DATE	ISSUED TO:	ISSUED FOR:
10-02-2014	COUNTY	PERMITS

**PROJECT ADDRESS:**  
**MASJID AL-MOMINEEN**  
 837 NORTH INDIAN CREEK DRIVE  
 CLARKSTON, DEKALB COUNTY  
 GEORGIA, 30021

**LAYOUT:**  
**ELECTRICAL**  
**BASEMENT FIRE ALARM PLAN**

PAPER SIZE: 24X36 (ARCH D)  
 SCALE: AS NOTED

SHEET NUMBER:  
**E501**

Order Plans @ www.LDLINE.com

**1** FIRE ALARM BASEMENT FLOOR PLAN  
 E501 SCALE: 1/8" = 1'-0"  
 0 4' 8' 16'