



GENERAL NOTES:

- A. FIRE ALARM CONTRACTOR TO COORDINATE EXACT NUMBER AND LOCATIONS OF DUCT SMOKE DETECTORS.
- B. FIRE ALARM SIGNALING LINE CIRCUITS SHALL COMPLY WITH NFPA 72, CLASS B, STYLE 4. NOTIFICATION-APPLIANCE CIRCUITS SHALL COMPLY WITH NFPA 72, CLASS A, STYLE Z.
- C. WIRE AND CABLE FOR FIRE ALARM SYSTEM SHALL BE UL LISTED AND LABELED AS COMPLYING WITH NFPA 70, ARTICLE 760. SIGNALING LINE CIRCUITS SHALL BE COMPRISED OF CIRCUIT INTEGRITY CABLE, TWISTED SHIELDED PAIR, NFPA 70, ARTICLE 760, CLASSIFICATION CI, FOR POWER-LIMITED FIRE ALARM SIGNAL SERVICE, UL LISTED AS TYPE FPL, AND COMPLYING WITH REQUIREMENTS IN UL 1424 AND IN UL 2196 FOR A 2-HOUR RATING.
- D. FIRE ALARM CONTROL PANEL SHALL BE INTERLOCKED WITH SPRINKLER SYSTEM.
- E. REFERENCE MECHANICAL DRAWINGS FOR EXACT LOCATIONS OF DAMPERS & DUCT DETECTORS. PROVIDE LOW VOLTAGE WIRING AS REQUIRED.
- F. REFER TO DRAWING E801 FOR FIRE ALARM LEGEND AND RISER DIAGRAM.

FIRE ALARM PLAN KEY NOTES:

- ① COORDINATE WITH SPRINKLER DRAWING FOR QUANTITY AND LOCATION OF TAMPER AND FUSIBLE SWITCH.
- ② FIRE ALARM CONTROL PANEL LOCATION TO BE VERIFIED WITH OWNER PRIOR TO INSTALL.
- ③ FIRE ALARM REMOTE ANNUNCIATOR PANEL.

DESIGN BUILD
BLACKWATER CONSTRUCTION GROUP, LLC
 2200 SATELLITE BLVD, DULUTH GA 30096
 TEL: (770) 455-1569

DESIGN CONSULTANTS
DESIGN SOLUTIONS LLC
 1100 SONDERS PRODUCTIONS.COM
 Phone: 404-740-7587

ARCHITECT OF RECORD
ROBERT J LARA, AIA
 8450 SW 201 ST.
 CUTLER BAY, FL 33189

STRUCTURAL
ENGQUEST
 3550 ENGINEERING DRIVE, SUITE 175
 PEACHTREE CORNERS, GA 30092
 TEL: (678) 906-4670
 www.engquest.com

MEP
ENGQUEST
 3550 ENGINEERING DRIVE, SUITE 175
 PEACHTREE CORNERS, GA 30092
 TEL: (678) 906-4670
 www.engquest.com

Professional Engineer Seal:
 PE032226
 PROFESSIONAL ENGINEER
 GEORGIA
 07/09/2014

NOTES:

REVISION #	DATE	REMARKS

ISSUE DATE	ISSUED TO:	ISSUED FOR:
10-02-2014	COUNTY	PERMITS

PROJECT ADDRESS:
MASJID AL-MOMINEEN
 837 NORTH INDIAN CREEK DRIVE
 CLARKSTON, DEKALB COUNTY
 GEORGIA, 30021

LAYOUT:
ELECTRICAL FIRE ALARM 1ST FLOOR PLAN

PAPER SIZE: 24X36 (ARCH D)
 SCALE: AS NOTED

SHEET NUMBER:
E502

Order Plans

1 FIRE ALARM 1ST FLOOR PLAN
 E502 SCALE: 1/8" = 1'-0"

