

Order Plans @ WWW.LDLINE.COM

ELECTRICAL GENERAL NOTES

1. THE ABBREVIATION G.C., WHEREVER IT APPEARS IN THESE ELECTRICAL DRAWING, SHALL REFER TO 'GENERAL CONTRACTOR'.
2. THE CONTRACTOR FOR THIS WORK IS REQUIRED TO READ THE SPECIFICATIONS AND REVIEW DRAWINGS OF ALL DIVISIONS OF WORK AND IS RESPONSIBLE FOR THE COORDINATION OF THIS WORK AND THE WORK OF ALL SUBCONTRACTORS WITH ALL DIVISIONS OF WORK. IT IS THE CONTRACTOR'S RESPONSIBILITY TO PROVIDE ALL SUBCONTRACTORS WITH A COMPLETE SET OF BID DOCUMENTS.
3. AIM AND ADJUST ALL TRACK FIXTURES AS DIRECTED BY GAP, INC.
4. ALL LIGHTING AND RECEPTACLE CIRCUITS UP TO 60'-0" IN LENGTH SHALL UTILIZE #12 CONDUCTORS MINIMUM, CIRCUITS FROM 61'-0" THRU 100'-0" IN LENGTH SHALL UTILIZE #10 CONDUCTORS MINIMUM AND FROM 101'-0" THRU 150'-0" IN LENGTH SHALL UTILIZE #8 CONDUCTORS MINIMUM, UNLESS OTHERWISE NOTED.
5. IN DRYWALL CEILING AREAS, ARRANGE CIRCUITS TO AVOID THE USE OF JUNCTION BOXES IN INACCESSIBLE LOCATIONS. THE USE OF JUNCTION BOXES ABOVE DRYWALL CEILINGS SHALL BE LIMITED TO LOCATIONS NEAR ACCESS PANELS AS LOCATED ON PLANS. FIELD COORDINATE WITH G.C. PRIOR TO ROUGH-IN TO AVOID ANY CONFLICTS.
6. PLACEMENT OF ALL RECEPTABLES IN THE "SALES" AREA SHALL BE INTENTIONAL (I.E. - CENTERED ON COLUMNS, WALL FEATURES OR TIGHT TO CORNERS AND FLUSH MOUNTED AT GYP BOARD WALL ONLY). FIELD VERIFY EXACT PLACEMENT OF RECEPTACLE WITH G.C. PRIOR TO ROUGH-IN.

STORE DESIGN IS BASED ON THE FOLLOWING SURVEY AND BASE FILES: EEA MEP SURVEY 11/21/2016 AND BASE BUILDING PERMIT/CONSTRUCTION SET 09/13/2012

ELECTRICAL SYMBOLS

- ▼ TELEPHONE OUTLET
- TELEPHONE OUTLET, FLOOR MOUNTED
- TELEPHONE OUTLET, CEILING MOUNTED
- DATA OUTLET
- DATA OUTLET, FLOOR MOUNTED
- DATA OUTLET, CEILING MOUNTED
- PHONE/DATA OUTLET, FLOOR MOUNTED
- PHONE/DATA OUTLET, CEILING MOUNTED
- PHONE/DATA OUTLET
- DUPLEX RECEPTACLE
- CEILING MOUNTED RECEPTACLE
- DUPLEX RECEPTACLE, FLOOR MOUNTED
- POWERSTRUT MOUNTED RECEPTACLE
- CEILING MOUNTED QUADRUPLX RECEPTACLE
- QUADRUPLX RECEPTACLE
- DUPLEX RECEPTACLE WITH GROUND FAULT CIRCUIT INTERRUPTER
- DUPLEX, WHITE RECEPTACLE AND COVERPLATE
- DUPLEX, WHITE RECEPTACLE AND STAINLESS STEEL COVERPLATE
- DUPLEX RECEPTACLE, STOREFRONT
- SINGLE RECEPTACLE
- QUADRUPLX RECEPTACLE WITH ISOLATED GROUND
- DUPLEX RECEPTACLE WITH ISOLATED GROUND
- DUPLEX RECEPTACLE WITH USB PORTS
- JUNCTION BOX
- \$ SWITCH, 1-POLE, REFER TO ARCHITECTURAL FOR MOUNTING HEIGHT
- \$3 SWITCH, 3-WAY, REFER TO ARCHITECTURAL FOR MOUNTING HEIGHT
- \$T MOTOR RATED SWITCH WITH THERMAL OVERLOAD PROTECTION
- \$D DIMMER SWITCH
- MS MOTION SENSOR
- BB BYPASS BUTTON
- RB REMOTE BALLAST
- R RELAY
- NON-FUSED DISCONNECT SWITCH
- FUSED DISCONNECT SWITCH
- MS MAGNETIC STARTER
- ELECTRICAL PANEL (SHOWN TO SCALE ON PLANS)
- DRY TYPE TRANSFORMER
- PUSH BUTTON FOR BELL OR BUZZER
- BELL BUZZER
- BUZZER OR BELL
- ADA PUSHBUTTON
- INTERCOM CALL BUTTON
- ADT CONTROL PANEL
- SPEAKER VOLUME CONTROL
- S SPEAKER
- B BASS MODULE MOUNTED ABOVE CEILING
- ACCESS PANEL. SEE ARCHITECTURAL DRAWINGS.
- HOMERUN CIRCUIT
- POWERSTRUT SUSPENDED FROM STRUCTURE
- UNISTRUT
- FACP FIRE ALARM CONTROL PANEL
- ANNUN FACP REMOTE ANNUNCIATOR
- P PHOTO CELL
- MANUAL PULL STATION
- S CEILING MOUNTED AREA SMOKE DETECTOR
- X(S) DUCT MOUNTED SMOKE DETECTOR
- 120V POWER FROM RTU REC/LT CCT IF REQUIRED
- INTERNAL CONTACTOR
- CONTROL RELAY
- TS TAMPER SWITCH
- FS WATER FLOW SWITCH
- AV HORN WITH STROBE LIGHT WALL MOUNTED @ 80" AFF
- V STROBE LIGHT, WALL MOUNTED @ 80" AFF
- A HORN WALL MOUNTED @ 80" AFF
- V STROBE LIGHT, CEILING MOUNTED.
- AV HORN WITH STROBE LIGHT CEILING MOUNTED
- S HVAC TEMPERATURE SENSOR
- T HVAC THERMOSTAT
- ELECTRICALLY POWERED EQUIPMENT
- AFF ABOVE FINISH FLOOR
- EAS ELECTRONIC ARTICLE SURVEILLANCE
- EBBH ELECTRIC BASEBOARD HEATER
- EC ELECTRICAL CONTRACTOR
- EM EMERGENCY
- EWC ELECTRIC WATER COOLER - COORDINATE RECEPTACLE LOCATION WITH PLUMBING CONTRACTOR
- IG ISOLATED GROUND
- NL NIGHT LIGHTING
- WP WEATHER PROOF
- (X) X = QUANTITY OF CONDUCTORS
- NOTE: NOT ALL SYMBOLS NECESSARILY USED ON PLAN.

RESPONSIBILITY MATRIX LEGEND

ITEM	FURNISHED BY	INSTALLED BY	COMMENTS
MAIN OVERCURRENT DEVICE AT LANDLORD'S SERVICE POINT	E	E	
SERVICE ENTRANCE CONDUIT(S) STUBBED TO LEASE SPACE	E	E	
SERVICE ENTRANCE FEEDERS STUBBED TO LEASE SPACE	E	E	
120/208V PANELS	E	E	5
LIGHTING FIXTURES AND LAMPS	E	GC	2
MUSIC SYSTEMS SPEAKER CABINET	O	O	1,2
MUSIC SYSTEM WIRING	O	O	1,2,3
EMERGENCY SYSTEM	O	O	

REMARKS:
 1. ALL EQUIPMENT WIRING AND EQUIPMENT INSTALLATION BY OTHERS
 2. GENERAL CONTRACTOR TO COORDINATE SCHEDULE AND DELIVERY WITH SUPPLIER. STANDARD SHIPPING PROVIDED BY GAP, INC. ANY EXPEDITED SHIPPING COSTS ARE THE RESPONSIBILITY OF THE GENERAL CONTRACTOR.
 3. ROUGH-IN BY GC
 4. FOR ROOFTOP UNITS ONLY WHEN LL PROVIDES ROOF TOP UNITS
 5. PANELS ARE EXISTING IN SPACE TO BE RELOCATED

LOEB ELECTRIC CONTACT INFORMATION

JOHN CALICOAT
 1800 E. 5TH AVENUE
 COLUMBUS, OHIO 43219

PHONE: 614-421-5058
 FAX: 614-299-6268
 EMAIL: TheGap@loebelectric.com

DRAWING SCHEDULE

NUMBER	TITLE
E0-1	ELECTRICAL NOTES AND LEGEND
ED1-0	ELECTRICAL DEMOLITION PLAN
E1-0	POWER PLAN
E1-0A	ROOF POWER PLAN
E1-1	LIGHTING PLAN
E1-2	TRACK LAYOUT PLAN
E4-0	LIGHT FIXTURE SCHEDULE
E5-0	EAS. DETAILS
E6-0	CASHWRAP DETAILS
E8-0	ELECTRICAL DETAILS
E9-0	POWER RISER AND SCHEDULES
E9-1	PANEL SCHEDULES
E9-4	ELECTRICAL DETAILS
E9-6	ELECTRICAL DETAILS
E11-0	ELECTRICAL DETAILS
E13-0	ELECTRICAL SPECIFICATIONS
E13-1	ELECTRICAL SPECIFICATIONS

NEW STORE

OLD NAVY


GAP, INC.
 CORPORATE ARCHITECTURE
 HARRIS STREET
 SAN FRANCISCO, CA 94105

REPS. ID: 0000054156


STORE NUMBER: 4458


STORE LOCATION: VINELAND
 8231 VINELAND AVENUE
 SUITE 2151
 ORLANDO, FLORIDA 32821

DESIGN TYPE: P3
 GENERATION: 17Q12
 PROTOTYPE DATE: 07/18/16
 OPENING: 2017

CONSULTANT INFO:

 EEA Consulting Engineers
 6615 Vaughn Ranch Road, Suite 100
 Austin, Texas 78730-2314 USA
 512.744.4400 main 512.744.4444 fax
 www.eea.com

State of Registration: FLORIDA
 Firm Registration No. 24645
 EEA Project No. 20169549

PROFESSIONAL STAMP

 SARAHAMILL
 LICENSE
 No. 74882
 STATE OF FLORIDA
 PROFESSIONAL ENGINEER
 4/1/17

ARCHITECT INFO:

 ARCHITECT OF RECORD: BRR ARCHITECTURE, INC.
 6702 ANTIOCH PLAZA, SUITE 300, NEARHAM, KANSAS 66204

ISSUE TYPE:
 PERMIT/BID: 04/07/17

REVISIONS:

DRAWN BY: DPR
 A/E JOB NUMBER: 65013011

TITLE SHEET:
 ELECTRICAL NOTES AND LEGEND

SHEET NUMBER:
E0-1