


FIRE ALARM SYSTEM SHOWN ON ELECTRICAL DRAWINGS ARE FOR SCHEMATIC AND BIDDING PURPOSES ONLY. FIRE ALARM SYSTEM CONTRACTOR SHALL SUBMIT FIRE DRAWINGS, EQUIPMENT CUT SHEETS, ETC. PER LOCAL CODE AND NFPA 72 TO LOCAL AUTHORITIES HAVING JURISDICTION AND OWNER'S INSURANCE COMPANY FOR APPROVAL PRIOR TO ORDERING EQUIPMENT. THE FIRE ALARM CONTRACTOR SHALL BE RESPONSIBLE FOR INSURING COMPATIBILITY BETWEEN THE FIRE ALARM SYSTEM AND THE LANDLORD'S CENTRAL SYSTEM WHEN REQUIRED TO CONNECT TO THE LANDLORD CENTRAL SYSTEM. ENGINEER SHALL APPROVE FIRE ALARM DRAWINGS, EQUIPMENT CUT SHEETS, ETC. INCLUDE IN BID ALL COSTS FOR PERMITS AND FEES. ALL PANELS AND PERIPHERAL DEVICES SHALL BE STANDARD PRODUCT OF SINGLE MANUFACTURER AND SHALL DISPLAY THE MANUFACTURER'S NAME ON EACH COMPONENT. ACCEPTABLE MODELS (UNLESS LANDLORD REQUIRES DIFFERENT): SILENT KNIGHT 5700 OR 5808. PROVIDE COVER PLATES FOR FIRE ALARM PULL STATIONS IF PERMITTED BY LOCAL CODE. IN NEW YORK CITY, THESE ARE NOT ACCEPTABLE AND A FIRELITE 9200 SERIES IS ALLOWED.

PROVIDE COVER PLATES FOR FIRE ALARM PULL STATIONS IF PERMITTED BY CODE.

LANDLORD MALL OR BUILDING FIRE ALARM CONNECTION
 THE FIRE ALARM SYSTEM REQUIRES CONNECTION TO THE LANDLORD CENTRAL SYSTEM. THE GENERAL CONTRACTOR SHALL BE RESPONSIBLE FOR CONNECTION TO THE LANDLORD CENTRAL SYSTEM.

CODED NOTE	MARK	TYPE	MANUFACTURER/MODEL	COLOR	MOUNTING HEIGHT	USE	NOTES
200	SF	Duplex	See Specifications	White	12" above glass	General	Install vertically on vertical face of storefront
202	WS	Duplex - UNO	Steel City 52151 SVT	White	18" AFF UNO	General	
203		J-Box	4" Sq X 1-1/2" deep	Grey	+40" See Arch drawings	Hand Dryer	
206							Power pole provided by cashwrap vendor. Route cashwrap power and buzzer/data/phone up through power pole to about 10', connect to a threaded rod and run overhead to non-sales location. Route one 3/4" conduit for isolated receptacles and one 3/4" for general receptacles, one 3/4" conduit for battery charger, one 3/4" conduit for hold-up button, and one 3/4" conduit for sound system volume control. Field verify exact location and requirements.
207		Duplex	See Specifications	White	6" above boothset	Marketing	
210		J-Box	4" SQ X 1-1/2" deep	Grey	44" AFF	ADT keypad	
212		Duplex	See Specifications	White	+27" See Arch dwgs 8/A7-0	Fitting room mirrors	From ceiling route 3/4" conduit directly to back side of fitting room mirror. Then flexible conduit (hidden) to each following mirror. Install one duplex outlet per mirror. Refer to architectural details.
215							Junction box for connection to ADA pushbuttons. Coordinate exact location and connection requirements prior to installation.
217							Provide J-box for manufacturer provided USB outlets in furniture. Coordinate connection requirements prior to rough-in.
229		Duplex	See Specifications	White	at deck	LP monitor	
230		J-Box	4" sq X 1-1/2" deep	Grey	see Arch drawings	Panic hardware; EM door	
303		J-Box	2" X 4" X 1-1/2" deep	Grey	48" AFF W/CONDUIT TO 12' AFF	HVAC Control	
311							Refer to A1-0 for trenching details.
400		USB OUTLET	HUBBELL USB 4W	WHITE	see Arch drawings	USB Power	



NEW STORE

OLD NAVY

GATLINC CORPORATION ARCHITECTURE
 HARRIS STREET
 SAN FRANCISCO, CA 94105

REPS. I.D.: 000054156

STORE NUMBER: 4458

STORE LOCATION: VINELAND AVENUE
 8231 VINELAND AVENUE
 SUITE 2151
 ORLANDO, FLORIDA 32821

DESIGN TYPE: P3
 GENERATION: 17Q12
 PROTOTYPE DATE: 07/18/16
 OPENING: 2017

CONSULTANT INFO:

EBA
 EBA Consulting Engineers
 6615 Vaught Ranch Road, Suite 100
 Austin, Texas 78739-2214 USA
 512.744.4400 main 512.744.4444 fax
 www.ebaec.com

State of Registration: FLORIDA
 Firm Registration No. 26645
 EBA Project No. 20169549

PROFESSIONAL STAMP:
 SARA HAMIL
 LICENSE
 No. 74882
 STATE OF
 FLORIDA
 PROFESSIONAL ENGINEER

ARCHITECT INFO:

B|R|R
 architecture

ARCHITECT OF RECORD: BRR ARCHITECTURE, INC.
 6709 ANTOCH PLAZA, SUITE 300, NEENAH, WISCONSIN 54956

ISSUE TYPE:

PERMIT/BID: 04/07/17

REVISIONS:

DRAWN BY: DPR
 A/E JOB NUMBER: 65013011

TITLE SHEET:
POWER PLAN

SHEET NUMBER:
E1-0