



- *NOTES:**
1. LOW VOLTAGE CABLES MAY BE RUN IN CABLE TRAY IN LIEU OF CONDUIT MAIN WHEN PERMITTED BY LOCAL AUTHORITIES AND LANDLORD.
 2. WIRING DIAGRAM SHOW ALL COMPONENTS FOR A NEW STORE. FOR ANY TWO EXISTING COMPONENTS, THE CONDUIT BETWEEN THE COMPONENTS WILL REMAIN AS IS. ONLY NEW OR RELOCATED COMPONENTS REQUIRE NEW CONDUIT.
 3. CONDUIT LENGTH SHALL NOT EXCEED 300 FT.
 4. ALL CONDUIT SHALL INCLUDE A PULLSTRING.

Order Plans