

| PANEL: LA | | VOLTAGE | 480/277 | | | PHASE/WIRE | 3/4 | | | LOCATION | UTILITY ROOM | | | | | | | |
|------------------|------|---------|-------------|------|----------------------|------------|------|-----|----|----------|------------------|------|--------|------------------------|------|------|-------|-----------------|
| MAIN BUS 400 | | MLO | FULLY RATED | | | NEUTRAL | 100% | | | BUS: | COPPER | GND: | COPPER | FAULT DUTY: 14,000 AIC | | | | |
| LOAD INFORMATION | | KVA | | | BREAKER RATING/POLES | | | KVA | | | LOAD INFORMATION | | | | | | | |
| LOAD | NOTE | TYPE | PH-A | PH-B | PH-C | ØKT | P | CB | PH | CB | P | ØKT | PH-A | PH-B | PH-C | TYPE | NOTE | LOAD |
| FIELD 2 POLE A4 | | | 2400 | | | 1 | | | A | | | 2 | 2400 | | | | | FIELD 1 POLE A1 |
| | | | | 2400 | | 3 | 3 | 30 | B | 40 | 3 | 4 | | 2400 | | | | |
| | | | | | 2400 | 5 | | | C | | | 6 | | | 2400 | | | |
| FIELD 2 POLE B4 | | | 4200 | | | 7 | | | A | | | 8 | 4200 | | | | | FIELD 1 POLE B1 |
| | | | | 4200 | | 9 | 3 | 40 | B | 40 | 3 | 10 | | 4200 | | | | |
| | | | | | 4200 | 11 | | | C | | | 12 | | | 4200 | | | |
| FIELD 2 POLE C4 | | | 1000 | | | 13 | | | A | | | 14 | 2000 | | | | | FIELD 1 POLE C1 |
| | | | | 1000 | | 15 | 3 | 30 | B | 40 | 3 | 16 | | 2000 | | | | |
| | | | | | 1000 | 17 | | | C | | | 18 | | | 2000 | | | |
| FIELD 2 POLE D4 | | | 2000 | | | 19 | | | A | | | 20 | 2000 | | | | | FIELD 1 POLE D1 |
| | | | | 2000 | | 21 | 3 | 30 | B | 40 | 3 | 22 | | 2000 | | | | |
| | | | | | 2000 | 23 | | | C | | | 24 | | | 2000 | | | |
| FIELD 2 POLE D3 | | | 2000 | | | 25 | | | A | | | 26 | 2000 | | | | | FIELD 1 POLE D2 |
| | | | | 2000 | | 27 | 3 | 30 | B | 40 | 3 | 28 | | 2000 | | | | |
| | | | | | 2000 | 29 | | | C | | | 30 | | | 2000 | | | |
| FIELD 2 POLE C3 | | | 1000 | | | 31 | | | A | | | 32 | 2000 | | | | | FIELD 1 POLE C2 |
| | | | | 1000 | | 33 | 3 | 30 | B | 40 | 3 | 34 | | 2000 | | | | |
| | | | | | 1000 | 35 | | | C | | | 36 | | | 2000 | | | |
| FIELD 2 POLE B3 | | | 4200 | | | 37 | | | A | | | 38 | 4200 | | | | | FIELD 1 POLE B2 |
| | | | | 4200 | | 39 | 3 | 40 | B | 40 | 3 | 40 | | 4200 | | | | |
| | | | | | 4200 | 41 | | | C | | | 42 | | | 4200 | | | |
| FIELD 2 POLE A3 | | | 2400 | | | 43 | | | A | | | 44 | 2400 | | | | | FIELD 1 POLE A2 |
| | | | | 2400 | | 45 | 3 | 30 | B | 40 | 3 | 46 | | 2400 | | | | |
| | | | | | 2400 | 47 | | | C | | | 48 | | | 2400 | | | |
| SPARE | | | | | | 49 | | | A | | | 50 | | | | | | SPARE |
| | | | | | | 51 | 3 | 30 | B | 30 | 3 | 52 | | | | | | |
| | | | | | | 53 | | | C | | | 54 | | | | | | |
| SPARE | | | | | | 55 | | | A | | | 56 | | | | | | SPARE |
| | | | | | | 57 | 3 | 30 | B | 30 | 3 | 58 | | | | | | |
| | | | | | | 59 | | | C | | | 60 | | | | | | |
| SPARE | | | | | | 61 | | | A | | | 62 | | | | | | SPARE |
| | | | | | | 63 | 3 | 40 | B | 40 | 3 | 64 | | | | | | |
| | | | | | | 65 | | | C | | | 66 | | | | | | |
| SPACE | | | | | 67 | 1 | 0 | A | 0 | 1 | 68 | | | | | | SPACE | |
| SPACE | | | | | 69 | 1 | 0 | B | 0 | 1 | 70 | | | | | | SPACE | |
| SPACE | | | | | 71 | 1 | 0 | C | 0 | 1 | 72 | | | | | | SPACE | |
| SPACE | | | | | 73 | 1 | 0 | A | 0 | 1 | 74 | | | | | | SPACE | |
| SPACE | | | | | 75 | 1 | 0 | B | 0 | 1 | 76 | | | | | | SPACE | |
| SPACE | | | | | 77 | 1 | 0 | C | 0 | 1 | 78 | | | | | | SPACE | |
| SPACE | | | | | 79 | 1 | 0 | A | 0 | 1 | 80 | | | | | | SPACE | |
| SPACE | | | | | 81 | 1 | 0 | B | 0 | 1 | 82 | | | | | | SPACE | |
| SPACE | | | | | 83 | 1 | 0 | C | 0 | 1 | 84 | | | | | | SPACE | |

| | | | | | | | | | | | |
|-------------------|------------------------|-------|--------|--|-------|-------|--|-------|-------|-------|--|
| MOUNTING: SURFACE | 19200 | 19200 | 19200 | | | | | 21200 | 21200 | 21200 | |
| ENCLOSURE: NEMA 1 | CONNECTED PHASE (KVA): | | | 40400 | 40400 | 40400 | | | | | |
| | CONNECTED CURRENT (A): | | | 145.8 | 145.8 | 145.8 | | | | | |
| | EMD (Amps) | | | 182.23 | | | | | | | |
| TYPE | KVA | DF | KVAxDF | LOAD TYPES: | | | | | | | |
| L | 121200 | 1.25 | 151500 | L - LIGHTING | | | | | | | |
| LM | 0 | 1.25 | 0 | LM - LARGEST MOTOR | | | | | | | |
| M | 0 | 1 | 0 | M - MOTOR LOAD | | | | | | | |
| O | 0 | 1.00 | 0 | O - MISC OR OTHER TYPE LOADS | | | | | | | |
| R | 0 | 1.00 | 0 | R - RECEPTACLE (First 10,000 VA per NEC) | | | | | | | |
| R | 0 | 0.50 | 0 | R - RECEPTACLE (over 10,000 VA per NEC) | | | | | | | |
| S | 0 | 0.50 | 0 | S - SPARE | | | | | | | |
| CND | 121200 | EMD | 151500 | | | | | | | | |
| | | | | EMD (Amps) 182.23 | | | | | | | |

| PANEL: LA | | VOLTAGE | 208/120 | | | PHASE/WIRE | 3/4 | | | LOCATION | UTILITY ROOM | | | | | | | |
|---------------------|------|---------|-------------|------|----------------------|------------|------|-----|----|----------|------------------|------|--------|------------------------|------|------|------|---------------------|
| MAIN BUS 225 | | 150 MCB | FULLY RATED | | | NEUTRAL | 100% | | | BUS: | COPPER | GND: | COPPER | FAULT DUTY: 14,000 AIC | | | | |
| LOAD INFORMATION | | KVA | | | BREAKER RATING/POLES | | | KVA | | | LOAD INFORMATION | | | | | | | |
| LOAD | NOTE | TYPE | PH-A | PH-B | PH-C | ØKT | P | CB | PH | CB | P | ØKT | PH-A | PH-B | PH-C | TYPE | NOTE | LOAD |
| MEETING ROOM | | | 540 | | | 1 | 1 | 20 | A | 20 | 1 | 2 | 600 | | | | | FIELDHOUSE LIGHTING |
| MEETING ROOM | | | | 540 | | 3 | 1 | 20 | B | 20 | 1 | 4 | | 600 | | | | FIELDHOUSE LIGHTING |
| UTILITY ROOM | | | | | 360 | 5 | 1 | 20 | C | 20 | 1 | 6 | | | 1200 | | | CONCESSIONS |
| GENERAL STORAGE (S) | | | 720 | | | 7 | 1 | 20 | A | 20 | 1 | 8 | 1200 | | | | | CONCESSIONS |
| GENERAL STORAGE (L) | | | | 540 | | 9 | 1 | 20 | B | 20 | 1 | 10 | | 1200 | | | | CONCESSIONS |
| COVERED AREA | | | | | 540 | 11 | 1 | 20 | C | 20 | 1 | 12 | | | 1200 | | | CONCESSIONS |
| BIG ASS FANS | | | 360 | | | 13 | 1 | 20 | A | 20 | 1 | 14 | 1200 | | | | | CONCESSIONS |
| CONCESSIONS STORAGE | | | | 540 | | 15 | 1 | 20 | B | 20 | 1 | 16 | | 1200 | | | | CONCESSIONS |
| WASHROOM | | | | | 540 | 17 | 1 | 20 | C | 20 | 1 | 18 | | | 1200 | | | CONCESSIONS |
| WASHROOM | | | 360 | | | 19 | 1 | 20 | A | 20 | 1 | 20 | | | 1200 | | | CONCESSIONS |
| WASHROOM | | | | 180 | | 21 | 1 | 20 | B | 20 | 1 | 22 | | 1200 | | | | CONCESSIONS |
| WATER FOUNTAIN | | | | | 360 | 23 | 1 | 20 | C | 20 | 1 | 24 | | | 1200 | | | CONCESSIONS |
| CONCESSIONS | | | 1000 | | | 25 | 1 | 20 | A | 20 | 2 | 26 | 3900 | | | | | HP-1 |
| DUGOUT | | | | 360 | | 27 | 2 | 30 | B | 20 | 2 | 28 | | 3900 | | | | HP-2 |
| DUGOUT | | | | | 360 | 29 | 2 | 30 | C | 20 | 2 | 30 | | | 3900 | | | HP-2 |
| DUGOUT | | | 360 | | | 31 | 1 | 20 | A | 20 | 2 | 32 | 3900 | | | | | HP-2 |
| DUGOUT | | | | 360 | | 33 | 1 | 20 | B | 20 | 2 | 34 | | 7000 | | | | AC-1 |
| DUGOUT | | | | | 360 | 35 | 1 | 20 | C | 20 | 2 | 36 | | | 7000 | | | AC-1 |
| DUGOUT | | | 360 | | | 37 | 2 | 30 | A | 20 | 2 | 38 | 7000 | | | | | AC-2 |
| DUGOUT | | | | 360 | | 39 | 2 | 30 | B | 20 | 2 | 40 | | 7000 | | | | AC-2 |
| DUGOUT | | | | | 360 | 41 | 1 | 20 | C | 20 | 1 | 42 | | | 500 | | | SCORE BOARD EAST |
| SERVER CLOSET | | | 540 | | | 43 | 1 | 20 | A | 20 | 1 | 44 | 500 | | | | | SCORE BOARD WEST |
| PUBLIC ADDRESS | | | | 180 | | 45 | 1 | 20 | B | 20 | 1 | 46 | | 0 | | | | EXTERIOR LIGHTING |
| CONCESSIONS | | | | | 1200 | 47 | 1 | 20 | C | 20 | 1 | 48 | | | 0 | | | EXTERIOR LIGHTING |
| CONCESSIONS | | | 1200 | | | 49 | 1 | 20 | A | 20 | 1 | 50 | | | | | | SPARE |
| CONCESSIONS | | | | 600 | | 51 | 1 | 20 | B | 20 | 1 | 52 | | | | | | SPARE |
| CONCESSIONS | | | | | 1200 | 53 | 2 | 30 | C | 20 | 1 | 54 | | | | | | SPARE |
| CONCESSIONS | | | 1200 | | | 55 | 2 | 30 | A | 20 | 1 | 56 | | | | | | SPARE |
| CONCESSIONS | | | | 600 | | 57 | 2 | 30 | B | 20 | 1 | 58 | | | | | | SPARE |
| CONCESSIONS | | | | | 600 | 59 | 2 | 30 | C | 20 | 1 | 60 | | | | | | SPARE |
| CONCESSIONS | | | 600 | | | 61 | 2 | 30 | A | 20 | 1 | 62 | | | | | | SPARE |
| CONCESSIONS | | | | 600 | | 63 | 2 | 30 | B | 20 | 1 | 64 | | | | | | SPARE |
| SPARE | | | | | | 65 | 1 | 20 | C | 20 | 1 | 66 | | | | | | SPARE |
| SPARE | | | | | | 67 | 1 | 20 | A | 20 | 1 | 68 | | | | | | SPARE |
| SPACE | | | | | | 69 | 1 | 20 | B | 20 | 1 | 70 | | | | | | SPACE |
| SPACE | | | | | | 71 | 1 | 20 | C | 20 | 1 | 72 | | | | | | SPACE |
| SPACE | | | | | | 73 | 1 | 20 | A | 20 | 1 | 74 | | | | | | SPACE |
| SPACE | | | | | | 75 | 1 | 20 | B | 20 | 1 | 76 | | | | | | SPACE |
| SPACE | | | | | | 77 | 1 | 20 | C | 20 | 1 | 78 | | | | | | SPACE |
| SPACE | | | | | | 79 | 1 | 20 | A | 20 | 1 | 80 | | | | | | SPACE |
| SPACE | | | | | | 81 | 1 | 20 | B | 20 | 1 | 82 | | | | | | SPACE |
| SPACE | | | | | | 83 | 1 | 20 | C | 20 | 1 | 84 | | | | | | SPACE |