



Bid Summary...▼	Questions & Answers (Bid RFIs)	\$ Submit your Bid online
-----------------	--------------------------------	---------------------------

General Contractor

Questions and Answers ☆ Submit New Question (RFI)

Question	<p><i>Sheet ALSP-1 indicates that the building in non sprinklered and has a limited area sprinkler system in the laundry room.</i></p> <p><i>Sheet C7.1 shows a 6" fire line going into the building with a remote fire department connection.</i></p> <p><i>Please confirm whether the building has a full fire sprinkler system or not.</i></p>
Answer	<p>The 6" fire line to and from the building as indicated on sheet C7.1 shall be deleted from the project. It is not required by design..</p> <p>By: GSB Travel Stops on 18-May-2017 02:40 PM EST</p>