

1 LIGHTING PLAN
SCALE: 1/4"=1'-0"


2 KEYNOTES (APPLY TO THIS SHEET ONLY)

- 1 EXISTING EMERGENCY LIGHT. FIXTURE CONNECTED SO THAT BATTERY PACK IS NOT SWITCHED WITH LIGHTS, BUT ALL LAMPS ARE SWITCHED.
- 2 EXISTING EMERGENCY LIGHT. FIXTURE CONNECTED SO THAT LAMP BALLAST AND EMERGENCY BALLAST ARE NOT SWITCHED. 'N' MARKED TO FIXTURE INDICATES THAT FIXTURE SHALL BE ON 24 HOURS.
- 3 NOT USED.
- 4 PROVIDE A TYPE B1 LIGHT FIXTURE. MOUNT TO THE UNDERSIDE OF THE WIRE SHELVING. PROVIDE FLEX CONDUIT AND CONNECT TO A SWITCH IN FS BOX MOUNTED TO THE SHELF. FROM FS BOX PROVIDE AN SO CORD WITH PLUG AND CONNECT TO THE GEN RECEPTACLE.
- 5 PROVIDE A TYPE B3 LIGHT FIXTURE. MOUNT TO THE UNDERSIDE OF THE WIRE SHELVING. FIXTURE PROVIDED WITH A PLUG & CORDSET - PLUG INTO A GEN RECEPTACLE. FIXTURE SHALL BE MOUNTED TO SHELF WITH HARDWARE THAT WILL NOT INTERFERE WITH THE USE OF THE SHELF.
- 6 CONNECT FIXTURE TO CIRCUIT HEAD OF ALL SWITCHING AND CONTROLS. THIS FIXTURE SHALL NOT BE SWITCHED.
- 7 PROVIDE CLIX-STYLE REPLACEMENT EQUIVALENT TO COOPER / ARROWHART R1780W. FIELD COORDINATE LOCATION.
- 8 PLUG LIGHT SWITCH FOR CONTROL OF THE FLUORESCENT LIGHT INSIDE THE OR WIF UNIT. PROVIDE CONDUIT SEAL-OFF FITTINGS FOR ALL CONDUIT PENETRATIONS THROUGH FREEZER'S WALL. FLUORESCENT LIGHT FURNISHED WITH THE UNIT BY THE EQUIPMENT SUPPLIER.
- 9 STUB NEW 1/2" CONDUIT DOWN IN WALL TO THE EXTERIOR DOOR'S FRAME FOR THE SECURITY SYSTEM. VERIFY ALL REQUIREMENTS WITH THE OWNER'S SECURITY SYSTEM VENDOR.
- 10 COORDINATE CONNECTION OF REPLACEMENT SIGNAGE TO EXISTING CKT.

3 LIGHTING FIXTURE (LUMINAIRE) SCHEDULE - CHICK-FIL-A FSU - STORE #2593 (HERITAGE)

MARK	MANUFACTURER	CATALOG NUMBER	NO. LAMPS/TYPE	STL LAMP NO.	WATTS	VOLTS	MOUNTING	REMARKS
A	LITHONIA	2GT8-G-432-A12V-MVOLT-OSIOIS	4-F028/B35/XP/SS/ECO	2278	99	120	RECESSED	2X4' STATIC TROFFER. SMOOTH SIDE OF PRISMATIC LENS DOWN.
AE	LITHONIA	2GT8-G-432-A12V-MVOLT-OSIOIS-ELJ4	4-F028/B35/XP/SS/ECO	2278	99	120	RECESSED	SAME AS 'A' WITH EMERGENCY BATTERY PACK. SEE PLAN NOTES ABOUT LAMP SWITCHING.
B1	ILLUMITEX	CSI-24-4-DW-6-35-U-WH	INTEGRAL WITH FIXTURE	-	35	120	SURFACE	SEE KEYNOTE #4, THIS SHEET, FOR ADDITIONAL INFORMATION.
B3	CON-TECH	UF228-P WITH PLUG & CORDSET	I-FP28/B35/ECO	20901	31	120	SURFACE	SEE KEYNOTE #5, THIS SHEET, FOR ADDITIONAL INFORMATION.

- NOTES:
- LUMINAIRES UTILIZING DOUBLE-ENDED LAMPS AND CONTAIN BALLASTS THAT CAN BE SERVICED IN PLACE SHALL HAVE A DISCONNECTING MEANS EITHER INTERNAL OR EXTERNAL TO EACH LUMINAIRE PER NEC 410.130(G).
 - THE LIGHTING FIXTURE PACKAGE IS AVAILABLE THROUGH A NATIONAL ACCOUNT PROGRAM. REFER TO SHEET E42, SECTION 16500 FOR VENDOR INFORMATION.
 - THE FLUORESCENT BALLAST CATALOG NUMBER INDICATES OSRAM AND ALL LAMP DESIGNATIONS ARE FOR OSRAM/SYLVANIA PER A NATIONAL ACCOUNT AGREEMENT.



Chick-fil-A

5200 Buffington Rd.
Atlanta Georgia,
30349-2998

Revisions:
Mark Date By
△ 06.30.17
ISSUED FOR PERMIT

Mark Date By
△ 07.11.17
ISSUED FOR BID

Mark Date By
△

Seal
STATE OF KENTUCKY
MARK T. KURZYNSKE
1 2
07-11-17

Kurzynske & Associates
CONSULTING ENGINEERS
2900 Lebanon Pike, Ste 201
Nashville, Tennessee 37214
Telephone: (615) 255-5203
Fax: (615) 255-5207
Email: mail@kurzynske.com

STORE #02593
HOUSTON ROAD FSU

4980 HOUSTON RD
FLORENCE, KY
41042

SHEET TITLE
LIGHTING PLAN

VERSION: S08C-R
ISSUE DATE: 05.2017

Job No. : 17091.CD.R
Store : 02593
Date : 06.30.17
Drawn By : RW
Checked By : MK

Sheet