



PLAN NORTH
1 FIRST FLOOR PLUMBING DEMOLITION PLAN
 SCALE: 1/8" = 1'-0"

- DEMOLITION NOTES:**
- ① REMOVE DEADLEG BACK TO MAIN. REMOVE TEE FROM MAIN AND PROVIDE NEW PIPING AND INSULATION TO MATCH EXISTING.
 - ② REMOVE 1 1/2" DCW RISER UP TO SECOND FLOOR. REMOVE DEADLEG BACK TO MAIN WHERE LAVATORIES IN MENS 124 ARE FED. REMOVE TEE AND PROVIDE NEW PIPING AND INSULATION TO MATCH EXISTING. FIRESTOP OPENING IN SECOND FLOOR SLAB.

- GENERAL NOTES:**
- 1. REFER TO THE DOMESTIC WATER DEAD LEG AND ASBESTOS ABATEMENT SCHEDULE FOR PIPING CONTAINING ASBESTOS INSULATION.

Order Plans @ WWW.DLine.com

Revisions	Date

Atrix
 Atrix, p.l.c.
 102 3rd Avenue, NE
 PO Box 1628,
 Hickory, NC 28603
 Phone: 828.315.9962
 Fax: 828.315.9964
 www.atrigroup.com

WileyWilson
 WileyWilson
 127 Nationwide Drive
 Lynchburg, VA 24502
 Phone: 434.947.1901
 www.wileywilson.com



Approved: Energy Engineer
CONSTRUCTION DOCUMENTS

Approved: Safety Manager
 Approved: Infection Control Officer
 Approved: GEMS Coordinator

Approved: Service Chief
 Approved: Chief of Staff
 Approved: Associate Director

Drawing Title
**PD-9-103
 BLDG 9 FIRST FLOOR PLUMBING PLAN
 DEMOLITION**
 Approved: Chief of Facility Management Svc.
 Approved: Medical Center Director

Project Title
RENOVATE FOR WATER QUALITY
 Building Number
9
 Location
VA MEDICAL CENTER, SALEM, VA 24153

Date
04/28/2017
 Project No.
658-15-101
 DRAWING SET
2592
 Dwg. 41 Of 155

Veterans Affairs