



DOMESTIC WATER DEAD LEG REMOVAL AND ASBESTOS ABATEMENT SCHEDULE

BUILDING NUMBER	FLOOR NUMBER	DEAD LEG NUMBER	ROOM NUMBER	USE (HOT WATER, HOT WATER RECIRC, OR COLD WATER)	IS DEAD LEG ACCESSIBLE WITHOUT ARCH DEMOLITION OF SURFACE (Y/N)	ABOVE LAY-IN CEILING (Y/N)	PIPING MATERIAL	PIPE SIZE INCH	MAIN PIPE SIZE INCH	LENGTH OF DEAD LEG TO BE REMOVED FEET	ASBESTOS PIPE INSULATION (Y/N)	SHUTOFF VALVE LOCATION	WHEN CAN WORK BE PERFORMED?	REFERENCE DRAWING
143	4	01	4H-114 AND C4-17	HOT RECIRC WATER	Y	Y	COPPER	1/2"	3/4"	15	N	4H-114	NIGHT	PD-143-115
143	4	02	4H-113	HOT/COLD WATER	Y	Y	COPPER	H/C-1/2"	H/C-3/4"	10	N	4H-114	NIGHT	PD-143-115
143	4	03	4H-113	COLD WATER	Y	Y	COPPER	3/4"	3/4"	1	N	4H-114	NIGHT	PD-143-115
143	4	04	4H-106A	HOT/COLD WATER	Y	Y	COPPER	H/C-1/2"	H-1", C-2"	H/C-2	N	4H-114	NIGHT	PD-143-115
143	4	05	4H-136 AND 4H-119	HOT/COLD WATER	Y	Y	COPPER	H/C-1/2"	H/C-3/4"	H/C-35	N	4H-114	NIGHT	PD-143-115
143	4	06	4H-136	HOT/COLD WATER	Y	Y	COPPER	H/C-1/2"	H/C-3/4"	H/C-10	N	4H-114	NIGHT	PD-143-115
143	4	07	4H-126	HOT/COLD WATER	Y	Y	COPPER	H/C-1/2"	H-3/4", C-2"	H/C-3	N	C4-19	DAY	PD-143-115
143	4	08	4J-151A	COLD WATER	Y	Y	COPPER	1/2"	2"	3	N	4J-153	NIGHT	PD-143-115
143	4	09	4J-132	HOT/COLD WATER	Y	Y	COPPER	H/C-1/2"	H-3/4", C-2"	H/C-5	N	4J-118	NIGHT	PD-143-116
143	4	10	4J-140	HOT/COLD WATER	Y	Y	COPPER	H/C-1/2"	H/C-3/4"	H/C-10	N	4J-118	NIGHT	PD-143-116
143	4	11	4J-140 AND 4J-122	HOT/COLD WATER	Y	Y	COPPER	H/C-1/2"	H/C-3/4"	H/C-25	N	4J-122A	DAY	PD-143-116
143	4	12	4J-117	HOT/COLD WATER	Y	Y	COPPER	H/C-3/4"	H-3/4", C-2"	H/C-5	N	4J-118	NIGHT	PD-143-116
143	4	13	C4-6 AND 4J-110A	HOT/COLD WATER	Y	Y	COPPER	H/C-3/4"	H-2 1/2", C-3"	H/C-40	N	4J-118	NIGHT	PD-143-116
143	4	14	C4-7, 4J-115, 4J-118	HOT RECIRC WATER	Y	Y	COPPER	3/4"	3/4"	40	N	4J-118	NIGHT	PD-143-116
143	4	15	C4-7 AND 4J-118	HOT RECIRC WATER	Y	Y	COPPER	3/4"	3/4"	25	N	4J-118	NIGHT	PD-143-116

GENERAL NOTES:

- "DAY" WORK HOURS ARE 7:00 AM TO 5:00 PM. "NIGHT" WORK HOURS ARE 5:01 PM TO 6:59 AM.
- SHUTDOWN OF THE DOMESTIC WATER SYSTEM IN ORDER TO PERFORM REMOVAL OF DEAD LEG(S) SHALL BE LIMITED TO 4 HOURS.
- ONLY VA EMPLOYEES MAY OPERATE WATER SYSTEM VALVES. PROVIDE AT LEAST 7 DAYS ADVANCE NOTICE.
- IN LIEU OF CLOSING ISOLATION VALVES AND PERFORMING DEAD LEG REMOVAL WORK, NIGHT, PIPE FREEZING CAN BE UTILIZED BY THE CONTRACTOR, ON APPROVAL OF THE COR. PROVIDE 5 DAYS ADVANCE NOTICE.

Order Plans @

www.LDILine.com

Revisions	Date

 Atriax, pllc 102 3rd Avenue, NE PO Box 1628, Hickory, NC 28603 Phone: 828.315.9962 Fax: 828.315.9964 www.atriaxgroup.com	 Wiley Wilson 127 Nationwide Drive Lynchburg, VA 24502 Phone: 434.947.1901 www.wileywilson.com
--	---



Approved: Energy Engineer

CONSTRUCTION DOCUMENTS

Approved: Safety Manager

Approved: Infection Control Officer

Approved: GEMS Coordinator

Approved: Service Chief

Approved: Chief of Staff

Approved: Associate Director

Drawing Title
PD-605 DOMESTIC WATER DEAD LEG REMOVAL SCHEDULE

Approved: Chief of Facility Management Svcs.

Approved: Medical Center Director

Project Title
RENOVATE FOR WATER QUALITY

Building Number

Checked MJG

Location
VA MEDICAL CENTER, SALEM, VA 24153

Date
04/28/2017

Project No.
658-15-101

DRAWING SET
2592

Dwg. 74 Of 155

Veterans Affairs