CONSTRUCTION NOTES:

1. PROVIDE THERMOSTATIC MIXING VALVE BELOW SINK/LAVATORY PER DETAIL C DRAWING PL-501.
2. PROVIDE THERMOSTATIC MIXING VALVE IN CEILING ABOVE LAV PER DETAIL D DRAWING PL-501.
3. PROVIDE THERMOSTATIC MIXING VALVE IN CEILING ABOVE CLOSET SINK FAUCET. MIXING VALVE SHALL SERVE CLINIC SINK FAUCET AND BEDPAN WASHER FOOT PEDAL PER DETAIL D DRAWING PL-501.
4. REMOVE SHOWER VALVE AND PROVIDE ASSE 1016 THERMOSTATIC AND PRESSURE BALANCING COMBINATION SHOWER VALVE. REMOVE AND REPLACE PORTION OF WALL TO ALLOW INSTALLATION OF NEW SHOWER VALVE.
5. INSULATE PIPING WITH FLEXIBLE ELASTOMERIC INSULATION.
6. PROVIDE TEMPERATURE SENSOR IN DCW AND CONNECT TO DDC PANEL LOCATED IN SVC BAY 3J-118. SEE DWG. PL-143-115.
7. PROVIDE TEMPERATURE SENSOR IN DHW AND CONNECT TO DDC PANEL LOCATED IN SVC BAY 3J-118. SEE DWG. PL-143-115.

MATCHLINE: SEE DWG. PL-143-113

PLAN NORTH

1 SECOND FLOOR PLUMBING PLAN - AREA "A"
SCALE: 1/8" = 1'-0"



PLAN NORTH

SECOND FLOOR KEY PLAN

Order Plans @ WWW.DILine.com

Revisions	Date
-	-

Atriax, pllc
102 3rd Avenue, NE
PO Box 1629,
Hickory, NC 28603
Phone: 828.315.9962
Fax: 828.315.9984
www.atriaxgroup.com

WileyWilson
127 Nationwide Drive
Lynchburg, VA 24502
Phone: 434.947.1901
www.wileywilson.com

COMMONWEALTH OF VIRGINIA
MICHAEL J. GEHL
Lic. No. 24298
4/28/2017
PROFESSIONAL ENGINEER

Approved: Energy Engineer	Approved: Safety Manager	Approved: Service Chief
CONSTRUCTION DOCUMENTS	Approved: Infection Control Officer	Approved: Chief of Staff
	Approved: GEMS Coordinator	Approved: Associate Director

Drawing Title: PL-143-112 BLDG 143 SECOND FLOOR PLUMBING PLAN NEW WORK	Project Title: RENOVATE FOR WATER QUALITY		Date: 04/28/2017
			Project No.: 658-15-101
Approved: Chief of Facility Management Svc.	Building Number: 143	Checked: MJG / Drawn: JFC	DRAWING SET: 2592
Approved: Medical Center Director	Location: VA MEDICAL CENTER, SALEM, VA 24153		Dwg. 113 Of 155

Veterans Affairs