



PLAN NORTH
1 SECOND FLOOR PLUMBING PLAN
SCALE: 1/8" = 1'-0"

CONSTRUCTION NOTES:

- 1 PROVIDE THERMOSTATIC MIXING VALVE BELOW SINK/LAVATORY PER DETAIL 'C' ON DRAWING PL-501.
- 2 PROVIDE THERMOSTATIC MIXING VALVE IN CEILING ABOVE LAV FOOT PEDAL PER DETAIL 'D' ON DRAWING PL-501.
- 3 REMOVE SHOWER VALVE AND PROVIDE ASSE 1016 ADA COMPLIANT, TRI-LEVER HANDLE THERMOSTATIC AND PRESSURE BALANCING COMBINATION SHOWER VALVE. SHOWER VALVE HAS A REMOVABLE STAINLESS STEEL ACCESS PANEL.
- 4 REMOVE EXISTING MIXING VALVE AND PROVIDE ASSE 1070 MIXING VALVE SET AT 110 DEGREES FAHRENHEIT.
- 5 PROVIDE THERMOSTATIC MIXING VALVE IN CEILING ABOVE CLINIC SINK FAUCET. MIXING VALVE SHALL SERVE SINK FAUCET AND PAN WASHER FOOT PEDAL PER DETAIL 'D' ON DRAWING PL-501.
- 6 PROVIDE COMBINATION SHUTOFF/CALIBRATED BALANCING VALVE ON DHWR. BALANCE TO 0.5 GPM.
- 7 PROVIDE COMBINATION SHUTOFF/CALIBRATED BALANCING VALVE ON DHWR. BALANCE TO 1.0 GPM.
- 8 PROVIDE TEMPERATURE TRANSMITTER IN DCW AND CONNECT TO DDC PANEL LOCATED IN HVC RM 37.
- 9 PROVIDE TEMPERATURE TRANSMITTER IN DHW AND CONNECT TO DDC PANEL LOCATED IN HVC RM 37.
- 10 PROVIDE CHLORINE ANALYZER. CONNECT TO DDC PANEL LOCATED IN HVC RM 37. PROVIDE 1/2" SAMPLE OUTLET DRAIN PIPING TO SERVICE SINK. PROVIDE SHUTOFF VALVE IN VERTICAL ON 1/2" DCW SUPPLY.
- 11 PROVIDE NEW BUTTERFLY VALVE.
- 12 PROVIDE NEW BALL VALVE.

Order Plans @ WWW.DIline.com

| Revisions | Date |
|-----------|------|
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |

Atriax, pllc
 102 3rd Avenue, NE
 PO Box 1628,
 Hickory, NC 28603
 Phone: 828.315.9962
 Fax: 828.315.9964
 www.atriaxgroup.com

Wiley Wilson
 127 Nottoway Drive
 Lynchburg, VA 24502
 Phone: 434.947.1901
 www.wileywilson.com



Approved: Energy Engineer

CONSTRUCTION DOCUMENTS

Approved: Safety Manager

Approved: Infection Control Officer

Approved: GEMS Coordinator

Approved: Service Chief

Approved: Chief of Staff

Approved: Associate Director

Drawing Title
**PL-7-103
 BLDG 7 SECOND FLOOR PLUMBING PLAN
 NEW WORK**

Approved: Chief of Facility Management Svcs.

Approved: Medical Center Director

Project Title
RENOVATE FOR WATER QUALITY

Building Number
7

Location
VA MEDICAL CENTER, SALEM, VA 24153

Date
04/28/2017

Project No.
658-15-101

DRAWING SET
2592

Dwg. 85 Of 155

Veterans Affairs