



CONSTRUCTION NOTES:

- 1 PROVIDE THERMOSTATIC MIXING VALVE BELOW SINK/LAVATORY PER DETAIL 'C' ON DRAWING PL-501.
- 2 PROVIDE THERMOSTATIC MIXING VALVE IN CEILING ABOVE LAV PER DETAIL 'D' ON DRAWING PL-501.
- 3 REMOVE SHOWER VALVE AND PROVIDE ASSE 1016 THERMOSTATIC AND PRESSURE BALANCING COMBINATION SHOWER VALVE. REMOVE AND REPLACE PORTION OF TILE WALL TO ALLOW INSTALLATION OF NEW SHOWER VALVE.
- 4 REMOVE FAUCET AERATOR AND PROVIDE LAMINAR FLOW OUTLET.
- 5 INSULATE PIPING TO MATCH EXISTING.

www.DLine.com

Order Plans

Revisions	Date

Atrix
Atrix, pllc
102 3rd Avenue, NE
PO Box 1628,
Hickory, NC 28603
Phone: 828.315.9962
Fax: 828.315.9964
www.atrigrup.com

WileyWilson
WileyWilson
127 Nationwide Drive
Lynchburg, VA 24502
Phone: 434.947.1901
www.wileywilson.com



Approved: Energy Engineer
Approved: Safety Manager
Approved: Infection Control Officer
Approved: GEMS Coordinator
Approved: Service Chief
Approved: Chief of Staff
Approved: Associate Director

Drawing Title PL-77-103 BLDG 77 FIRST FLOOR PLUMBING PLAN NEW WORK
Approved: Chief of Facility Management Svcs.
Approved: Medical Center Director

Project Title RENOVATE FOR WATER QUALITY			
Date 04/28/2017			
Project No. 688-15-101			
Building Number 77	Checked MJG	Drawn JFC	DRAWING SET 2592
Location VA MEDICAL CENTER, SALEM, VA 24153			

Date
Project No.
DRAWING SET
Dwg. 99 Of 155

Veterans Affairs

CONSTRUCTION DOCUMENTS