



DOMESTIC WATER PIPE REINSULATION SCHEDULE

BUILDING NUMBER	FLOOR NUMBER	INSULATION NUMBER	ROOM	USE (HOT WATER, HOT WATER RECIRC OR COLD WATER)	IS INSULATION ACCESSIBLE WITHOUT ARCH. DEMOLITION OF SURFACE (Y/N)?	ABOVE LAY-IN CEILING (Y/N)?	PIPING MATERIAL	PIPE SIZE (INCH)	PIPE LENGTH (INCHES)	NUMBER OF 90 DEG ELBOWS	ADDITIONAL FITTINGS/VALVES	REFERENCE DRAWING
9	1	9-INS-1-03	TOILET (111)	COLD WATER	Y	Y	COPPER	3/4"	240	5	(5) GATE VALVES	PL-9-103
9	1	9-INS-1-04	TOILET (111)	COLD WATER	Y	N	COPPER	1 1/2"	400	1	-	PL-9-103
9	1	9-INS-1-05	TOILET (117)	HOT WATER	Y	Y	COPPER	1"	140	3	-	PL-9-103
9	1	9-INS-1-06	TOILET (117)	HOT WATER RECIRC	Y	Y	COPPER	3/4"	150	3	-	PL-9-103
9	1	9-INS-1-07	TOILET (117)	COLD WATER	Y	Y	COPPER	1 1/4"	180	4	-	PL-9-103
9	1	9-INS-1-08	TOILET (117), EQUIPMENT STORAGE (118A)	COLD WATER	Y	Y	COPPER	1/2"	300	4	-	PL-9-103
9	1	9-INS-1-09	GROUP ROOM (118C)	COLD WATER	Y	Y	COPPER	1/2"	50	2	-	PL-9-103
9	1	9-INS-1-10	AUDIO/VISUAL STORAGE (118)	COLD WATER	Y	Y	COPPER	1"	130	-	(1) BALL VALVE	PL-9-103
9	2	9-INS-2-01	BATHROOM CHASE (210A)	COLD WATER	Y	N	COPPER	1"	20	-	-	PL-9-104
9	2	9-INS-2-02	BATHROOM CHASE (210A)	COLD WATER	Y	N	COPPER	3/4"	25	1	-	PL-9-104
9	2	9-INS-2-03	BATHROOM CHASE (210A)	COLD WATER	Y	N	COPPER	1"	20	-	-	PL-9-104
9	2	9-INS-2-04	BATHROOM CHASE (210A)	COLD WATER	Y	N	COPPER	1"	20	-	-	PL-9-104
9	2	9-INS-2-05	BATHROOM CHASE (210A)	HOT WATER RECIRC	Y	N	COPPER	1/2"	20	-	-	PL-9-104
9	2	9-INS-2-06	BATHROOM CHASE (210A)	COLD WATER	Y	N	COPPER	1"	20	-	-	PL-9-104
9	2	9-INS-2-07	BATHROOM CHASE (210A)	COLD WATER	Y	N	COPPER	1"	30	1	-	PL-9-104
9	2	9-INS-2-08	BATHROOM CHASE (210A)	COLD WATER	Y	N	COPPER	1/2"	75	1	-	PL-9-104
9	2	9-INS-2-09	BATHROOM CHASE (227B)	HOT WATER RECIRC	Y	N	COPPER	1"	30	2	-	PL-9-104
9	2	9-INS-2-10	BATHROOM CHASE (229A)	COLD WATER	Y	N	COPPER	3/4"	20	1	-	PL-9-104
9	2	9-INS-2-11	BATHROOM (217)	HOT WATER	Y	N	COPPER	1/2"	30	1	-	PL-9-104
9	2	9-INS-2-12	BATHROOM (217)	HOT WATER RECIRC	Y	N	COPPER	1/2"	20	1	-	PL-9-104
9	2	9-INS-2-13	BATHROOM (217)	HOT WATER	Y	N	COPPER	1/2"	30	1	-	PL-9-104
9	2	9-INS-2-14	BATHROOM (217)	COLD WATER	Y	N	COPPER	1/2"	50	1	-	PL-9-104
9	2	9-INS-2-15	BATHROOM (217)	COLD WATER	Y	N	COPPER	1/2"	50	1	-	PL-9-104
12	CRAWL SPACE	12-INS-CS-01	CRAWL SPACE	COLD WATER	Y	N	COPPER	4"	90	2	(2) GATE, (2) CHECK, (1) STRAINER, (1) FLANGE	PL-12-401
12	CRAWL SPACE	12-INS-CS-02	CRAWL SPACE	HOT WATER RECIRC	Y	N	COPPER	1/2"	60	1	-	PL-12-101
12	CRAWL SPACE	12-INS-CS-03	CRAWL SPACE	COLD WATER	Y	N	COPPER	1/2"	150	3	-	PL-12-101
12	CRAWL SPACE	12-INS-CS-04	CRAWL SPACE	HOT WATER	Y	N	COPPER	1/2"	80	2	-	PL-12-101
12	CRAWL SPACE	12-INS-CS-05	CRAWL SPACE	HOT WATER RECIRC	Y	N	COPPER	3/4"	50	1	(1) BALL VALVE, (1) BALANCING VALVE	PL-12-101
12	CRAWL SPACE	12-INS-CS-06	CRAWL SPACE	COLD WATER HOT WATER HOT WATER RECIRC	Y	N	COPPER	1 1/4" 3/4" 1/2"	12 50 60	2 2 2	- - (1) BALANCING VALVE	PL-12-101
12	CRAWL SPACE	12-INS-CS-07	CRAWL SPACE	COLD WATER	Y	N	COPPER	2"	180	2	(1) GATE VALVE	PL-12-101
12	CRAWL SPACE	12-INS-CS-08	CRAWL SPACE	HOT WATER	Y	N	COPPER	1"	15	1	-	PL-12-101
12	CRAWL SPACE	12-INS-CS-09	CRAWL SPACE	HOT WATER RECIRC	Y	N	COPPER	3/4"	70	-	(1) BALL VALVE	PL-12-101
12	CRAWL SPACE	12-INS-CS-10	CRAWL SPACE	COLD WATER	Y	N	COPPER	3/4"	120	1	-	PL-12-101
12	CRAWL SPACE	12-INS-CS-11	CRAWL SPACE	HOT WATER	Y	N	COPPER	1/2"	120	1	-	PL-12-101
12	CRAWL SPACE	12-INS-CS-12	CRAWL SPACE	COLD WATER	Y	N	COPPER	3/4"	60	-	-	PL-12-101

Order Plans

Revisions	Date

**Atriax**  
Atriax, pllc  
102 3rd Avenue, NE  
PO Box 1628,  
Hickory, NC 28603  
Phone: 828.315.9962  
Fax: 828.315.9964  
www.atriaxgroup.com

**Wiley Wilson**  
Wiley Wilson  
127 Nationwide Drive  
Lynchburg, VA 24502  
Phone: 434.947.1901  
www.wileywilson.com



Approved: Energy Engineer	Approved: Safety Manager	Approved: Service Chief	Project Title	Date			
<b>CONSTRUCTION DOCUMENTS</b>	Approved: Infection Control Officer	Approved: Chief of Staff	PL-604 SCHEDULES	04/28 / 2017			
	Approved: GEMS Coordinator	Approved: Associate Director	Project No.	658-15-101			
			Approved: Chief of Facility Management Svc.	Building Number	Checked MJC	Drawn WJC	DRAWING SET
		Approved: Medical Center Director	Location			2592	Dwg. 128 Of 155
			VA MEDICAL CENTER, SALEM, VA 24153				