



DOMESTIC WATER PIPE REINSULATION SCHEDULE

BUILDING NUMBER	FLOOR NUMBER	INSULATION NUMBER	ROOM	USE (HOT WATER, HOT WATER RECIRC OR COLD WATER)	IS INSULATION ACCESSIBLE WITHOUT ARCH DEMOLITION OF SURFACE (Y/N)?	ABOVE LAY-IN CEILING (Y/N)?	PIPING MATERIAL	PIPE SIZE (INCH)	PIPE LENGTH (INCHES)	NUMBER OF 90 DEG ELBOWS	ADDITIONAL FITTINGS/VALVES	REFERENCE DRAWING
77	BASEMENT	77-INS-B-03	GIP STORAGE (5)	COLD WATER	Y	Y	COPPER	1 1/2"	40	1	-	PL-77-102
77	BASEMENT	77-INS-B-04	GIP STORAGE (5)	COLD WATER	Y	Y	COPPER	3/4"	70	-	-	PL-77-102
77	1	77-INS-1-01	MED LIBRARY (115)	COLD WATER	Y	Y	COPPER	1/2"	40	1	-	PL-77-103
77	1	77-INS-1-02	MED LIBRARY (115)	HOT WATER	Y	Y	COPPER	1/2"	20	1	-	PL-77-103
77	1	77-INS-1-03	STORAGE (106C)	COLD WATER	Y	N	COPPER	1/2"	20	1	-	PL-77-103
77	1	77-INS-1-04	STORAGE (106C)	HOT WATER	Y	N	COPPER	1/2"	20	1	-	PL-77-103
77	1	77-INS-1-05	WOMENS TOILET (129A)	COLD WATER	Y	Y	COPPER	1/2"	40	1	-	PL-77-103
77	1	77-INS-1-06	WOMENS TOILET (126A)	COLD WATER	Y	Y	COPPER	1"	160	-	-	PL-77-103
77	1	77-INS-1-07	TOILETS (128 & 129A)	HOT WATER	Y	Y	COPPER	1/2"	210	5	-	PL-77-103
143	SUB-BASEMENT	143-INS-SB-01	SUB-BASEMENT	COLD WATER	Y	N	COPPER	1/2"	120	2	-	PL-143-401
143	SUB-BASEMENT	143-INS-SB-02	MAIN MECH ROOM (SD-100)	COLD WATER	Y	Y	COPPER	1/2"	60	2	-	PL-143-101
143	SUB-BASEMENT	143-INS-SB-03	MAIN MECH ROOM (SD-100)	HOT WATER	Y	N	COPPER	1/2"	570 30	5	(2) BALL VALVES	PL-143-101
143	SUB-BASEMENT	143-INS-SB-04	SUB-BASEMENT	HOT WATER RECIRC	Y	Y	COPPER	1 1/4"	20	1	-	PL-143-102
143	SUB-BASEMENT	143-INS-SB-05	SUB-BASEMENT	HOT WATER RECIRC	Y	N	COPPER	1 1/4"	90	-	-	PL-143-102
143	SUB-BASEMENT	143-INS-SB-06	SUB-BASEMENT	HOT WATER RECIRC	Y	N	COPPER	1 1/4"	20	1	-	PL-143-102
143	SUB-BASEMENT	143-INS-SB-07	SUB-BASEMENT	HOT WATER RECIRC	Y	N	COPPER	3/4"	190	-	-	PL-143-103
143	SUB-BASEMENT	143-INS-SB-08	SUB-BASEMENT	HOT WATER RECIRC	Y	N	COPPER	3/4"	130	-	-	PL-143-103
143	SUB-BASEMENT	143-INS-SB-09	SUB-BASEMENT	HOT WATER RECIRC	Y	N	COPPER	3/4"	70	1	-	PL-143-103
143	BASEMENT	143-INS-B-01	ENTRANCE (BE-107)	COLD WATER	Y	Y	COPPER	1/2"	330	4	-	PL-143-104
143	BASEMENT	143-INS-B-02	STAFF TOILET (BE-111)	COLD WATER	Y	Y	COPPER	1/2"	70	2	-	PL-143-104
143	BASEMENT	143-INS-B-03	ELEVATOR LOBBY OFFICE (BC-36) (BC-106)	HOT WATER RECIRC	Y	Y	COPPER	3/4"	200	-	-	PL-143-104
143	BASEMENT	143-INS-B-04	CAFE (BA-102) MENS TOILET (BA-101)	HOT WATER	Y	Y	COPPER	1/2"	360	4	-	PL-143-105
143	BASEMENT	143-INS-B-05	DEC RM (BD-103) TOILET (BD-102A)	HOT WATER	Y	Y	COPPER	1/2"	120	2	-	PL-143-106
143	BASEMENT	143-INS-B-06	DEC RM (BD-103) TOILET (BD-102A)	COLD WATER	Y	Y	COPPER	1/2"	130	2	-	PL-143-106
143	BASEMENT	143-INS-B-07	MALE SHOWER (BD-107)	COLD WATER	Y	Y	COPPER	1/2"	90	2	-	PL-143-106
143	BASEMENT	143-INS-B-08	CORRIDOR (CB-24)	HOT WATER RECIRC	Y	Y	COPPER	3/4"	160	-	-	PL-143-106
143	BASEMENT	143-INS-B-09	PT DRESSING (BC-103)	HOT WATER RECIRC	Y	Y	COPPER	3/4"	300	3	-	PL-143-106
143	BASEMENT	143-INS-B-10	S ELEVATOR LOBBY (CB-36)	HOT WATER RECIRC	Y	Y	COPPER	3/4"	70	-	-	PL-143-106
143	BASEMENT	143-INS-B-11	CORRIDOR (CB-21) TUMOR REG (BB-147)	HOT WATER	Y	Y	COPPER	1/2"	160	-	-	PL-143-107
143	BASEMENT	143-INS-B-12	CORRIDOR (CB-21) TUMOR REG (BB-147)	COLD WATER	Y	Y	COPPER	1/2"	160	-	-	PL-143-107
143	BASEMENT	143-INS-B-13	CORRIDOR (CB-20)	COLD WATER	Y	Y	COPPER	1/2"	60	2	(1) BALL VALVE	PL-143-107
143	BASEMENT	143-INS-B-14	CORRIDOR (CB-20)	HOT WATER	Y	Y	COPPER	1/2"	70	2	(1) BALL VALVE	PL-143-107
143	BASEMENT	143-INS-B-15	LOUNGE (BB-138) CORRIDOR (CB-21)	COLD WATER	Y	Y	COPPER	3/4"	450	4	(1) BALL VALVE	PL-143-107
143	BASEMENT	143-INS-B-16	LOUNGE (BB-138) CORRIDOR (CB-21)	HOT WATER	Y	Y	COPPER	3/4"	480	4	(1) BALL VALVE	PL-143-107
143	BASEMENT	143-INS-B-17	CORRIDOR (CB-22)	HOT WATER RECIRC	Y	Y	COPPER	3/4"	60	-	-	PL-143-107

Order Plans @

Revisions	Date

Atriax
 Atriax, plc
 102 3rd Avenue, NE
 PO Box 1628,
 Hickory, NC 28603
 Phone: 828.315.9962
 Fax: 828.315.9964
 www.atriaxgroup.com

WileyWilson
 WileyWilson
 127 Natterville Drive
 Lynchburg, VA 24502
 Phone: 434.947.1901
 www.wileywilson.com



Approved: Energy Engineer

CONSTRUCTION DOCUMENTS

Approved: Safety Manager

Approved: Infection Control Officer

Approved: GEMS Coordinator

Approved: Service Chief

Approved: Chief of Staff

Approved: Associate Director

Drawing Title
PL-607 SCHEDULES

Approved: Chief of Facility Management Svc.

Approved: Medical Center Director

Project Title
RENOVATE FOR WATER QUALITY

Date
 04/28/2017

Project No.
 658-15-101

Building Number
 Checked MJG
 Drawn WJC

Location
 VA MEDICAL CENTER, SALEM, VA 24153

DRAWING SET
2592

Dwg. 129 Of 155

Veterans Affairs