



DOMESTIC WATER PIPE REINSULATION SCHEDULE

BUILDING NUMBER	FLOOR NUMBER	INSULATION NUMBER	ROOM	USE (HOT WATER, HOT WATER RECIRC OR COLD WATER)	IS INSULATION ACCESSIBLE WITHOUT ARCH DEMOLITION OF SURFACE (Y/N)?	ABOVE LAY-IN CEILING (Y/N)?	PIPING MATERIAL	PIPE SIZE (INCH)	PIPE LENGTH (INCHES)	NUMBER OF 90 DEG ELBOWS	ADDITIONAL FITTINGS/VALVES	REFERENCE DRAWING
143	1	143-INS-1-01	CORRIDOR (C1-36)	HOT WATER RECIRC	Y	Y	COPPER	1/2"	140	2	(2) BALANCING VALVES	PL-143-108
143	1	143-INS-1-02	EXAM (IEF-147A) OFFICE (IEF-148) CORRIDOR (C1-36)	COLD WATER	Y	Y	COPPER	3/8"	410	5	(1) BALL VALVE	PL-143-108
143	1	143-INS-1-03	EXAM (IEF-147A) OFFICE (IEF-148) CORRIDOR (C1-36)	HOT WATER	Y	Y	COPPER	3/8"	400	1	(1) BALL VALVE	PL-143-108
143	1	143-INS-1-04	HSK (IEF-102) ELEC (IEF-103)	HOT WATER RECIRC	Y	Y	COPPER	3/4"	160	2	-	PL-143-108
143	1	143-INS-1-05	LAB (IFG-140A)	HOT WATER	Y	Y	COPPER	1/2"	200	4	(1) BALL VALVE	PL-143-109
143	1	143-INS-1-06	HIST/CYT LAB (IFG-140)	COLD WATER	Y	Y	COPPER	1/2"	60	2	-	PL-143-109
143	1	143-INS-1-07	HIST/CYT LAB (IFG-140)	COLD WATER	Y	Y	COPPER	1/2"	70	1	-	PL-143-109
143	1	143-INS-1-08	HIST/CYT LAB (IFG-140)	HOT WATER	Y	Y	COPPER	1/2"	90	-	-	PL-143-109
143	1	143-INS-1-09	HIST/CYT LAB (IFG-140)	COLD WATER	Y	Y	COPPER	1/2"	90	1	-	PL-143-109
143	1	143-INS-1-10	HIST/CYT LAB (IFG-140)	COLD WATER	Y	Y	COPPER	1/2"	150	2	-	PL-143-109
143	1	143-INS-1-11	EXAM (IFG-123) EXAM (IFG-115)	COLD WATER	Y	Y	COPPER	1/2"	220	4	(1) BALL VALVE	PL-143-109
143	1	143-INS-1-12	EXAM (IFG-123) EXAM (IFG-115)	HOT WATER	Y	Y	COPPER	1/2"	220	4	(1) BALL VALVE	PL-143-109
143	1	143-INS-1-13	OFFICE (IFG-113) CORRIDOR (C1-63)	HOT WATER	Y	Y	COPPER	1/2"	350	4	(1) BALL VALVE	PL-143-109
143	1	143-INS-1-14	OFFICE (IFG-113) CORRIDOR (C1-63)	COLD WATER	Y	Y	COPPER	1/2"	110	2	(1) BALL VALVE	PL-143-109
143	1	143-INS-1-15	WAITING (C1-60) CHECK IN (IFG-100A)	COLD WATER	Y	Y	COPPER	3/8"	350	4	(1) BALL VALVE	PL-143-109
143	1	143-INS-1-16	WAITING (C1-60) CHECK IN (IFG-100A)	HOT WATER	Y	Y	COPPER	3/8"	350	4	(1) BALL VALVE	PL-143-109
143	1	143-INS-1-17	MECH RM (IC-132)	HOT WATER	Y	N	COPPER	3/4"	180	1	(1) BALL VALVE	PL-143-110
143	1	143-INS-1-18	MECH RM (IC-29A)	HOT WATER	Y	N	COPPER	1/2"	60	2	-	PL-143-110
143	1	143-INS-1-19	MECH RM (IC-29A)	COLD WATER	Y	N	COPPER	1/2"	50	1	-	PL-143-110
143	1	143-INS-1-20	STAIR	HOT WATER RECIRC	Y	N	COPPER	1"	180	2	-	PL-143-110
143	1	143-INS-1-21	STAIR EXIT	HOT WATER	Y	N	COPPER	3"	200	2	-	PL-143-110
143	1	143-INS-1-22	CORRIDOR (C1-11) REST RM (IC-108B)	HOT WATER	Y	Y	COPPER	3/4"	260	2	(1) BALL VALVE	PL-143-111
143	1	143-INS-1-23	CORRIDOR (C1-3) MECH RM (IB-120)	HOT WATER RECIRC	Y	Y	COPPER	3/4"	220	1	-	PL-143-111
143	1	143-INS-1-24	CORRIDOR (C1-8) OFFICE (IB-117)	COLD WATER	Y	Y	COPPER	1/2"	300	2	-	PL-143-111
143	1	143-INS-1-25	TOILET (IB-104A)	COLD WATER	Y	Y	COPPER	1"	110	2	-	PL-143-111
143	1	143-INS-1-26	TOILET (IB-104A)	HOT WATER	Y	Y	COPPER	1/2"	100	2	(1) BALL VALVE	PL-143-111
143	2	143-INS-2-01	EQUIP STORAGE (2J-177)	COLD WATER	Y	Y	COPPER	3/4"	100	3	-	PL-143-112
143	2	143-INS-2-02	EQUIP STORAGE (2J-177)	HOT WATER	Y	Y	COPPER	3/4"	100	3	-	PL-143-112
143	2	143-INS-2-03	CORRIDOR (C2-16) HAC (2J-173) EQUIP STOR (2J-175)	HOT WATER	Y	Y	COPPER	1/2"	230	2	-	PL-143-112
143	2	143-INS-2-04	CORRIDOR (C2-16) HAC (2J-173) EQUIP STOR (2J-175)	COLD WATER	Y	Y	COPPER	1/2"	230	2	-	PL-143-112
143	2	143-INS-2-05	NOUR STA (2J-141)	COLD WATER	Y	Y	COPPER	1/2"	120	2	-	PL-143-113
143	2	143-INS-2-06	CORRIDOR (C2-10) NOUR STA (2J-141)	HOT WATER	Y	Y	COPPER	3/4"	310	3	(1) BALL VALVE	PL-143-113
143	2	143-INS-2-07	CORRIDOR (C2-10) NOUR STA (2J-141)	COLD WATER	Y	Y	COPPER	3/4"	310	3	(1) BALL VALVE	PL-143-113
143	2	143-INS-2-08	CORRIDOR (C2-7)	COLD WATER	Y	Y	COPPER	2 1/2"	90	-	-	PL-143-113
143	2	143-INS-2-09	BATH (2J-116A)	COLD WATER	Y	Y	COPPER	3/4"	50	-	-	PL-143-113

Order Plans @

Revisions	Date

Atrix, plc
102 3rd Avenue, NE
PO Box 1628,
Hickory, NC 28603
Phone: 828.315.9962
Fax: 828.315.9964
www.atraxisgroup.com

WileyWilson
127 Natterville Drive
Lynchburg, VA 24502
Phone: 434.947.1901
www.wileywilson.com



Approved: Energy Engineer

CONSTRUCTION DOCUMENTS

Approved: Safety Manager

Approved: Infection Control Officer

Approved: GEMS Coordinator

Approved: Service Chief

Approved: Chief of Staff

Approved: Associate Director

Drawing Title
PL-608 SCHEDULES

Approved: Chief of Facility Management Svc.

Approved: Medical Center Director

Project Title
RENOVATE FOR WATER QUALITY

Building Number

Checked MJC

Drawn WJC

Location
VA MEDICAL CENTER, SALEM, VA 24153

Date
04/28/2017

Project No.
658-15-101

DRAWING SET
2592

Dwg. 130 Of 155

Veterans Affairs