

three inches = one foot
 one and one-half inches = one foot
 one inch = one foot
 three-quarters inch = one foot
 one-half inch = one foot
 three-eighths inch = one foot
 one-quarter inch = one foot
 one-eighth inch = one foot

| ELECTRIC UNIT HEATER SCHEDULE | | | | | | | | | | |
|--------------------------------|--------------|---------------------------|----------------------------|--------------|-----------|-------------|------------|-------|--------------------|--|
| MARK | LOCATION | SYSTEM AND/OR BLDG SERVED | TYPE | AIR FLOW CFM | E.A.T. °F | CAPACITY KW | ELECTRICAL | | MOUNTING HEIGHT FT | REMARKS |
| | | | | | | | VOLT | PHASE | | |
| 174-EUH-1 THRU 174-EUH-5 | BUILDING 174 | BUILDING HEATING | HORIZONTAL COIL RESISTANCE | 575 | 50 | 7.5 | 480 | 3 | 9 | PROVIDE HEAT PURGE FAN DELAY, 24V TRANSFORMER, EPOXY COATING, UNIT MOUNTED THERMOSTAT, DISCONNECT SWITCH & WALL MOUNTING BRACKET |
| 172-EUH-1 | BUILDING 172 | BUILDING HEATING | HORIZONTAL COIL RESISTANCE | 575 | 50 | 7.5 | 208 | 3 | 7.5 | PROVIDE HEAT PURGE FAN DELAY, 24V TRANSFORMER, EPOXY COATING, UNIT MOUNTED THERMOSTAT, DISCONNECT SWITCH & WALL MOUNTING BRACKET |
| 173-EUH-1 | BUILDING 173 | BUILDING HEATING | HORIZONTAL COIL RESISTANCE | 575 | 50 | 7.5 | 208 | 3 | 7.5 | PROVIDE HEAT PURGE FAN DELAY, 24V TRANSFORMER, EPOXY COATING, UNIT MOUNTED THERMOSTAT, DISCONNECT SWITCH & WALL MOUNTING BRACKET |

| FAN SCHEDULE | | | | | | | | | | | | | | | | | | |
|--------------|--------------|---------------------------|--------------|---------------------------|--------------------|-------------------|-------|-------------------------------------|--------------|--------|-------------|---------------|-----|-------|------|------|----------|--|
| MARK | LOCATION | SYSTEM AND/OR BLDG SERVED | AIR FLOW CFM | TOTAL STATIC PRESSURE IN. | FAN | | | | | | | ELECTRICAL | | | | | REMARKS | |
| | | | | | TYPE | WHEEL | CLASS | ARRANGEMENT, ROTATION AND DISCHARGE | DIAMETER IN. | DRIVE | FAN MAX RPM | NOMINAL POWER | | PHASE | VOLT | RPM | | SPEED CONTROL |
| | | | | | | | | | | | | BHP | HP | | | | | |
| 174-EF-1 | BUILDING 174 | GENERAL EXHAUST | 400 | 0.5 | INLINE-CENTRIFUGAL | BACKWARD INCLINED | 1 | HORIZONTAL | 10 | DIRECT | 1600 | 0.1 | 1/4 | 1 | 120 | 1725 | CONSTANT | ELECTRICALLY COMMUTATED MOTOR WITH MOTOR MOUNTED SPEED CONTROL |
| 172-EF-1 | BUILDING 172 | GENERAL EXHAUST | 350 | 0.3 | WALL PROPELLER | N/A | 1 | HORIZONTAL | 12 | DIRECT | 1300 | 0.1 | 1/4 | 1 | 120 | 1725 | CONSTANT | ELECTRICALLY COMMUTATED MOTOR WITH MOTOR MOUNTED SPEED CONTROL |
| 173-EF-1 | BUILDING 173 | GENERAL EXHAUST | 350 | 0.3 | WALL PROPELLER | N/A | 1 | HORIZONTAL | 12 | DIRECT | 1300 | 0.1 | 1/4 | 1 | 120 | 1725 | CONSTANT | ELECTRICALLY COMMUTATED MOTOR WITH MOTOR MOUNTED SPEED CONTROL |

NOTE:
ALL SELECTIONS ARE BASED ON AN ALTITUDE OF 1000 FT

one-eighth inch = one foot
 one-quarter inch = one foot
 three-eighths inch = one foot
 one-half inch = one foot
 three-quarters inch = one foot
 one inch = one foot

| Revisions | Date |
|-----------|------|
| | |
| | |
| | |
| | |
| | |

Atrix
 atrix, pllc
 102 3rd Avenue, NE
 PO Box 1628,
 Hickory, NC 28603
 Phone: 828.315.9962
 Fax: 828.315.9964
 www.atrigroup.com

Wiley/Wilson
 Wiley/Wilson
 127 Nationwide Drive
 Lynchburg, VA 24502
 Phone: 434.947.1901
 www.wileywilson.com



Approved: Energy Engineer
 Approved: Safety Manager
 Approved: Service Chief

CONSTRUCTION DOCUMENTS

Approved: Infection Control Officer
 Approved: Chief of Staff
 Approved: GEMS Coordinator
 Approved: Associate Director

| | | |
|--|------------------------------------|-----------------|
| Drawing Title | Project Title | Date |
| M-601 SCHEDULES | RENOVATE FOR WATER QUALITY | 04/28/2017 |
| Approved: Chief of Facility Management Svcs. | Building Number | Project No. |
| Approved: Medical Center Director | Checked MJG | 658-15-101 |
| | Drawn CDI | DRAWING SET |
| | | 2592 |
| | Location | Dwg. 135 Of 155 |
| | VA MEDICAL CENTER, SALEM, VA 24153 | |

Veterans Affairs