


**ELECTRICAL LIGHTING PLAN**  
SCALE: 1/4" = 1'-0"

**LIGHTING NOTES THIS SHEET:**

1. COORDINATE EXACT LOCATION OF SWITCHBANK WITH OWNER PRIOR TO INSTALL.
2. CIRCUIT EXHAUST FAN WITH LIGHTING IN SAME AREA. SEE MECHANICAL FOR CONTROL.
3. ALL EXIT/EMERGENCY LIGHTING TO BE CIRCUITED AHEAD OF LOCAL SWITCHING.
4. PROVIDE 2-CHANNEL, 365-DAY, 7-DAY PER WEEK ASTRONOMIC TIME CLOCK BY TORK (OR EQUAL) FOR CONTROL OF EXTERIOR LIGHTS. PROVIDE MANUAL OVERRIDE SWITCH. COORDINATE EXACT LOCATION WITH OWNER PRIOR TO INSTALL.
5. CONNECT TO WALK-IN COOLER AND FREEZER LIGHTING PROVIDED WITH EQUIPMENT.
6. CIRCUIT FIXTURES SHOWN AHEAD OF LOCAL SWITCHING FOR CONTINUOUS OPERATION (NIGHT LIGHT). FOR MULTI BALLASTED FIXTURES, ONLY CIRCUIT ONE BALLAST (HALF OF FIXTURE) AS NIGHT LIGHT.
7. SPEAKERS AND SOUND SYSTEM TO BE PROVIDED AND INSTALLED BY ELECTRICAL CONTRACTOR. LOCATE VOLUME CONTROL IN OFFICE. COORDINATE EXACT LOCATIONS WITH OWNER PRIOR TO INSTALL.




LUMINAIRE SCHEDULE					
TYPE	DESCRIPTION	VOLT	MOUNTING	MANUFACTURER, CAT. NUMBER	REMARKS
BL	BATHROOM WALL SCONCE	120V	SURFACE MOUNTED	MINIKA: ML-505-B4-PL	
C	TRACK HEAD - OPEN STYLE	120V	SURFACE MOUNTED	HALO: L703MR	
CX	COMBO LED EXT/INT HEAD EBU	120V	SURFACE MOUNTED	EXTRONIX: VEX-U-SP-WH-ELPO-R	
LED-1	LED DOWNLIGHT W/ RC-6 HOUSING	120V	RECESSED CEILING	OREE: VLB-1027120-SP1/MSA-SP1	
LED-2	EXTERIOR 3" FIXTURE	120V	SURFACE MOUNTED	CONTRAST LIGHTING: CA2550/REFR2550/CA2550-01	
LED-4	LED 2X2 RECESSED FIXTURE	120V	RECESSED CEILING	OREE: VL22-3235-SP-1	
LED-6	LED 2X4 RECESSED FIXTURE	120V	RECESSED CEILING	METALUX: 22R-LD1-48-UNV-LB35-CD1-U	
LED-6A	LED 2X2	120V	RECESSED CEILING	METALUX: 22R-LD4-48-F1-UNV-LB35-CD1-U	
LED-7	LED EXTERIOR STRIP LIGHT	120V	SURFACE MOUNTED	SLOAN: 701912 (48" LONG)	
RH	2 HEAD EMERGENCY LIGHT (EXTERIOR)	120V	SURFACE MOUNTED	EX: ZIP-2	
WEBU	2 HEAD EMERGENCY LIGHT	120V	SURFACE MOUNTED	EXTRONIX: UJSH	
WSC-1	EXTERIOR BLACK UP/DOWN SCONCE	120V	SURFACE MOUNTED	SLP: S340-10/9008-12	
WSC-2	SIGNATURE FIXTURE W/18" ARM	120V	SURFACE MOUNTED	COOPER: H-HDMR16/16-1-116/20W/LV-BCM-M	


NOTES: COORDINATE WITH OWNER ON EXACT LIGHTING FIXTURE PRIOR TO INSTALL

No.	Date	Description

This Drawing and all associated designs are the property of COPELAND ARCHITECTURE and shall be returned upon completion of work. Use or copy is permitted by contract only. Unauthorized use will be prosecuted.



**A NEW DARK ROAST STORE**  
DUNKIN' DONUTS  
for  
SHULER DEVELOPMENT  
STORE #357147  
4880-4890 PORT ROYAL ROAD  
SPRING HILL, TN 37174



**EDWARD L. COPELAND, AIA**  
4511 CHAMBLEE DUNWOODY ROAD, SUITE E-1  
ATLANTA, GEORGIA 30338  
PH. 770.551.9525 FAX 770.551.9524  
WWW.COPELANDARCHITECTURE.COM

DRAWN BY:  
KJB  
CHECKED BY:  
WFB  
DATE:  
06/22/17  
SCALE:

C.A. COMMISSION NUMBER  
1704

SHEET NAME  
LIGHTING PLAN

SHEET NUMBER

**E2.0**

**WILLIAM F. BELL**  
Engineer  
TN REG. # 105518  
1702 Sheep Cliff Road  
Hiawassee, GA 30546  
(404) 897-7602