



FOUNDATION NOTES

- N-1 FOR GENERAL STRUCTURAL NOTES SEE DRAWINGS S1.0.
- N-2 FOR PLAN DIMENSIONS NOT SHOWN, REFER TO ARCH. DRAWINGS. VERIFY ALL DIMENSIONS WITH ARCH. DRAWINGS.
- N-3 SEE PLAN FOR FINISH FLOOR ELEVATIONS, VERIFY ELEVATIONS WITH CIVIL DRAWINGS.
- N-4 VERIFY TOP OF FOOTINGS WITH PLANS AND SECTIONS.
- N-5 8" CONCRETE SLAB-ON-GRADE WITH #4 @ 12" O.C. F. & B. ON WELL COMPACTED SOIL. SEE ARCHITECTURAL DRAWINGS FOR VAPOR BARRIER AND SOIL TREATMENT REQUIREMENTS.
- N-6 4" CONCRETE SLAB-ON-GRADE WITH W. & B. @ 12" O.C. F. & B. ON WELL COMPACTED SOIL. SEE ARCHITECTURAL DRAWINGS FOR VAPOR BARRIER, SOIL TREATMENT REQUIREMENTS, SLAB STEPS AND SLOPES.
- N-7 SLAB-ON-GRADE CONTROL JOINT. SEE DETAIL 4/S3.1
- N-8 2-#4 X 5'-0 LG. AT MIN. DEPTH OF SLAB, TYPICAL AT RE-ENTRANT CORNERS TYP.
- N-9 1-#5 @ 12" X 3'-0" TOP BAR TYPICAL WHERE SHOWN.
- N-10 A TOP OF INTERIOR WALL BEARING CMU WALLS, PROVIDE 8" KNIFE-OUT BLOCK BOND BEAM WITH 1-#5 CONTINUOUS AND CORNER BARS.
- N-11 CMU WALLS BELOW GRADE SHALL BE FULLY GROUTED

FOUNDATION LEGEND

- CX INDICATES CAST-IN-PLACE CONCRETE COLUMN (SHEARWALL) SEE DETAIL 7/S3.1 FOR SIZE AND REINFORCEMENT.
- INDICATES #5 BAR IN A FULLY GROUTED CELL WITH STANDARD HOOK IN FOOTING AND BOND BEAM (4'-0" MAXIMUM SPACING)
- INDICATES WINDOW OPENING ABOVE, REFERENCE ARCH. DRAWINGS FOR SIZE AND LOCATION.

FOOTING SCHEDULE					
MARK	LENGTH	WIDTH	DEPTH	REINFORCEMENT	COMMENTS
WF1.67	CONT.	1'-8"	1'-0"	2-#5 BARS EQ. SPACED BOTTOM LONG. AND #5 BARS AT 14" O.C. TRANS.	--
WF2.0	CONT.	2'-0"	1'-0"	3-#5 BARS EQ. SPACED BOTTOM LONG. AND #5 BARS AT 14" O.C. TRANS.	--
WF2.5	CONT.	2'-6"	1'-0"	4-#5 BARS EQ. SPACED BOTTOM LONG. AND #5 BARS AT 14" O.C. TRANS.	--
F-1	4'-0"	4'-0"	1'-0"	4-#5 BARS EQ. SPACED EACH WAY TOP AND BOTTOM	--
F-2	5'-0"	4'-0"	1'-0"	5-#5 BARS SHORT WAY TOP AND BOTTOM 4-#5 BARS LONG WAY TOP AND BOTTOM	--
-	-	-	-	-	--

1 FOUNDATION PLAN
 S2.1 SCALE: 1/8" = 1'-0"



CITY OF TAMPA
 CONTACT ADMINISTRATION
 DEPARTMENT
 PLANNING AND DESIGN DIVISION
 105 E. JACKSON STREET 4 NORTH
 TAMPA, FLORIDA 33602
 P: 813.274.8466 - F: 813.274.8080
 W: www.tampagov.us

James E. Jackson, Jr. AIA, NOMA
 City Architect
 Edward D. Rios, AIA
 Project Architect
 Kevin L. Heredia, AIA
 Project Architect
 Thomas A. Hester, Sr., AIA, NOMA
 Project Architect
 Kasey C. Tillman
 Drafting Technician
 Jerry P. Sanders
 Drafting Technician
 Byron K. Thomas, LEED AP
 Drafting Technician

MEP CONSULTANT
 GRINER ENGINEERING, INC.
 1628 1st AVENUE NORTH
 ST. PETERSBURG, FL 33713

STRUCTURAL CONSULTANT
 BILLER REINHART
 ENGINEERING GROUP, INC.
 3434 COLLIWELL AVENUE, SUITE 100
 TAMPA, FL 33614

CIVIL CONSULTANT
 5 M CIVIL LLC
 12315 UYCLIFF PLACE
 TAMPA, FL 33626

LANDSCAPE CONSULTANT
 DAVID CONNER & ASSOCIATES
 1509 W. SWANN AVENUE, SUITE 255
 TAMPA, FL 33606

FIRE STATION 23
 2070 TROUT CREEK DR
 TAMPA, FLORIDA

DPW FILE NUMBER

DPW NUMBER
 FD0118

ISSUE DATE
 7-28-17

DRAWN BY
 RC, RM

REVISIONS

△	
△	
△	

SEAL
 TO THE BEST OF THE ENGINEER'S KNOWLEDGE, THE PLANS AND SPECIFICATIONS COMPLY WITH THE APPLICABLE MINIMUM BUILDING CODES

ROBERT J. REINHART
 FL. P.E. NO. 50076

SCALE: VARIES

FOUNDATION PLAN

SHEET NUMBER

S2.0
 X OF X

billerreinhardt
 ENGINEERING GROUP, INC.
 3434 COLLIWELL AVENUE SUITE 100, TAMPA, FLORIDA 33614
 telephone : 813.908.7203 fax : 813.931.5200
 email : info@billerreinhardt.com
 State of Florida Certificate of Authorization No. 9149

Order Plans