

Order Plans

FIRE STATION 23, TAMPA LIGHTING CONTROL SCHEDULES						
MASTER LIGHTING CONTROL PANEL (MLCP) BY LCD, LOCATED IN ELECTRICAL ROOM						
RELAY CONTROL		LOAD				
NO	N / EM	BRANCH CIRCUIT	VOLT AC	CIRCUIT DESIGNATION	FIXTURE TYPE	CONTROL DESCRIPTION
NOTE						
1	EM	EM-1	120	APPARATUS BAY	LED	RELAY DESIGNATION "e1" - 100% LIGHTS
2	EM	EM-3	120	APPARATUS BAY	LED	RELAY DESIGNATION "e2" - 100% LIGHTS
3	EM	EM-5	120	ACTIVITY AREA	LED	RELAY DESIGNATION "e3" - 50% LIGHTS
4	EM			ACTIVITY AREA	LED	RELAY DESIGNATION "e4" - 100% LIGHTS
5	EM	EM-5	120	KITCHEN	LED	RELAY DESIGNATION "e5" - 50% LIGHTS
6	EM			KITCHEN	LED	RELAY DESIGNATION "e6" - 100% LIGHTS
7	EM	EM-9	120	CORRIDOR QUARTERS	LED	RELAY DESIGNATION "e7" - 100% LIGHTS
8	EM			CORRIDOR QUARTERS	LED	RELAY DESIGNATION "e8" - 50% LIGHTS
9	EM	EM-4	120	APPARATUS BAY EXTERIOR S. WALL LIGHTING FIXTURES	LED	RELAY DESIGNATION "e9" - 100% LIGHTS. PROVIDE WITH OVER-RIDE LOW VOLTAGE SWITCH AT CONTROL PANEL IN OFFICE
10	EM			APPARATUS BAY EXTERIOR N. WALL LIGHTING FIXTURES	LED	RELAY DESIGNATION "e10" - 100% LIGHTS. PROVIDE WITH OVER-RIDE LOW VOLTAGE SWITCH AT CONTROL PANEL IN OFFICE
11	EM			EXTERIOR BUILDING WALL PACKS	LED	RELAY DESIGNATION "e11" - 100% LIGHTS. PROVIDE WITH OVER-RIDE LOW VOLTAGE SWITCH AT CONTROL PANEL IN OFFICE
12	EM	EM-2	120	EXTERIOR BUILDING DOWNLIGHTS COVERED PATIO	LED	RELAY DESIGNATION "e12" - 100% LIGHTS PROVIDE WITH OVER-RIDE LOW VOLTAGE SWITCH IN COVERED PATIO
13	EM	EM-23,25	208	SITE LIGHTING	LED	RELAY DESIGNATION "e13,e14" - 100% PROVIDE WITH OVER-RIDE LOW VOLTAGE SWITCH PER OWNER'S DIRECTION
14						
15	EM	EM-27,29	208	SITE LIGHTING	LED	RELAY DESIGNATION "e15,e16" - 100% PROVIDE WITH OVER-RIDE LOW VOLTAGE SWITCH PER OWNER'S DIRECTION
16						
17	EM			SPARE		
18	EM			SPARE		
19	N	SA-1	120	APPARATUS BAY	LED	RELAY DESIGNATION "a1" - 50% LIGHTS
20	N	SA-3	120	APPARATUS BAY	LED	RELAY DESIGNATION "a2" - 100% LIGHTS
21	N	SB-35	120	SPARE	LED	PHOTOCELL ON/TIMECLOCK OFF RELAY DESIGNATION "a3" - 100% LIGHTS
22	N			SPARE		
23	N			SPARE		
24	N			SPARE		
SLAVE LIGHTING CONTROL PANEL (SLCP1) BY LCD, LOCATED ABOVE CEILING IN QUARTER						
1	N	SA-5	120	CREW QUARTER LIGHTING	LED	RELAY DESIGNATION "a11" - 50% LIGHTS
2	N	SA-5	120	CREW QUARTER LIGHTING	LED	RELAY DESIGNATION "a12" - 100% LIGHTS
3	N	SA-5	120	CREW QUARTER LIGHTING	LED	RELAY DESIGNATION "a13" - 50% LIGHTS
4	N	SA-5	120	CREW QUARTER LIGHTING	LED	RELAY DESIGNATION "a14" - 100% LIGHTS
SLAVE LIGHTING CONTROL PANEL (SLCP2) BY LCD, LOCATED ABOVE CEILING IN QUARTER						
1	N	SA-5	120	CREW QUARTER LIGHTING	LED	RELAY DESIGNATION "a21" - 50% LIGHTS
2	N	SA-5	120	CREW QUARTER LIGHTING	LED	RELAY DESIGNATION "a22" - 100% LIGHTS
3	N	SA-5	120	CREW QUARTER LIGHTING	LED	RELAY DESIGNATION "a23" - 50% LIGHTS
4	N	SA-5	120	CREW QUARTER LIGHTING	LED	RELAY DESIGNATION "a24" - 100% LIGHTS
SLAVE LIGHTING CONTROL PANEL (SLCP3) BY LCD, LOCATED ABOVE CEILING IN QUARTER						
1	N	SA-5	120	CREW QUARTER LIGHTING	LED	RELAY DESIGNATION "a31" - 50% LIGHTS
2	N	SA-5	120	CREW QUARTER LIGHTING	LED	RELAY DESIGNATION "a32" - 100% LIGHTS
3	N	SA-5	120	CREW QUARTER LIGHTING	LED	RELAY DESIGNATION "a33" - 50% LIGHTS
4	N	SA-5	120	CREW QUARTER LIGHTING	LED	RELAY DESIGNATION "a34" - 100% LIGHTS
SLAVE LIGHTING CONTROL PANEL (SLCP4) BY LCD, LOCATED ABOVE CEILING IN QUARTER						
1	N	SA-5	120	CREW QUARTER LIGHTING	LED	RELAY DESIGNATION "a41" - 50% LIGHTS
2	N	SA-5	120	CREW QUARTER LIGHTING	LED	RELAY DESIGNATION "a42" - 100% LIGHTS
3	N	SA-5	120	CREW QUARTER LIGHTING	LED	RELAY DESIGNATION "a43" - 50% LIGHTS
4	N	SA-5	120	CREW QUARTER LIGHTING	LED	RELAY DESIGNATION "a44" - 100% LIGHTS
SLAVE LIGHTING CONTROL PANEL (SLCP5) BY LCD, LOCATED ABOVE CEILING IN QUARTER						
1	N	SA-5	120	CREW QUARTER LIGHTING	LED	RELAY DESIGNATION "a45" - 50% LIGHTS
2	N	SA-5	120	CREW QUARTER LIGHTING	LED	RELAY DESIGNATION "a46" - 100% LIGHTS
3	N	SA-5	120	CREW QUARTER LIGHTING	LED	RELAY DESIGNATION "a47" - 50% LIGHTS
4	N	SA-5	120	CREW QUARTER LIGHTING	LED	RELAY DESIGNATION "a48" - 100% LIGHTS



CITY OF TAMPA
CONTRACT ADMINISTRATION
DEPARTMENT
PLANNING AND DESIGN DIVISION
105 E. JACKSON STREET 4 NORTH
TAMPA, FLORIDA 33602
p: 813. 274. 8456 - f: 813. 274. 8080
url: www.tampagov.net

James E. Jackson, Jr. AIA, NOMA
City Architect
Edward D. Rice, AIA
Project Architect
Kevin L. Henka, AIA
Project Architect
Thomas A. Hester, Sr., AIA, NOMA
Project Architect
David R. Pagitt
Supervisor, Architectural Drafting
Kinsey C. Tillman
Drafting Technician
Jerry P. Sanders
Drafting Technician
Byron K. Thomas, LEED AP
Drafting Technician

MEP CONSULTANT
GRINER ENGINEERING, INC.
1628 1st AVENUE NORTH
ST. PETERSBURG, FL 33713

STRUCTURAL CONSULTANT
BILLER REINHART
STRUCTURAL GROUP, INC.
4014 GUNN HWY. SUITE 248
TAMPA, FL 33713

CIVIL CONSULTANT
B M CIVIL LLC
12315 WYCLIFF PLACE
TAMPA, FL 33626

LANDSCAPE CONSULTANT
DAVID CONNER & ASSOCIATES
1503 W. SWANN AVENUE SUITE 255
TAMPA, FL 33606

FIRE STATION 23
20770 TROUT CREEK DR.
TAMPA, FL 33647

DPW FILE NUMBER

DPW NUMBER
17-C-00037

ISSUE DATE
07-28-2017

DRAWN BY

REVISIONS

△
△
△
△

SEAL

Jose A Rosario, P.E. FL. 74457

SCALE: N.T.S.

ELECTRICAL LIGHTING
CONTROL SCHEDULE

SHEET NUMBER

E5.3

X OF X



	GRINER ENGINEERING, INC.	
	1628 First Avenue North	
	St. Petersburg, Florida 33713	
	Phone: (727)-822-2335	
	Fax: (727)-821-3361	
Date	06-15-2017	
Drawn	HH	
Designed	HH	
EOR	JAR	
Job no.	17049	