



GENERAL PLUMBING NOTES:

1. PRIOR TO BID, P.C. AND G.C. SHALL VERIFY SANITARY SEWER SYSTEM LOCATION, ROUTING, PITCHES, INVERTS, SIZES AND TIE-IN POINT. ALL SEWER SYSTEM INFORMATION SHALL BE COORDINATED WITH ALDI, INC. REPRESENTATIVE AT TIME OF BID WALK-THROUGH. INFORM PLUMBING ENGINEER OF ANY AND ALL DISCREPANCIES FROM WORK SHOWN ON PLUMBING DRAWINGS PRIOR TO BID DATE.
2. GAS METER BY UTILITY CO. PROVIDE CONCRETE PAD UNDER METER AS REQUIRED BY THE UTILITY CO. 10\"/>

PLUMBING PLAN KEYNOTES:

- (P1) NOT USED.
- (P2) 1/2\"/>
- (P3) PROVIDE GAS METER WITH GAS REGULATOR. CONNECT TO UNDERGROUND GAS SERVICE BY GAS COMPANY. GAS REGULATOR SHALL BE 10\"/>
- (P4) PROVIDE 1/2\"/>
- (P5) PROVIDE GAS PIPING. ROUTE AT UNDERSIDE OF STEEL.
- (P6) NOT USED.
- (P7) PROVIDE MOP BASIN WITH FAUCET ON WALL. PROVIDE 1/2\"/>
- (P8) NOT USED.
- (P9) NOT USED.
- (P10) NOT USED.
- (P11) PROVIDE 3\"/>
- (P12) NOT USED.
- (P13) PROVIDE VENT PIPING ABOVE CEILING.
- (P14) NOT USED.
- (P15) PROVIDE FLOOR DRAIN. LOCATE DRAIN TO BE CLEAR OF PALLET BUMPER.
- (P16) PROVIDE 1/2\"/>
- (P17) PROVIDE 2\"/>
- (P18) PROVIDE VENT THROUGH ROOF.
- (P19) NOT USED.
- (P20) SEE DETAIL A3/P-401 FOR EWH-1 PIPING DETAIL & HW & CW PIPING SCHEMATIC DOWN TO MB-A. PROVIDE TRAP GUARD INSERT FOR FLOOR DRAIN.
- (P21) PROVIDE 1/2\"/>
- (P22) PROVIDE ROOF HYDRANT AT A MINIMUM OF DISTANCE OF 4'-0\"/>
- (P23) NOT USED.
- (P24) REFER TO ENLARGED PLANS DRAWING P-201 FOR PIPING WITHIN AREA AND DRAWING P-301 FOR ISOMETRIC DIAGRAMS.
- (P25) REFER TO SITE UTILITY DRAWINGS FOR CONTINUATION OF PIPING. P.C. SHALL MAKE FINAL CONNECTIONS TO SITE PIPING. COORDINATE WITH S.C. FOR CONNECTIONS.
- (P26) PROVIDE GAS PIPING UP THRU ROOF TO RTU. PROVIDE WITH DIRT LEG AND ISOLATION SHUTOFF VALVE. MAKE FINAL CONNECTION TO UNIT. REFER TO ISOMETRIC B2/P-301 AND DETAIL B2/P-401.
- (P27) PROVIDE GAS PIPING TO UNIT HEATER. PROVIDE WITH DIRT LEG AND ISOLATION SHUTOFF VALVE. MAKE FINAL CONNECTION TO UNIT. REFER TO ISOMETRIC B2/P-301 AND DETAIL B3/P-401.
- (P28) GC IS RESPONSIBLE FOR IRRIGATION PLAN AND INSTALLATION.
- (P29) HUB DRAIN FOR FUTURE USE. REFER TO P-102 FOR CONNECTION TO STORM DRAIN SYSTEM.
- (P30) PROVIDE 3/4\"/>
- (P31) PROVIDE RIGID WATER PIPE SUPPORT ON EACH SIDE OF PIPING CHANGING DIRECTION UPSTREAM OF VACUUM SYSTEM CONNECTIONS. INSTALL SHOCKSTOP AS CLOSE AS POSSIBLE TO QUICK-CLOSING VALVES. PROVIDE UNISTRUT SUPPORT WITH HOLDRIE 257-P SIZES UNDER 1\"/>
- (P32) PROVIDE REDUCED PRESSURE ZONE ASSEMBLY AND 3/4\"/>

Issued:	Date:
A Client Review Set	04/07/17
B Permit Set	04/07/17
C Bid Set	09/05/17
D	
Revisions:	Date:
1	
2	
3	
4	
5	
6	
7	
8	
9	

DO NOT SCALE PLANS
 Copying, Printing, Software and other processes required to produce these prints can stretch or shrink the actual paper or layout. Therefore, scaling of this drawing may be inaccurate. Contact us consultants with any need for additional dimensions or clarifications.

ms consultants, inc.
 engineers, architects, planners
 2221 Schrock Road
 Columbus, Ohio 43229-1547
 phone 614.898.7100
 fax 614.898.7570

DRAWN BY: ZRD
 REVIEWED BY: KFF/DED

Seal
 PROFESSIONAL OF RECORD:
 DANIEL E. DOWLER No.0402054658
 EXP. DATE: 02/28/2019

ALDI Inc.
 1985 Old Union Church Road
 Salisbury, NC 28146
 (704) 642-0279
 (704) 642-0278 fax

ALDI Inc. Store #: 161
 VA Beach Blvd & Thalia
 4220 Virginia Beach Blvd
 Virginia Beach, VA 23452
 Willis Wayside
 Project Name & Location:

Plumbing Floor Plan Drawing Name:	
Prototype Rls. 02/08/17	Project No. 40320-40
Type: RHSD-V7	P-101
Scale: As Noted	Drawing No.

Order Plans @

1 Plumbing Floor Plan
 SCALE: 1/8" = 1'-0"

