

- submittals.
- E. Additional Copies: Unless additional copies are required for final submittal, and unless Architect observes noncompliance with provisions of the Contract Documents, initial submittal may serve as final submittal.
  - F. Transmittal: Package each submittal individually and appropriately for transmittal and handling. Transmit each submittal using a transmittal form. Architect will return submittals, without review received from sources other than Contractor or for items that do not require submittals in the Contract Documents.
    1. Include Contractor's certification stating that the information submitted has been reviewed and complies with requirements of the Contract Documents.
    2. Transmittal Form: Use AIA Document G816.
  - G. Use for Construction: Use only final submittals with mark indicating action taken by Architect in connection with construction.

**PART 2 - PRODUCTS**

- 2.1 ACTION SUBMITTALS**
- A. General: Prepare and submit Action Submittals required by individual Specification Sections.
    1. Number of Copies: Submit 3 copies of each submittal, unless otherwise indicated. Architect will return 2 copies. Mark up and retain one returned copy as a Project Record Document.
    2. Complete Submittals: Submit complete submittals in accordance with submittal schedule. The architect reserves the right to withhold action on a submittal until remaining information required in that section or division is provided.
  - B. Product Data: Collect information into a single submittal for each element of construction and type of product or equipment.
    1. If information must be specially prepared for submittal because standard printed data are not suitable for use, submit as Shop Drawings, not as Product Data.
    2. Mark each copy of each submittal to show which products and options are applicable.
  - C. Shop Drawings: Prepare Project-specific information, drawn accurately to scale. Do not base Shop Drawings on reproductions of the Contract Documents or standard printed data.
  - D. Samples: Prepare physical units of materials or products, including the following:
    1. Comply with requirements in Division 1 Section "Quality Requirements" for mockups.
    2. Samples for Initial Selection: Submit manufacturer's color charts consisting of units or sections of units showing the full range of colors, textures, and patterns available.
    3. Preparation: Mount, display, or package Samples in manner specified to facilitate review of qualities indicated. Prepare Samples to match Architect's sample where so indicated. Attach label on unexposed side.
    4. Submit Samples for review of kind, color, pattern, and texture for a final check of their characteristics with other elements and for a comparison of these characteristics between final submittal and actual components as delivered and installed.
    5. Disposition: Maintain sets of approved Samples at Project site, available for quality-control comparisons throughout the course of construction activity. Sample sets may be used to determine final acceptance of construction associated with each set.
  - E. Product Schedule or List: Prepare a written summary indicating types of products required for the Work and their intended location.
  - F. Subcontract List: Prepare a written summary identifying individuals or firms proposed for each portion of the Work, including those who are to furnish products or equipment fabricated to a special design. Use CSI Form 1.5A or similar format suitable to the Owner.

**PART 3 - EXECUTION**

- 3.1 CONTRACTOR'S REVIEW**
- A. Review each submittal and check for compliance with the Contract Documents. Note corrections and field dimensions. Mark with approval stamp before submitting to Architect.
  - B. Approval Stamp: Stamp each submittal with a uniform approval stamp. Include Project name and location, submittal number, Specification Section title and number, name of reviewer, date of Contractor's approval, and statement certifying that submittal has been reviewed, checked, and approved for compliance with the Contract Documents.
- 3.2 ARCHITECT'S ACTION**
- A. General: Architect will not review submittals that do not bear Contractor's approval stamp and will return them without action.
  - B. Action Submittals: Architect will review each submittal, make marks to indicate corrections or modifications required, and return it. Architect will stamp each submittal with an action stamp and will mark stamp appropriately to indicate action taken.
  - C. Submittals not required by the Contract Documents will not be reviewed and may be discarded.

**END OF SECTION 01330**

**SECTION 01400 - QUALITY REQUIREMENTS**

**PART 1 - GENERAL**

- 1.1 SUMMARY**
- A. This Section includes administrative and procedural requirements for quality assurance and quality control.
  - B. Testing and inspecting services are required to verify compliance with requirements specified or indicated. These services do not relieve Contractor of responsibility for compliance with the Contract Document requirements.
    1. Specified tests, inspections, and related actions do not limit Contractor's quality-control procedures that facilitate compliance with the Contract Document requirements.
    2. Requirements for Contractor to provide quality-control services required by Architect, Owner, authorities having jurisdiction are not limited by provisions of this Section.
  - C. See Divisions 2 through 16 Sections for specific test and inspection requirements.
- 1.2 DEFINITIONS**
- A. Quality-Assurance Services: Activities, actions, and procedures performed before and during execution of the Work to guard against defects and deficiencies and ensure that proposed construction complies with requirements.
  - B. Quality-Control Services: Tests, inspections, procedures, and related actions during and after execution of the Work to evaluate that completed construction complies with requirements. Services do not include contract enforcement or performance by Architect.
  - C. Mockups: Show physical sample assemblies to illustrate finishes and materials. Mockups are used to verify work, make mockup sample submittals, demonstrate aesthetic effects and, where indicated, qualities of materials and workmanship, and to review construction coordination, testing, or operation; they are not Samples used to establish the standard of work that will be judged.
  - D. Testing Agency: An entity engaged to perform specific tests, inspections, or both. Testing laboratory shall remain the same as the Testing Agency.

**DELEGATED DESIGN**

Performance and Design Criteria: Where professional design services or certifications by a design professional are specifically required of Contractor by the Contract Documents, provide products and systems complying with specific performance and design criteria indicated. If criteria indicated are not sufficient to perform services or certification required, submit a written request for additional information to Architect.

**1.4 SUBMITTALS**

- A. Delegated-Design Submittal: In addition to Shop Drawings, Product Data, and other required submittals, submit a statement, signed and sealed by the responsible design professional, for each product and system specifically assigned to Contractor to be designed or certified by a design professional, indicating that the products and systems are in compliance with performance and design criteria indicated. Include list of codes, loads, and other factors used in performing these services.
- B. Reports: Prepare and submit certified written reports that include the following:
  1. Date of issue.
  2. Project title and number.
  3. Name, address, and telephone number of testing agency.
  4. Dates and locations of samples and tests or inspections.
  5. Names of individuals making tests and inspections.
  6. Description of the Work and test and inspection method.
  7. Identification of product and Specification Section.
  8. Complete test or inspection data.
  9. Test and inspection results and an interpretation of test results.
  10. Ambient conditions at time of sample taking and testing and inspecting.
  11. Comments or professional opinion on whether tested or inspected Work complies with the Contract

- Document requirements.
  12. Name and signature of laboratory inspector.
  13. Recommendations on retesting and reinspection.
- C. Permits, Licenses, and Certificates: For Owner's records, submit copies of permits, licenses, certifications, inspection reports, releases, jurisdictional settlements, notices, receipts for fee payments, judgments, correspondence records, and similar documents, established for compliance with standards and regulations bearing on performance of the Work.
- 1.5 QUALITY ASSURANCE
  - A. Fabricator Qualifications: A firm experienced in producing products similar to those indicated for this Project and with a record of successful in-service performance, as well as sufficient production capacity to produce required units.
  - B. Factory-Authorized Service Representative Qualifications: An authorized representative of manufacturer who is trained and approved by manufacturer to inspect installation of manufacturer's products that are similar in material, design, and extent to those indicated for this Project.
  - C. Installer Qualifications: A firm or individual experienced in installing, erecting, or assembling work similar in material, design, and extent to that indicated for this Project, whose work has resulted in construction with a record of successful in-service performance.
  - D. Manufacturer Qualifications: A firm experienced in manufacturing products or systems similar to those indicated for this Project and with a record of successful in-service performance.
  - E. Professional Engineer Qualifications: A professional engineer who is legally qualified to practice in jurisdiction where Project is located and who is experienced in providing engineering services of the kind indicated. Engineering services are defined as those performed for installations of the system, assembly, or product that are similar to those indicated for this Project in material, design, and extent.
  - F. Specialists: Certain sections of the Specifications require that specific construction activities shall be performed by entities who are recognized experts in those operations. Specialists shall satisfy qualification requirements indicated and shall be engaged for the activities indicated.
    1. Requirements for specialists shall not supersede building codes and similar regulations governing the Work, nor interfere with local trade-union jurisdictional settlements and similar conventions.
  - G. Testing Agency Qualifications: An agency with the experience and capability to conduct testing and inspecting indicated, as documented by ASTM E 348, and that specializes in type of tests and inspections to be performed.
- 1.6 QUALITY CONTROL
  - A. Owner Responsibilities: Where quality-control services are indicated as Owner's responsibility, Owner will engage a qualified testing agency to perform these services.
    1. Owner will furnish Contractor with names, addresses, and telephone numbers of testing agencies engaged and a description of the types of testing and inspecting they are engaged to perform.
    2. Costs for retesting and reinspectng construction that replaces or is necessitated by work that failed to comply with the Contract Documents will be charged to Contractor.
  - B. Contractor Responsibilities: Unless otherwise indicated, provide quality-control services specified and authorized by authorities having jurisdiction.
    1. Where services are indicated as Contractor's responsibility, engage a qualified testing agency to perform these quality-control services.
      - a. Contractor shall not employ the same entity engaged by Owner, unless agreed to in writing by Owner.
    2. Notify testing agencies at least 24 hours in advance of time when Work that requires testing or inspecting will be performed.
    3. Where quality-control services are indicated as Contractor's responsibility, submit a certified written report, in duplicate, of each quality-control service.
    4. Testing and inspecting requested by Contractor and not required by the Contract Documents are Contractor's responsibility.
    5. Submit additional copies of each written report directly to authorities having jurisdiction, when they so direct.
  - C. Manufacturer's Field Services: Where indicated, engage a factory-authorized service representative to inspect field-assembled components and equipment installation, including service connections. Report results in writing.
  - D. Retesting/Reinspecting: Regardless of whether original tests or inspections were performed by Contractor's responsibility, provide quality-control services, including retesting and reinspectng, for construction revised or replaced Work that failed to comply with requirements established by the Contract Documents.
  - E. Testing Agency Responsibilities: Cooperate with Architect and Contractor in performance of duties. Provide qualified personnel to perform required tests and inspections.
    1. Notify Architect and Contractor promptly of irregularities or deficiencies observed in the Work during performance of its services.
    2. Interpret tests and inspections and state in each report whether tests and inspected work conformed with or deviates from requirements.
    3. Submit a certified written report, in duplicate, of each inspection and similar quality-control service through Contractor.
    4. Do not release, revoke, alter, or modify requirements, test procedures, documents or approve or accept any portion of the Work.
    5. Do not perform any duties of Contractor.

**END OF SECTION 01400**

**SECTION 01500 - TEMPORARY FACILITIES AND CONTROLS**

**PART 1 - GENERAL**

- 1.1 SUMMARY**
- A. This Section includes temporary facilities and controls, including temporary utilities, support facilities, and safety and protection facilities.
  - B. Temporary facilities include, but are not limited to, the following:
    1. Sewers and drainage.
    2. Water service and distribution.
    3. Testing facilities including toilets, wash facilities, and drinking-water facilities.
    4. Electric power service.
    5. Lighting.
    6. Telephone service.
  - C. Support facilities include, but are not limited to, the following:
    1. Project identification and temporary signs.
    2. Field offices.
    3. Temporary stairs.
  - D. Security and protection facilities include, but are not limited to, the following:
    1. Environmental protection.
    2. Stormwater control.
    3. Tree and plant protection.
    4. Barricades, warning signs, and lights.
    5. Fire protection.

**1.2 USE CHARGES**

- A. General: Cost or use charges for temporary facilities are not chargeable to Owner or Architect and shall be included in the Contract Sum. Allow other entities to use temporary services and facilities without cost, including, but not limited to, the following:
  1. Owner's construction forces.
  2. Occupants of Project.
  3. Architect.
  4. Testing agencies.
  5. Personnel of authorities having jurisdiction.
- B. Sewer Service: Pay sewer service use charges for sewer usage, by all parties engaged in construction, at Project site.
- C. Water Service: Pay water service use charges, whether metered or otherwise, for water used by all entities engaged in construction activities at Project site.
- D. Electric Power Service: Pay electric power service use charges, whether metered or otherwise, for electricity used by all entities engaged in construction activities at Project site.

**1.3 QUALITY ASSURANCE**

- A. Standards: Comply with ANSI A10.6, NECA's "Temporary Electrical Facilities," and NFPA 241.
  1. Trade regulations and standards: Assigned responsibilities for installation and operation of temporary utilities are not intended to interfere with trade regulations and union jurisdictions.
  2. Electric Service: Comply with NECA, NEMA, and UL standards and regulations for temporary electric service. Install service to comply with NFPA 70.
- B. Tests and Inspections: Arrange for authorities having jurisdiction to test and inspect each temporary utility before use. Obtain required certifications and permits.

**PART 2 - PRODUCTS**

**2.1 EQUIPMENT**

- A. General: Provide equipment suitable for use intended.
- B. Fire Extinguishers: Hand carried, portable, UL rated. Provide class and extinguishing agent as indicated or a combination of extinguishers of NFPA-recommended classes for exposures in quantities and locations determined by regulation of any authority having jurisdiction.
  1. Comply with NFPA 10 and NFPA 241 for classification, extinguishing agent, and size required by location and class of fire exposure.
- C. Self-Contained Toilet Units: Single-occupant units of chemical, aerated recirculation, or combustion type; vented, fully enclosed with a glass-fiber-reinforced polyester shell or similar noncombustible material in quantities and locations determined by regulation of any authority having jurisdiction.
- D. Drinking-Water Fixtures: Drinking-water fountains or containerized, tap-dispenser, hot/cold-water drinking-water units, including paper cup supply in quantities and locations determined by regulation of any authority having jurisdiction.
- E. Electrical Outlets: Properly configured, NEMA-polarized outlets to prevent insertion of 110- to 120-V plug into higher-voltage outlets; equipped with ground-fault circuit interrupters, reset button, and pilot light.
- F. Power Distribution System Circuits: Where permitted and overhead and exposed for surveillance, wiring circuits, not exceeding 125-V ac, 30-A rating, and lighting circuits may be nonmetallic sheathed cable.

**PART 3 - EXECUTION**

- 3.1 INSTALLATION, GENERAL**
- A. Locate facilities where they will serve Project adequately and result in minimum interference with performance of the Work. Relocate and modify facilities as required.
  - B. Provide each facility ready for use when needed to avoid delay. Maintain and modify as required. Do not remove until facilities are no longer needed or are replaced by authorized use of completed permanent facilities.
- 3.2 TEMPORARY UTILITY INSTALLATION**
- A. General: Engage appropriate local utility company to install temporary service or connect to existing service. Where utility company provides only part of the service, provide the remainder with existing compatible materials and equipment. Comply with utility company recommendations.
    1. Arrange with utility company, Owner, and existing users for time when work can be done, if necessary, to make connections for temporary services.
    2. Provide adequate capacity at each stage of construction. Before temporary utility is available, provide trucked-in services.
  - B. Sewers and Drainage: If sewers are available, provide temporary connections to receive effluent that can be discharged lawfully. If sewers are not available, provide dry wells, stabilization ponds, and similar facilities. If required, use no drainage facilities capable of safely used for discharge of effluent; provide containers to receive and dispose of effluent off-site in a lawful manner.
  - C. Water Service: Install water service and distribution in sizes and pressures adequate for construction until permanent water service is in use. Sterilize temporary water piping before use.
  - D. Sanitary Facilities: Provide temporary toilets, wash basins, and drinking-water fixtures. Comply with regulations and health codes for type, number, location, sanitation, and maintenance of fixtures and facilities.
  - E. Heating and Cooling: Provide temporary heating and cooling required by construction activities for curing or other completed installations or for protecting installed construction from adverse effects of low temperature or high humidity.
    1. Maintain minimum temperature of 50 deg F in permanently enclosed portions of building for normal construction activities, and 55 deg F for finishing activities and areas where finished Work has been installed.
  - F. Ventilation and Humidity Controls: Provide temporary ventilation required by construction activities for curing or drying completed installations or for protecting installed construction from adverse effects of high humidity.
  - G. Electric Power Service: Provide weatherproof, grounded electric power service and distribution system of sufficient size, capacity, and power characteristics during construction period. Include meters, transformers, overload-protected disconnecting means, automatic ground-fault interrupters, and main distribution switchgear.
  - H. Lighting: Provide temporary lighting with local switching that provides adequate illumination for construction operations and traffic conditions.
  - I. Telephone Service: Provide temporary telephone service throughout construction period for common-use facilities used by all personnel engaged in construction activities.
    1. Provide additional telephone lines for the following:
      - a. Provide a dedicated telephone line for each facsimile machine and computer with modem in each field office.
      2. Provide an answering machine on superintendent's telephone.
      3. Provide a facsimile machine for site use.
      4. Provide a portable cellular telephone for superintendent's use in making and receiving telephone calls when away from field office.

**3.3 SUPPORT FACILITIES INSTALLATION**

- A. General: Comply with the following:
  1. Locate field offices, storage sheds, sanitary facilities, and other temporary construction and support facilities for easy access, making them accessible for handicap access where required by the authority having jurisdiction.
  2. Maintain support facilities until near Substantial Completion. Remove before Substantial Completion. Personnel remaining after Substantial Completion will be permitted to use permanent facilities, under conditions acceptable to Owner.
- B. Project Identification and Temporary Signs: Prepare Project identification and other signs in sizes indicated. Install signs where indicated to inform public and persons seeking entrance to Project.
  1. Prepare temporary signs to provide directional information to construction personnel and visitors.
  2. Construct signs of exterior-type Grade B-B high-density concrete form overlay plywood in sizes and thicknesses indicated. Support on posts or framing of pressure-treated wood or steel.
  3. Paint sign panel and applied graphics with exterior-grade alkyd gloss enamel over exterior primer.
- C. Temporary Stairs: Until permanent stairs are available, provide temporary stairs where ladders are not adequate. Cover finished, permanent stairs with protective covering of plywood or similar material so finishes will be undamaged at time of acceptance.

**3.4 SECURITY AND PROTECTION FACILITIES INSTALLATION**

- A. Environmental Protection: Provide protection, operate temporary facilities, and conduct construction in ways and by methods that comply with environmental regulations and that minimize possible air, waterway, and subsurface contamination or pollution or other undesirable effects. Avoid using tools and equipment that produce harmful noise. Restrict use of noisemaking tools and equipment to hours that will minimize complaints from persons or firms near Project site.
- B. Stormwater Control: Provide earthen embankments and similar barriers in and around excavations and subsgrade construction, sufficient to prevent flooding by runoff of stormwater from heavy rains.
- C. Tree and Plant Protection: Install temporary fencing located as indicated or outside the drip line of trees to protect vegetation from construction damage. Protect tree root systems from damage, flooding, and erosion.
- D. Tree and Plant Protection: Comply with requirements in Division 2 Section "Tree Protection and Trimming."
- E. Barricades, Warning Signs, and Lights: Comply with standards and code requirements for erecting structurally adequate barricades. Paint with appropriate colors, graphics, and warning signs to inform personnel and public of possible hazard. Where appropriate and needed, provide lighting, including flashing red or amber lights.
- F. Temporary Partitions: Erect and maintain dustproof partitions and temporary enclosures to limit dust and dirt migration and to separate areas from fumes and noise.
- G. Temporary Fire Protection: Until fire-protection needs are supplied by permanent facilities, install and maintain temporary fire-protection facilities of types needed to protect against reasonably predictable and controllable fire losses. Comply with NFPA 241.
  1. Provide fire extinguishers, installed on walls on mounting brackets, visible and accessible from space being served, with sign mounted above. Store combustible materials in containers in fire-safe locations.
  2. Maintain unobstructed access to fire extinguishers, fire hydrants, temporary fire-protection facilities, stairways, and other access routes for firefighting. Prohibit smoking in hazardous fire-exposure areas.

**3.5 OPERATION, TERMINATION, AND REMOVAL**

- A. Termination and Removal: Remove each temporary facility when need for its service has ended, when it has been replaced by authorized use of a permanent facility, or no later than Substantial Completion. Complete or, if necessary, restore permanent construction that may have been delayed because of interference with temporary facility. Repair damaged Work, clean exposed surfaces, and replace construction that cannot be satisfactorily repaired.
  1. Materials and facilities that constitute temporary facilities are the property of Contractor. Owner reserves right to take possession of Project identification signs.
  2. Remove temporary paving not intended for or acceptable for integration into permanent paving. Where area is intended for landscape development, remove soil and aggregate fill that do not comply with requirements for fill or subsoil. Remove materials contaminated with road oil, asphalt and other petrochemical compounds, and other substances that might impair growth of plant materials or lawns. Repair or replace street paving, curbs, and sidewalks at temporary entrances, as required by authorities having jurisdiction.
  3. At Substantial Completion, clean and renovate permanent facilities used during construction period. Comply with final cleaning requirements in Division 1 Section "Closeout Procedures."

**END OF SECTION 01500**

**SECTION 01170 - CLOSEOUT PROCEDURES**

**PART 1 - GENERAL**

- 1.1 SUMMARY**
- A. This Section includes administrative and procedural requirements for final closeout, including, but not limited to, the following:
    1. Inspection procedures.
    2. Project Record Documents.
    3. Operation and maintenance manuals.
    4. Warranties.
    5. Instructions of Owner's personnel.
    6. Final cleaning.

**SUBSTANTIAL COMPLETION**

- Preliminary Procedures: Before requesting inspection for determining date of Substantial Completion, complete the following:
  1. Prepare a list of items to be completed and corrected (punch list), the value of items on the list, and reasons why the work is not complete.
  2. Advise Owner of pending insurance coverage requirements.
  3. Submit final warranties, workmanship bonds, maintenance service agreements, final inspection and maintenance documents, and similar documents.
  4. Obtain and submit releases permitting Owner unrestricted use of the Work and access to services and utilities. Include occupancy permits, operating certificates, and similar releases.
  5. Prepare and submit Project Record Documents, operation and maintenance manuals, property surveys, and similar final record information.
  6. Deliver tools, spare parts, extra materials, and similar items to location designated by Owner. Label with manufacturer's name and model number where applicable.
  7. Make final changeover of permanent locks and deliver keys to Owner. Advise Owner's personnel of changeover in security provisions.
  8. Complete startup testing of systems.
  9. Submit test/adjust/balance records.
  10. Terminate and remove temporary facilities from Project site, along with mockups, construction tools, and similar elements.
  11. Advise Owner of changeover in heat and other utilities.
  12. Submit changeover information related to Owner's occupancy, use, operation, and maintenance.
  13. Complete final cleaning requirements, including touchup painting.
  14. Touch up and otherwise repair and restore marred exposed finishes to eliminate visual defects.
- B. Inspection: Submit a written request for inspection for Substantial Completion. On receipt of request, Architect will either proceed with inspection or notify Contractor of unfulfilled requirements. Architect will prepare the Certificate of Substantial Completion after inspection or will notify Contractor of items, either on Contractor's list or additional items identified by Architect, that must be completed or corrected before certificate will be issued.
  1. Reinspection: Request reinspection when the Work identified in previous inspections as incomplete is completed or corrected.
  2. Results of completed inspection will form the basis of requirements for Final Completion.

**1.3 FINAL COMPLETION**

- A. Preliminary Procedures: Before requesting final inspection for determining date of Final Completion, complete the following:
  1. Submit a final Application for Payment according to Division 1 Section "Payment Procedures."
  2. Submit certified copy of Architect's Substantial Completion inspection list of items to be completed or corrected (punch list), enclosed and dated by Architect. The certified copy of the list shall state that each item has been completed or otherwise resolved for acceptance.
  3. Submit evidence of final, continuing insurance coverage complying with insurance requirements.
  4. Submit pest-control final inspection report and warranty.
  5. Instruct Owner's personnel in operation, adjustment, and maintenance of products, equipment, and systems.
- B. Inspection: Submit a written request for final inspection for acceptance. On receipt of request, Architect will either proceed with inspection or notify Contractor of unfulfilled requirements. Architect will prepare a final Certificate for Payment after inspection or will notify Contractor of construction that must be completed or corrected before certificate will be issued.
  1. Reinspection: Request reinspection when the Work identified in previous inspections as incomplete is completed or corrected.

**1.4 LIST OF INCOMPLETE ITEMS (PUNCH LIST)**

- A. Preparation: Submit 3 copies of list. Include name and identification of each space and area affected by construction operations for incomplete items and items needing correction including, if necessary, areas disturbed by Contractor that are outside the limits of construction. Use CSI Form 14.1A.
  1. Organize list of spaces in sequential order, starting with exterior areas first.
  2. Organize items applying to each space by major element, including categories for ceiling, individual walls, floors, equipment, and building systems.

**1.5 PROJECT RECORD DOCUMENTS**

- A. General: Do not use Project Record Documents for construction purposes. Protect Project Record Documents from deterioration and loss. Provide access to Project Record Documents for Architect's reference during normal working hours.
- B. Record Drawings: Maintain and submit one set of blue- or black-line white prints of Contract Drawings and Shop Drawings.
  1. Mark Record Prints to show the actual installation where installation varies from that shown originally. Prepare individual or entity who obtained record data, whether individual or entity is Installer, subcontractor, or similar entity, to prepare the marked-up Record Prints.
    - a. Give particular attention to information on concealed elements that cannot be readily identified and recorded later.
    - b. Record data as soon as possible after obtaining it. Record and check the markup before enclosing concealed installations.
  2. Mark record prints with erasable or non-erasable pencil. Use other colors to distinguish between changes for different categories of the Work at the same location.
  3. Note Construction Change Directive numbers, Change Order numbers, alternate numbers, and similar identification where applicable.
  4. Identify and date each Record Drawing; include the designation "PROJECT RECORD DRAWING" in a prominent location. Organize into manageable sets; bind each set with durable paper cover sheets. Include identification on cover sheets.
- C. Miscellaneous Record Submittals: Assemble miscellaneous records required by other Specification Sections for miscellaneous record keeping and submit in connection with actual performance of the Work. Bind or file miscellaneous records and identify each, ready for continued use and reference.

**1.6 OPERATION AND MAINTENANCE MANUALS**

- A. Assemble a complete set of operation and maintenance data indicating the operation and maintenance of each system, subsystem, and piece of equipment not part of a system. Include operation and maintenance data required in individual Specification Sections and as follows:
  1. Operation Data: Include emergency situations and procedures, system and equipment descriptions, operating procedures, and sequence of operations.
  2. Maintenance Data: Include manufacturer's information, list of spare parts, maintenance procedures, maintenance and service schedules for preventive and routine maintenance, and copies of warranties and bonds.
- B. Organize operation and maintenance manuals into suitable sets of manageable size. Bind and index data in heavy-duty, three-ring, vinyl-covered, loose-leaf binders, in thickness necessary to accommodate contents, with pocket inside the cover to receive folded oversized sheets. Identify each binder on front and spine with the printed title "OPERATION AND MAINTENANCE MANUAL," Project name, and subject matter of contents.

**1.7 WARRANTIES**

- A. Submittal Time: Submit written warranties on request of Architect for designated portions of the Work where commencement of warranties other than date of Substantial Completion is indicated.



**Publix Super Markets, Inc.**  
 3300 Public Corporate Pkwy.  
 Lakeland, FL 33811-3311

**Retal @ Red Bank**  
 South Lake Drive & Plant Springs Road  
 Lakeland, South Carolina



RELEASE	ISSUED TO BID/PERMIT 06/10/17
PROJECT NAME	Retal @ Red Bank
PROJECT NO.	
DATE	
DRAWN	
CHECKED	
DATE	

**A-002**

Order Information