



GENERAL NOTES:

- INTERIOR FOOTINGS HEREIN ARE RELATIVE TO FINISHED FLOOR ELEVATION OF 100'-0". THE TOP OF ALL INTERIOR FOOTINGS SHALL BE THIS 38'-0", TYP. U.O.N.
- EXTERIOR FOOTINGS HEREIN ARE RELATIVE TO FINISHED FLOOR ELEVATION OF 100'-0". THE TOP OF ALL EXTERIOR FOOTINGS SHALL BE THIS 38'-0", TYP. U.O.N.
- REFERENCE ARCHITECTURAL DRAWINGS FOR LOCATIONS AND CONSTRUCTION OF NON-LOAD BEARING MIL STUD WALLS, FIXTURES, AND OTHER ITEMS NOT PRESENTED HEREIN.
- 4" CONCRETE SLAB W/ 3000 PSI CONC. W/ 6X6X10X3 1/2 W W/F OVER 10 MIL MIN. VAPOR RETARDER. REFER TO GEOTECHNICAL FOR SUBGRADE REQUIREMENTS.
- C-J = CONTROL JOINT/CONSTRUCTION JOINT. TO BE COORDINATED (REF. SUBMITTAL SECTION OF GENERAL NOTES). CONTROL JOINTS SHALL BE 1" DEEP SAW CUTS TO BE MADE WITHIN 24 HRS OF POUR.
- REF. ARCH PLUMBING DRAWINGS FOR DRAIN SLOPES, ELEVATIONS AND SLAB RECESSES.
- CONTROL JOINTS (C-J) SHALL BE LOCATED AT 12'-0" O.C. MAX U.O.N. WITH LENGTH TO WIDTH RATIO NOT TO EXCEED 1.5:1.
- OPENING RE-ENTRANT CORNER, TYP. PROVIDE (2) #4 X 4'-0" LONG BARS @ MID-HEIGHT OF SLAB.

Mark	Length	Width	Foundation	Top Reinf.	Bottom Reinf.
F5	5'-0"	6'-0"	12" O.C.F.	#5 @ 12" O.C. E-W	#5 @ 12" O.C. E-W
F7	7'-0"	1'-0"	12" O.C.F.	#5 @ 12" O.C. E-W	#5 @ 12" O.C. E-W
F8	7'-0"	1'-0"	12" O.C.F.	#5 @ 12" O.C. E-W	#5 @ 12" O.C. E-W

Mark	Length	Width	PL Thickness	Masonry	Anchor Bolts
BP1	2'-0"	1'-0"	3/4"	ASB S.T.	(4) 3/4" THREADED HEADED STUDS (ASTM F1554 GR. 55 S1)
BP2	2'-0"	1'-0"	3/4"	ASB S.T.	(4) 3/4" THREADED HEADED STUDS (ASTM F1554 GR. 55 S1)

Mark	Width	Foundation Thickness	Top Reinf.	Bottom Reinf.
WF2	2'-0"	1'-0"	N/A	(8) #5 CDNT

Mark	Size	Vert Reinf.	Notes
MP#A3B	8" x 16"	(2) #5 EACH CELL (EDGE SPACING) REF. GEN. CMU INFO.	
MP#A3B	8" x 24"	(2) #5 EACH CELL (EDGE SPACING) REF. GEN. CMU INFO.	

1 Foundation Plan
SCALE: 1/8" = 1'-0"

- STRUCTURAL KEY NOTES:**
- (1) DRILL & EPOXY (3) #6 DOWELS FROM RETAIL FTG. TO PUBLIX FTG. IN A MIN. OF 4" EMBEDMENT OR POUR MONOLITHICALLY MATCH TOP OF PUBLIX FTG.
 - (2) EXPANSION JOINT REF. ARCH. FOR ADDITIONAL INFORMATION.
 - (3) REF. PUBLIX FOUNDATION PLANS FOR ADDITIONAL FOOTING AND COLUMN INFORMATION.
 - (4) MATCH PUBLIX TOP OF FTG. TYP. AT PUBLIX WALL.
 - (5) PUBLIX STRUCTURE, REF. PUBLIX PLANS FOR ADDITIONAL COLUMN WALL INFORMATION.
 - (6) REF. PUBLIX FOUNDATION PLANS FOR ADDITIONAL COLUMN WALL INFORMATION.
 - (7) PUBLIX FTG. MONOLITHICALLY MATCH TOP OF PUBLIX FTG. TYP.
 - (8) G.C. TO BE INDICATED FOOTING IN LIEU OF FOOTING INDICATED IN PLAN.

1925 Prospect Ave.
Orlando, FL 32814
P (407) 661-9100
F (407) 661-9101
www.ldilline.com

LDILLINE
Architects & Engineers

Windcrest Companies
605 E. Robinson Street, Suite 340
Orlando, Florida 32801

Publix/Retail @ Lake Crossing
South Lake Drive & Platt Springs Road
Lexington, South Carolina



No.	Description	Date
A	100% Publix Submission	03-31-17
C	ISSUED FOR PERMIT	08-10-17

S101