



TAG	DESCRIPTION	DATE
-----	-------------	------


FOUNDATION AND FRAMING PLANS

CLEMMONS FIRST BAPTIST CHURCH NARTHEX ADDITION




AUGUST 7, 2017


RSS	DESIGNED BY	SHEET NO.
RSS	CHECKED BY	51.1
DATE	DATE	OF 7
5/12/16	5/12/16	
SCALE		



5 LEVEL 5 FRAMING PLAN, COLD-FORMED STEEL



3 LEVEL 3 FRAMING PLAN



1 FOUNDATION PLAN

FOUNDATION PLAN NOTES


- REFERENCED FINISHED GROUND FLOOR ELEVATION IS +0'-0". ACTUAL FINISHED FLOOR ELEVATION IS #.#.#.
- SEE PLANS AND SECTIONS FOR TOP OF FOOTING ELEVATIONS.
- TOP OF COLUMN PIER ELEVATIONS ARE (1'-4") BELOW FINISHED GROUND FLOOR EL. UNLESS NOTED ON PLAN.
- FLOOR SLAB-ON-GRADE (SOG) CONSTRUCTION.
- SOG-1 TYPICAL U.N.O. 4" CONCRETE SLAB, VAPOR RETARDER 6" x 6" - #1.4 x #1.4 MESH, 4" STONE BASE.
- ⊖ - INDICATES STEEL COLUMN MARK. SEE CONCRETE PIER DETAILS. 11/52.1
 □ - INDICATES CONCRETE PIER MARK. SEE CONCRETE PIER DETAILS. 4/52.1
- SEE ARCHITECTURAL AND CIVIL DRAWINGS FOR EXTENT SIDEWALKS AND PERIMETER CONCRETE SLABS.
- ⊕ - INDICATES APPROXIMATE SOIL BORING LOCATIONS. (GEO. TECH. REPORT)
- NO PIPE SHALL PENETRATE OR BE CAST INTO CONCRETE FOOTINGS. PIPES SHALL PENETRATE STEM WALLS OR BE INSTALLED UNDER ISOLATED AND CONTINUOUS FOOTINGS.

FRAMING LEVELS


- TOP OF STRUCTURAL STEEL, DECK BEARING ELEVATION. SEE SECTIONS INDIVIDUAL LEVEL PLANS FOR TOP OF STEEL ELEVATIONS.
 TOS EL. = INDICATES TOP OF STRUCTURAL STEEL
 DB EL. = INDICATES BOTTOM OF METAL DECK BEARING ELEVATION.
- METAL FLOOR/ROOF DECK 1/2" DEEP, TYPE 30, WIDE RIB, 20-GAUGE, GALVANIZED WITH A MINIMUM OF THREE SPAN SUPPORT CONDITIONS. MINIMUM SECTION PROPERTIES:
 I_x = 12.1 in⁴; I_y = 2.34 in⁴; S_x = 247 in³; S_y = 33 in³
 WELD FASTENER LAYOUT: SEE PATTERN, 5/8" MIN. DIAMETER PUDDLE WELDS.
 EXTREME EDGE CONNECTIONS: 5/8" DIA. PUDDLE WELDS @ 12" OC MAX.
 SIDE LAP CONNECTIONS: #10 HEX HD SCREENS @ 18" OC MAX.
 TYPICAL UNLESS NOTED OTHERWISE.

⊕ - INDICATES WELDED MOMENT CONNECTION. SEE DETAIL 10/54.1
 MC-2 - INDICATES WELDED MOMENT CONNECTIONS, HSS SECTIONS, SEE SHEET 11/54.1
 EP-1 - INDICATES BOLTED END-PLATE MOMENT CONNECTIONS. SEE DETAILS 7, 8, 9/54.1

6 SHEET NOTES FOR PLANS



4 LEVEL 4 FRAMING PLAN



2 LEVEL 2 FRAMING PLAN

Order Plans @ WWW.LDOnline.com