



FUELING US HY 74 & TECHNOLOGY BLVD INDIAN TRAIL, NC 28079

SHEET INDEX

FS1	FUELING COVER SHEET AND INDEX
FS2	FUELING SITE PLAN
FS2.1	FUELING TRUCK ROUTE
FS3	PIPING PLAN AND DETAILS
FS4	SLAB PLAN AND DETAILS
FS5	TANK SECTIONS AND DETAILS
FS6	TANK SUMP DETAILS
FS7	MULTIPOINT SUMP DETAILS
FS8	DISPENSER AND SUMP DETAILS
FS9	DIESEL DISPENSER AND SUMP DETAILS
FS10	REMOTE VENT, E-STOP AND 911 PHONE
FS11	FUELING CANOPY LAYOUT
FS12	EQUIPMENT SCHEDULES
FS13	FUELING SPECS
FS14	FUELING SPECS
FS15	FUELING SPECS
FS16	FUELING SPECS
FS17	FUELING SPECS
FSE1	SITE ELECTRICAL PLAN
FSE2	TANK ELECTRICAL AND DETAILS
FSE3	PANEL SCHEDULES AND ONE-LINE DIAGRAM
FSE4	SITE BONDING DIAGRAMS
FSE5	SITE MONITORING WIRING DIAGRAM
FSE6	DISPENSER AND SITE ETHERNET WIRING DIAGRAM
FSE7	ISOLATION RELAY BOX DETAIL
FSE8	SITE MONITORING EQUIPMENT DIAGRAMS

HFA
ARCHITECTS
ENGINEERS
INTERIORS

HARRISON FRENCH
ASSOCIATES, PLLC

1705 S. WALTON BLVD, SUITE 3
BENTONVILLE, AR 72712
T 479-273-7780
F 479-231-9585
www.hfa-ae.com

STIPULATION FOR REUSE

THIS DRAWING IS THE PROPERTY OF HARRISON FRENCH ASSOCIATES, PLLC. IT IS TO BE USED ONLY FOR THE PROJECT AND SITE SPECIFICALLY IDENTIFIED HEREON. IT IS NOT TO BE REPRODUCED, COPIED, OR TRANSMITTED IN ANY FORM OR BY ANY MEANS, ELECTRONIC OR MECHANICAL, INCLUDING PHOTOCOPYING, RECORDING, OR BY ANY INFORMATION STORAGE AND RETRIEVAL SYSTEM, WITHOUT THE WRITTEN PERMISSION OF HARRISON FRENCH ASSOCIATES, PLLC.

- ## SUMMARY OF WORK
- GRADING AND SITEWORK.
 - ASSOCIATED UNDERGROUND TANKS AND PIPING.
 - FUELING STATION DESCRIPTION:
 - (4) NEW GILBARCO 700 S 3+1 DISPENSERS WITH ETHANOL FREE UNLEADED
 - (2) NEW GILBARCO 700 S 3+1 DISPENSERS WITH DIESEL
 - (1) 10' DIA. 20K GAL. GLASTEEL II UST FOR UNLEADED FUEL (DRY INTERSTICE)
 - (1) 10' DIA. 20K GAL. 3-COMPARTMENT GLASTEEL II UST - 6K DSL / 6K PUL / 6K EF-UNL (DRY INTERSTICE)
 - (3) 2.0 hp FIXED SPEED STP FOR RUL, EF-UNL AND PUL
 - (1) 1.5 hp FIXED SPEED STP FOR DIESEL
 - (4) ATG's (1 PER STP SUMP)
 - (4) MULTIPOINT FILL SUMPS (1 EACH UST COMPARTMENT)
 - 3" OVER 2" FRP PRODUCT PIPING
 - 2" SGL-WALL FRP VENT PIPING (UST's TO REMOTE VENT RISERS)
 - (1) NEW 24'-0" X 161'-0" FUELING CANOPY FOR (6) DISPENSERS (INLINE)

PROJECT DATA

BUILDING CODE:	2012 NC BUILDING CODE W/ AMENDMENTS
MECHANICAL CODE:	2012 NC MECHANICAL CODE W/ AMENDMENTS
PLUMBING CODE:	2012 NC PLUMBING CODE W/ AMENDMENTS
ELECTRICAL CODE:	2014 NEC
FIRE CODE:	2012 NC FIRE CODE W/ AMENDMENTS

NFPA 30 FLAMMABLE AND COMBUSTIBLE LIQUIDS CODE - LATEST EDITION
NFPA 30A CODE FOR MOTOR FUEL DISPENSING FACILITIES AND REPAIR GARAGES - LATEST EDITION
NFPA 1 UNIFORM FIRE CODE HANDBOOK

DISCLAIMER

EXISTING CONDITIONS SHOWN IN THESE CONSTRUCTION DOCUMENTS ARE BASED ON DRAWINGS AND OR INFORMATION PROVIDED TO HFA BY THE OWNER OR THE OWNER'S DULY AUTHORIZED REPRESENTATIVE. HFA HAS NOT FIELD VERIFIED THE EXISTING CONDITIONS INFORMATION AND ASSUMES NO RESPONSIBILITY FOR THE ACCURACY AND COMPLETENESS OF THIS INFORMATION. THE GENERAL CONTRACTOR SHALL NOTIFY HFA AND THE OWNER IMMEDIATELY IF EXISTING CONDITIONS ARE NOT AS SHOWN ON THE CONSTRUCTION DOCUMENTS.

PROJECT DIRECTORY

OWNER:	SXCW PROPERTIES, LLC 7935 COUNCIL PLACE, SUITE 200 MATTHEWS, NC 28105 (704) 567-8424
ARCHITECTURAL FIRM:	HARRISON FRENCH & ASSOCIATES, PLLC 1705 S. WALTON BLVD, SUITE 3 BENTONVILLE, AR 72712 (479) 273-7780
MEP ENGINEER:	RYAN RAY (ryan.ray@hfa-ae.com)
FUEL PROGRAM MGR:	BRANSON HALL (branson.hall@hfa-ae.com)

SAM'S MART
US HY 74 & TECHNOLOGY BLVD
INDIAN TRAIL, NC 28079

JOB NUMBER: 07-16-80004

ISSUE BLOCK

NO.	DESCRIPTION	DATE


STORE NO: _____

DOCUMENT DATE: 05-31-17

CHECKED BY: *PH* BKH

DRAWN BY: JMA

PROTO CYCLE MAY-2017





HARRISON FRENCH AND ASSOCIATES, PLLC
P-0402

MAY 31 2017

**FUELING
COVER SHEET
AND INDEX**

SHEET: **FS1**



May 04 2017 10:11am - User: jn
 A:\07\07-16-80004-Sams Mart - Indian Trail, NC\Fuel\Site\Draws\Fuel FS1 FUELING COVER SHEET AND INDEX.dwg

Order Plans

WWW.LDILLIEN.COM