


SITE NOTES

1. COORDINATE EXACT STUB-UP OF ALL CONDUIT WITH OWNER.
2. ALL CONDUITS TO BE UNDERGROUND UNLESS NOTED OTHERWISE.
3. COORDINATE EXACT ELECTRICAL REQUIREMENTS WITH INSTALLED EQUIPMENT.



HARRISON FRENCH & ASSOCIATES, PLLC
 1705 S. Harrison Blvd., Suite 3
 Bentonville, Arkansas 72712
 479.272.7780
 479.250.9685
 www.hfa-ac.com

STIPULATION FOR REUSE
 THIS DRAWING WAS PREPARED FOR USE ON A SPECIFIC PROJECT AND IS NOT TO BE REUSED OR REPRODUCED IN ANY MANNER WITHOUT THE WRITTEN CONSENT OF HARRISON FRENCH & ASSOCIATES, PLLC. ANY REUSE OF THIS DRAWING OR ANY PART OF IT AT A LATER TIME OR IN ANOTHER PROJECT WITHOUT THE WRITTEN CONSENT OF HARRISON FRENCH & ASSOCIATES, PLLC IS STRICTLY PROHIBITED AND MAY BE CONSIDERED A VIOLATION OF APPLICABLE LAWS AND REGULATIONS.

SAM'S MART
 US HY 74 & TECHNOLOGY BLVD
 INDIAN TRAIL, NC 28079

JOB NUMBER: 07-16-80004

ISSUE BLOCK


STORE NO.:

DOCUMENT DATE: 05-31-17

CHECKED BY: JAC

DRAWN BY: KRS

PROTO CYCLE: MAY-2017



HARRISON FRENCH AND ASSOCIATES, PLLC
 P-0402
 5.31.17

ELECTRICAL SITE PLAN

SHEET: FSE6



REFER TO CIVIL DRAWING FOR EXACT LOCATIONS OF SITE SIGNAGE, LIGHTS, AND EQUIPMENT.

PROVIDE 1" CONDUIT FROM EMERGENCY PHONE TO PHONE EQUIPMENT AT CARWASH. REF CARWASH DRAWINGS FOR STUB-UP LOCATIONS. REF 3 FS-10 FOR INSTALLATION DETAILS AT POST.

E-STOP LOCATION. ROUTE 1" CONDUIT WITH WIRING TO CONTRACTOR ON FUELING WALL REF3-FSE3

100 FT RADIUS TO E-STOP

AIR STATION. PROVIDE WEATHER PROOF JUNCTION BOX AND MAKE FINAL CONNECTIONS WITH SEAL-TIGHT

1 ELECTRICAL SITE PLAN
 SC 3/32" = 1'-0"

Order Plans @ www.LDILine.com

May 31, 2017 8:05am - User: hfr@hfa.com
 2017-05-31 08:05:07 Sam Harris - hfr@hfa.com, NCMEP/SAM/Sheet1 (550) - FSE6 ELECTRICAL SITE PLAN.dwg