



- LEGEND:**
- ① SINGLE ARCH WITH 12" INTERCEPTOR (4)
  - ② DOUBLE ARCH WITH 12" INTERCEPTOR (12)
  - ③ EM 40HP SYSTEM WITH 38" BAG SEPARATOR  
1250 CFM @ 7" HG  
ELECTRICAL REQUIREMENTS:  
SUPPLY: 208-250/3/60  
FULL LOAD AMPS: 100-88 AMPS  
CIRCUIT REQUIRED: 150-130 AMPS
  - ④ EM 30HP SYSTEM WITH 34" BAG SEPARATOR  
990 CFM @ 6.5" HG  
ELECTRICAL REQUIREMENTS:  
SUPPLY: 208-250/3/60  
FULL LOAD AMPS: 74-68 AMPS  
CIRCUIT REQUIRED: 110-100 AMPS
  - ⑤ TUBE CLEANOUT
  - ⑥ SINGLE CANOPY DROP (2)
  - ⑦ DOUBLE CANOPY DROP (7)

**GENERAL NOTES:**

1. ALL LOCATIONS AND DISTANCES ARE APPROXIMATE.
2. VACUUM EQUIPMENT AREA TO BE PROPERLY VENTILATED.
3. CUSTOMER TO VERIFY THE FOLLOWING:
  - A. ALL LOCATIONS;
  - B. ALL DISTANCES;
  - C. BUILDING ELEVATION AND ACCESS;
  - D. LINE VOLTAGE.
4. VACUUM LINES SHOULD COME UP CENTERED TO PROPOSED PARKING STRIPING. SEE CIVIL ENGINEERING SITE PLANS FOR STRIPING-DETAILS DIMENSIONS.

**EUROVAC TO PROVIDE:**

1. ELECTRICAL CONTROL WIRING FROM OUR CONTROL PANEL TO OUR DEVICES.
2. INSTALL ALL VACUUM EQUIPMENT AND TUBING.

**CONTRACTOR TO PROVIDE:**

1. ANY WALL, FLOOR OR ROOF PENETRATIONS.
2. POWER WIRING TO OUR CONTROL PANEL (460V)

Order Plans @ WWW.LDILine.com

REV.	DATE:	DESCRIPTION:
1		
2		
3		
4		
5		

**EUROVAC**  
WWW.EUROVAC.COM  
TEL: 1-800-265-3878

SCALE: N.T.S.
DATE: 16/05/17
APPROVED BY: AR

SITE PLAN  
**SAM'S WINSTON SALEM**  
PIPING LAYOUT

DRAWN BY: AV
SHEET: 1 OF 3