

SECTION 09260 - GYPSUM BOARD ASSEMBLIES, CONTINUED
PART 3 - EXECUTION

3.1 NON-LOAD-BEARING STEEL FRAMING INSTALLATION
A. GENERAL: COMPLY WITH ASTM C 754, AND ASTM C 840 REQUIREMENTS THAT APPLY TO FRAMING AND INSULATION.
B. SUSPENDED CEILING AND SOFFIT FRAMING:
1. SUSPEND CEILING HANGERS PLUMB AND FREE FROM CONTACT WITH INSULATION OR OTHER OBJECTS WITHIN CEILING PLENUM THAT ARE NOT PART OF SUPPORTING STRUCTURAL OR CEILING SUSPENSION SYSTEM. SPLAY HANGERS ONLY WHERE REQUIRED TO MISS OBSTRUCTIONS AND OFFSET RESULTING HORIZONTAL FORCES BY BRACING, COUNTER-SPLAYING, OR OTHER EQUALLY EFFECTIVE MEANS.
2. WHERE WIDTH OF DUCTS AND OTHER CONSTRUCTION WITHIN CEILING PLENUM PRODUCES HANGER SPACINGS THAT INTERFERE WITH THE LOCATION OF HANGERS REQUIRED TO SUPPORT STANDARD SUSPENSION SYSTEM MEMBERS, INSTALL SUPPLEMENTAL SUSPENSION MEMBERS AND HANGERS IN FORM OF TRAPEZES OR EQUIVALENT DEVICES. SIZE SUPPLEMENTAL SUSPENSION MEMBERS AND HANGERS TO SUPPORT CEILING LOADS WITHIN PERFORMANCE LIMITS ESTABLISHED BY REFERENCED STANDARDS.
3. ATTACH HANGERS TO STRUCTURAL MEMBERS. DO NOT SUPPORT CEILINGS FROM OR ATTACH HANGERS TO PERMANENT METAL FORMS, STEEL DECK TABS, STEEL ROOF DECKS, DUCTS, PIPES, OR CONDUIT.
C. PARTITION AND SOFFIT FRAMING:
1. WHERE STUDS ARE INSTALLED DIRECTLY AGAINST EXTERIOR WALLS, INSTALL ISOLATION STRIP BETWEEN STUDS AND WALL.
2. EXTEND PARTITION FRAMING FULL HEIGHT TO STRUCTURAL SUPPORTS OR SUBSTRATES ABOVE SUSPENDED CEILINGS, EXCEPT WHERE PARTITIONS ARE INDICATED TO TERMINATE AT SUSPENDED CEILINGS. CONTINUE FRAMING OVER FRAMES FOR DOORS AND OPENINGS AND FRAME AROUND DUCTS PENETRATING PARTITIONS ABOVE CEILING TO PROVIDE SUPPORT FOR GYPSUM BOARD.
3. FRAME DOOR OPENINGS TO COMPLY WITH GA-600 AND WITH GYPSUM BOARD MANUFACTURER'S APPLICABLE WRITTEN RECOMMENDATIONS, UNLESS OTHERWISE INDICATED. SCREW VERTICAL STUDS AT JAMBS TO JAMB ANCHOR CLIPS ON DOOR FRAMES; INSTALL RUNNER TRACK SECTION (FOR CRIPPLE STUDS) AT HEAD AND CLIPS TO JAMB STUDS.
a. INSTALL TWO STUDS AT EACH JAMB, UNLESS OTHERWISE INDICATED.
4. FRAME OPENINGS OTHER THAN DOOR OPENINGS THE SAME AS REQUIRED FOR DOOR OPENINGS, UNLESS OTHERWISE INDICATED. INSTALL FRAMING BELOW SILLS OF OPENINGS TO MATCH FRAMING REQUIRED ABOVE DOOR HEADS. NO UNFINISHED GYP. WORK AND WOOD WORK ALLOWED, INCLUDING BEHIND FURNITURE & ANY EQUIPMENT ITEMS. ALL GYPSUM BOARD PARTITIONS SHALL BE TAPED, SPACKLED, AND SANDED SMOOTH WITH NO VISIBLE JOINTS. PAINT AS SPECIFIED. PROVIDE GALVANIZED METAL CORNER BEADS AND SIMILAR CONCEALED TRIM AT ALL EXPOSED EDGES; USE EXPOSED TRIM ONLY AS APPROVED BY ARCHITECT.
D. Z-FURRING MEMBERS: ERECT INSULATION VERTICALLY AND HOLD IN PLACE WITH Z-FURRING MEMBERS.
3.2 PANEL PRODUCT INSTALLATION
A. GYPSUM BOARD: COMPLY WITH ASTM C 840 AND GA-216.

SECTION 09650 - RESILIENT FLOORING
1.1 GENERAL
A. PROVIDE RESILIENT FLOORING WHERE INDICATED IN THE DRAWINGS AS REQUIRED HEREIN, AND AS NECESSARY FOR A COMPLETE AND PROPER INSTALLATION. THE WORK INCLUDES CALCULATION OF MATERIAL QUANTITY REQUIRED, LEVELING AND PATCHING OF CONCRETE FLOORS, INSTALLATION OF RESILIENT FLOORING AND ACCESSORIES.
1.2 SUBMITTALS
A. PRODUCT DATA: FOR EACH PRODUCT INDICATED.
PART 2 - PRODUCTS
2.1 MATERIALS
A. VINYL COMPOSITION TILE: 12X12X1/8 VCT OR 36"X36" VINYL FLOORING PER FINISH SCHEDULE.
B. TRANSITION AND EDGE STRIPS: RUBBER, THICKNESS TO MATCH ADJACENT TILE, TAPERED, OR BULLSEYE EDGE. COLOR PER FINISH SCHEDULE.
C. LEVELING COMPOUND: ARDEX 50-1
D. ADHESIVE: WATER RESISTANT, NON-STAINING AS RECOMMENDED BY VCT MANUFACTURER.
2.2 INSTALLATION
A. IF FLOOR LEVELING OR PREPARATION IS REQUIRED TO MAKE FLOOR SURFACE READY FOR FINISH WORK, CONTRACTOR SHALL PREPARE FLOOR ARE PER MANUFACTURER'S REQUIREMENTS.
B. INSTALL WALL TO WALL AND TO FIXED CABINETS AND UNDER FREESTANDING EQUIPMENT.
C. LAY OUT SQUARE, PARALLEL WITH STRAIGHT UNBROKEN JOINT LINES. FIT TIGHTLY AND ACCURATELY TO VERTICAL SURFACE, FLOOR PLATES, THRESHOLDS, EDGING STRIPS WITH CLEAR CUTS.
2.3 CLEANING AND FINISHING
A. CLEAN ALL RESILIENT FLOORING THOROUGHLY AND APPLY WAX OF FINISHING MATERIALS IN ACCORD WITH MANUFACTURER'S RECOMMENDATIONS.
B. POLISH THOROUGHLY. DELAY CLEANING AND FINISHING UNTIL JUST PRIOR TO DATE OF SUBSTANTIAL COMPLETION.

SECTION 09681 - TILE CARPETING
1.1 GENERAL
A. PROVIDE RESILIENT FLOORING WHERE INDICATED IN THE DRAWINGS AS REQUIRED HEREIN, AND AS NECESSARY FOR A COMPLETE AND PROPER INSTALLATION. THE WORK INCLUDES CALCULATION OF MATERIAL QUANTITY REQUIRED, LEVELING AND PATCHING OF CONCRETE FLOORS, INSTALLATION OF TILE CARPET FLOORING AND ACCESSORIES.
PART 2 - PRODUCTS
2.1 MATERIALS
A. CARPET TILE TYPE <CT>: AS SCHEDULED, MANUFACTURED IN ONE COLOR DYE LOT.
2.2 ACCESSORIES
A. ADHESIVES: ACCEPTABLE TO CARPET TILE MANUFACTURER, COMPATIBLE WITH MATERIALS BEING ADHERED, MAXIMUM VOC CONTENT AS SPECIFIED IN SECTION 01 611.6.
PART 3 - EXECUTION
3.1 INSTALLATION
A. BLEND CARPET FROM DIFFERENT CARTONS TO ENSURE MINIMAL VARIATION IN COLOR MATCH.
B. CUT CARPET TILE CLEAN. FIT CARPET TIGHT TO INTERSECTION WITH VERTICAL SURFACES WITHOUT GAPS.
C. LAY CARPET TILE IN PATTERN INDICATED.

SECTION 09653 - RESILIENT BASE
1.1 GENERAL
A. PROVIDE RESILIENT BASE WHERE INDICATED IN THE DRAWINGS, AS REQUIRED HEREIN, AND AS NECESSARY FOR A COMPLETE AND PROPER INSTALLATION. THE WORK INCLUDES CALCULATION OF MATERIAL QUANTITY REQUIRED.
B. REPLACEMENT MATERIALS: AFTER COMPLETION OF WORK, DELIVER NOT LESS THAN 10 FEET OF EXTRA STOCK TO TENANT. EXTRAS SHALL BE FROM THE SAME BATCH AS THOSE INSTALLED.
1.2 SUBMITTALS
A. PRODUCT DATA: FOR EACH PRODUCT INDICATED.
PART 2 - PRODUCTS
2.1 MATERIALS
A. RESILIENT BASE PER FINISH SCHEDULE.
B. ADHESIVE: WATER RESISTANT, NON-STAINING AS RECOMMENDED BY MANUFACTURER.
2.2 INSTALLATION
A. INSTALL AROUND CABINETS AND OTHER STANDING EQUIPMENT.
B. SET STRAIGHT AND EVEN, JOINTS CLOSELY FITTED AND FLUSH, TOP AND BOTTOM, EDGES IN FIRM, FULL CONTACT WITH FLOOR AND WALL, OR TREADS AND ENTIRE BACKSIDE BONDED TO SUBSTRATE. PREVENT STAINING OF ADJACENT SURFACES.
2.3 CLEANING AND FINISHING
A. CLEAN ALL RESILIENT BASE THOROUGHLY IN ACCORD WITH MANUFACTURER'S RECOMMENDATIONS.
B. REMOVE STAINS AND EXCESS ADHESIVE FROM BASE AND ADJACENT SURFACES WITHOUT INJURY TO SURFACES.
C. REMOVE ALL SCRAPS AND RUBBISH.

SECTION 09775 - FIBER REINFORCED PANEL
1.1 GENERAL
A. THIS SECTION INCLUDES FIBER REINFORCED PANEL FOR RESTROOM WALLS AND MOP SINK WALLS.
PART 2 - PRODUCT
2.1 MATERIALS
A. FRP PANELS TO BE NUDD, INC (OR APPROVED EQUAL) LP-F9-FR .090" THICKNESS. 48" HIGH SHEETS WITH APPROPRIATE ACCESSORIES FOR A COMPLETE INSTALLATION.
PART 3 - EXECUTION
A. 2 PIECE DIVISION BARS SHALL BE USED AT ALL PANEL ABUTMENTS.
B. CORNER ANGLES SHALL BE USED AT ALL CORNERS.
C. PANEL CAPS SHALL BE USED THE LENGTH OF THE MATERIAL.
D. APPLY SEALANT ALONG TOP EDGES OF PANEL CAPS AT GYP. BOARD TRANSITION.

SECTION 09912 - PAINTING
PART 1 - GENERAL
1.1 SUMMARY
A. HIS SECTION INCLUDES SURFACE PREPARATION AND FIELD PAINTING OF EXPOSED ITEMS AND SURFACES.
1.2 PROJECT CONDITIONS
A. STORE MATERIALS NOT IN USE IN TIGHTLY COVERED CONTAINERS IN A WELL-VENTILATED AREA AT A MINIMUM AMBIENT TEMPERATURE OF 45 DEG F. MAINTAIN STORAGE CONTAINERS IN A CLEAN CONDITION, FREE OF FOREIGN MATERIALS AND RESIDUE.
B. APPLY WATERBORNE PAINTS ONLY WHEN TEMPERATURES OF SURFACES TO BE PAINTED AND SURROUNDING AIR ARE BETWEEN 50 AND 90 DEG.
C. APPLY SOLVENT-THINNED PAINTS ONLY WHEN TEMPERATURES OF SURFACES TO BE PAINTED AND SURROUNDING AIR ARE BETWEEN 45 AND 95 DEGREES FAHRENHEIT.
D. FOR SUSTAINABILITY PAINT IS TO BE A PRODUCT AND FROM A MANUFACTURER ACCEPTED BY THE CALIFORNIA HIGH PERFORMANCE SCHOOLS PROGRAM. WEBSITE IS HTTP://WWW.CHPS.NET
1.3 EXTRA MATERIALS
A. FURNISH EXTRA PAINT MATERIALS FROM THE SAME PRODUCTION RUN AS THE MATERIALS APPLIED AND IN THE QUANTITIES DESCRIBED BELOW. PACKAGE WITH PROTECTIVE COVERING FOR STORAGE AND IDENTIFY WITH LABELS DESCRIBING CONTENTS. DELIVER EXTRA MATERIALS TO OWNER.
1. QUANTITY: THREE PERCENT, BUT NOT LESS THAN 1 GAL OF EACH MATERIAL AND COLOR APPLIED.
PART 2 - PRODUCTS
2.1 MANUFACTURERS
A. PRODUCTS: AS LISTED IN THE FINISH SCHEDULE.
1. BENJAMIN MOORE & CO. (BENJAMIN MOORE).
2. SHERWIN-WILLIAMS CO. (SHERWIN-WILLIAMS).
3. GLIDDEN CO. (THE GLIDDEN COMPANY).
4. PPG INDUSTRIES INC. (PPG).
5. OR EQUAL AS APPROVED BY SPRINT PROJECT MANAGER
2.2 PAINT MATERIALS, GENERAL
A. MATERIAL COMPATIBILITY: PROVIDE BLOCK FILLERS, PRIMERS, AND FINISH-COAT MATERIALS THAT ARE COMPATIBLE AND WITH THE SUBSTRATES INDICATED UNDER CONDITIONS OF SERVICE AND APPLICATION, AS DEMONSTRATED BY MANUFACTURER BASED ON TESTING AND EXPERIENCE.
B. MATERIAL QUALITY: PROVIDE MANUFACTURER'S BEST-QUALITY PAINT MATERIAL OF THE VARIOUS COATING TYPES SPECIFIED THAT ARE FACTORY FORMULATED AND RECOMMENDED BY THE MANUFACTURER FOR APPLICATION INDICATED. PAINT-MATERIAL CONTAINERS NOT DISPLAYING MANUFACTURER'S PRODUCT IDENTIFICATION WILL NOT BE ACCEPTABLE.
C. COLORS: AS CALLED OUT IN FINISH SCHEDULE.
2.3 INTERIOR FINISH COATS
A. INTERIOR SEMI-GLOSS ALKYL ENAMEL:
1. AS CALLED OUT IN FINISH SCHEDULE.
2.4 PREPARATORY COATS
PART 3 - EXECUTION
3.1 APPLICATION
A. EXAMINE SUBSTRATES, AREAS, AND CONDITIONS, WHEN APPLICABLE, FOR PRESENT, FOR COMPLIANCE WITH REQUIREMENTS FOR PAINT APPLICATION.
B. COORDINATION OF WORK: REVIEW OTHER SECTIONS IN WHICH PRIMERS ARE PROVIDED TO ENSURE COMPATIBILITY OF THE TOTAL SYSTEM FOR VARIOUS SUBSTRATES. ON REQUEST, FURNISH INFORMATION ON CHARACTERISTICS OF FINISH MATERIALS TO ENSURE USE OF COMPATIBLE PRIMERS.
C. REMOVE HARDWARE AND ACCESSORIES, PLATES, MACHINED SURFACES, LIGHTING FIXTURES, AND EQUIPMENT ALREADY INSTALLED THAT ARE NOT TO BE PAINTED. IF REMOVAL IS IMPRACTICAL, IT IS POSSIBLE BECAUSE OF SIZE OR WEIGHT OF THE ITEM, PROVIDE SURFACE-APPLIED PROTECTION BEFORE SURFACE PREPARATION AND PAINTING.
1. AFTER COMPLETION OF PAINTING OPERATIONS IN EACH SPACE OR AREA, REINSTALL ITEMS REMOVED USING WORKERS EMPLOYED IN THE TRADES INVOLVED.
D. SURFACE PREPARATION: CLEAN AND PREPARE SURFACES TO BE PAINTED ACCORDING TO MANUFACTURER'S WRITTEN INSTRUCTIONS FOR EACH PARTICULAR SUBSTRATE CONDITION AND AS SPECIFIED.
1. PAINT BARRIER COATS OVER INCOMPATIBLE PRIMERS OR REMOVE AND REPRIME FERROUS METALS: CLEAN UNGALVANIZED FERROUS-METAL SURFACES THAT HAVE NOT BEEN SHOP COATED, REMOVE OIL, GREASE, DIRT, LOOSE MILL SCALE, AND OTHER FOREIGN SUBSTANCES. USE SOLVENT OR MECHANICAL CLEANING METHODS THAT COMPLY WITH SSPC'S RECOMMENDATIONS.
a. TREAT BARE AREAS AND SHOP-APPLIED PRIME COATS THAT HAVE BEEN DAMAGED. WIRE-BRUSH, CLEAN WITH SOLVENTS RECOMMENDED BY PAINT MANUFACTURER, AND TOUCH UP WITH SAME PRIMER AS THE SHOP COAT.
b. TOUCH UP BARE AREAS AND SHOP-APPLIED PRIME COATS THAT HAVE BEEN DAMAGED. WIRE-BRUSH, CLEAN WITH SOLVENTS RECOMMENDED BY PAINT MANUFACTURER, AND TOUCH UP WITH SAME PRIMER AS THE SHOP COAT.
3. GALVANIZED SURFACES: CLEAN GALVANIZED SURFACES WITH NONPETROLEUM-BASED SOLVENTS SO SURFACE IS FREE OF OIL AND SURFACE CONTAMINANTS. REMOVE PRETREATMENT FROM GALVANIZED SHEET METAL FABRICATED FROM COIL STOCK BY MECHANICAL METHODS.
E. MATERIAL PREPARATION:
1. MAINTAIN CONTAINERS USED IN MIXING AND APPLYING PAINT IN A CLEAN CONDITION, FREE OF FOREIGN MATERIALS AND RESIDUE.
2. STIR MATERIAL BEFORE APPLICATION TO PRODUCE A MIXTURE OF UNIFORM DENSITY. STIR AS REQUIRED DURING APPLICATION. DO NOT STIR SURFACE FILM INTO MATERIAL. IF NECESSARY, REMOVE SURFACE FILM AND STRAIN MATERIAL BEFORE USING.
F. EXPOSED SURFACES: INCLUDE AREAS VISIBLE WHEN PERMANENT OR BUILT-IN FIXTURES, GRILLES, CONNECTOR COVERS, AND SIMILAR COMPONENTS ARE IN PLACE. EXTEND COATINGS IN THESE AREAS, AS REQUIRED, TO MAINTAIN SYSTEM INTEGRITY AND PROVIDE DESIRED PROTECTION.
1. PAINT SURFACES BEHIND MOVABLE EQUIPMENT AND FURNITURE THE SAME AS SIMILAR EXPOSED SURFACES. BEFORE FINAL INSTALLATION OF EQUIPMENT, PAINT SURFACES BEHIND PERMANENTLY FIXED EQUIPMENT OR FURNITURE WITH PRIME COAT ONLY.
2. PAINT INTERIOR SURFACES OF DUCTS WITH A FLAT, NON-SPECULAR BLACK PAINT WHERE VISIBLE THROUGH REGISTERS OR GRILLES.
3. PAINT BACK SIDES OF ACCESS PANELS AND REMOVABLE OR HINGED COVERS TO MATCH EXPOSED SURFACES.
4. FINISH EXTERIOR DOORS ON TOPS, BOTTOMS, AND SIDE EDGES THE SAME AS EXTERIOR FACES.

6. SCHEDULING PAINTING: APPLY FIRST COAT TO SURFACES THAT HAVE BEEN CLEANED, PRETREATED, OR OTHERWISE PREPARED FOR PAINTING AS SOON AS PRACTICABLE AFTER PREPARATION AND BEFORE SUBSEQUENT SURFACE DETERIORATION.
1. OMIT PRIMER OVER METAL SURFACES THAT HAVE BEEN SHOP PRIMED AND TOUCH-UP PAINTED.
2. IF UNDERCOATS, STAINS, OR OTHER CONDITIONS SHOW THROUGH FINAL COAT OF PAINT, APPLY ADDITIONAL COATS UNTIL PAINT FILM IS OF UNIFORM FINISH, COLOR, AND APPEARANCE.
H. APPLICATION PROCEDURES: APPLY PAINTS AND COATINGS BY BRUSH, ROLLER, SPRAY, OR OTHER APPLICATORS ACCORDING TO MANUFACTURER'S WRITTEN INSTRUCTIONS.
I. MINIMUM COATING THICKNESS: APPLY PAINT MATERIALS NO THINNER THAN MANUFACTURER'S RECOMMENDED SPREADING RATE. PROVIDE TOTAL DRY FILM THICKNESS OF THE ENTIRE SYSTEM AS RECOMMENDED BY MANUFACTURER.
J. PRIME COATS: BEFORE APPLYING FINISH COATS, APPLY A PRIME COAT, AS RECOMMENDED BY MANUFACTURER; TO MATERIAL THAT IS REQUIRED TO BE PAINTED OR FINISHED AND THAT HAS NOT BEEN PRIME COATED BY OTHERS. RECOAT PRIMED AND SEALED SURFACES WHERE EVIDENCE OF SUCTION SPOTS OR UNSEALED AREAS IN FIRST COAT APPEARS, TO ENSURE A FINISH COAT WITH NO BURN-THROUGH OR OTHER DEFECTS DUE TO INSUFFICIENT SEALING.
3.2 CLEANING AND PROTECTING
A. AT THE END OF EACH WORKDAY, REMOVE EMPTY CANS, RAGS, RUBBISH, AND OTHER DISCARDED PAINT MATERIALS FROM PROJECT SITE.
B. PROTECT WORK OF OTHER TRADES, WHETHER BEING PAINTED OR NOT, AGAINST DAMAGE FROM PAINTING. CORRECT DAMAGE BY CLEANING, REPAIRING OR REPLACING, AND REPAINTING, AS APPROVED BY ARCHITECT.
C. PROVIDE "WET PAINT" SIGNS TO PROTECT NEWLY PAINTED FINISHES. AFTER COMPLETING PAINTING OPERATIONS, REMOVE TEMPORARY PROTECTIVE WRAPPINGS PROVIDED BY OTHERS TO PROTECT THEIR WORK.
1. AFTER WORK OF OTHER TRADES IS COMPLETE, TOUCH UP AND RESTORE DAMAGED OR DEFACED PAINTED SURFACES. COMPLY WITH PROCEDURES SPECIFIED IN PDCA P1.
3.3 INTERIOR PAINT SCHEDULE
A. WOOD: 1ST COAT PRIMER/FILLER AS REQUIRED INTERIOR SEMI-GLOSS ENAMEL
2ND COAT INTERIOR SEMI-GLOSS ENAMEL
B. METAL: 1ST COAT PRIMER INTERIOR SEMI-GLOSS ENAMEL
2ND COAT INTERIOR SEMI-GLOSS ENAMEL
3RD COAT INTERIOR SEMI-GLOSS ENAMEL
C. CONCRETE: 1ST COAT CONCRETE SEALER
2ND COAT PRIMER/FILLER AS REQUIRED
D. WOOD DOORS: 1ST COAT INTERIOR SEMI-GLOSS ENAMEL
2ND COAT PRIMER
E. GYPSUM BOARD: 1ST COAT PRIMER
15D/3RD COAT INTERIOR SEMI-GLOSS ENAMEL

SECTION 10000 - MISCELLANEOUS SPECIALTIES
1.1 SIGNS
A. OWNER SHALL PROVIDE EXTERNAL SIGNAGE AND INSTALLATION. SIGN SUBCONTRACTOR RESPONSIBLE FOR ALL PERMITS AND ZONING ISSUES AS REQUIRED. CONTRACTOR TO COORDINATE LOCATION OF POWER FOR SIGNAGE.
1.2 FIRE EXTINGUISHER
A. GENERAL CONTRACTOR TO PROVIDE SURFACE MOUNTED FIRE EXTINGUISHER (5 LBS. TYPE ABC, MANUFACTURER - KIDD, GRANGER OR EQUAL) MUST HAVE CURRENT INSPECTION TAGS ATTACHED.
SECTION 10801 - TOILET AND BATH ACCESSORIES
1.1 MANUFACTURERS
A. BOBRICK OR APPROVED EQUAL AS APPROVED BY THE SPRINT PROJECT MANAGER. TYPE 304 STAINLESS STEEL, TYPICAL.
1.2 INSTALLATION
A. INSTALL ACCESSORIES TO SUBSTRATES INDICATED AND RECOMMENDED BY THE MANUFACTURER. FASTENERS, LEVEL, PLUMB, AND FIRMLY ANCHORED IN LOCATIONS AND HEIGHTS INDICATED.
B. ADJUST ACCESSORIES FOR UNENCUMBERED, SMOOTH OPERATION AND VERIFY THAT MECHANISMS FUNCTION. PROPERLY REPLACE DAMAGED OR DEFECTIVE ITEMS. REMOVE TEMPORARY LABELS AND PROTECTIVE COATING.
SECTION 12000 - FINISHINGS
1.1 GENERAL
A. CONTRACTOR SHALL COORDINATE THE DELIVERY AND INSTALLATION OF FIXTURES AND OTHER ITEMS SUPPLIED AND INSTALLED BY THE TENANTS VENDORS.
B. CONTRACTOR SHALL ASSEMBLE AND INSTALL FURNISHINGS PROVIDED BY SPRINT.

A	ARCHITECTURAL	FA	FIRE ALARM	N	NORTH
AB	ANCHOR BOLT	FD	FLOOR DRAIN	NEO	NEOPRENE
AC	ACOUSTICAL CEILING	FDN	FOUNDATION	NIC	NOT IN CONTRACT
AFF	ABOVE FINISH FLOOR	FE	FIRE EXTINGUISHER	NOM	NUMBER
ACOUS	ACOUSTICAL	FEC	FIRE EXTINGUISHER	NOM	NOMINAL
ADJ	ADJACENT	FIN	FINISH	NTS	NOT TO SCALE
ADJUSTABLE	ADJUSTABLE	FLR	FLOOR	OC	ON CENTER
ALUM	ALUMINUM	FIXT	FIXTURE	OD	OUTSIDE DIAMETER
ALT	ALTERNATE	FLR	FLOOR	OFF	OFFICE
AP	ACCESS PANEL	FLASH	FLASHING	OPNG	OPENING
APPROX	APPROXIMATE	FLUOR	FLOURESCENT	OPP	OPPOSITE
ARCH	ARCHITECTURAL	FACE	FACE OF CONCRETE	P	PAINT
BD	BOARD	FOF	FACE OF FINISH	PL	PLATE
BLDG	BUILDING	FOS	FACE OF STUDS	P-LAM	PLYWOOD LAMINATE
BLK	BLOCK	FW	FACE OF WALL	PLYW	PLYWOOD
BLKG	BLOCKING	FR	FIRE	PNL	PANEL
BM	BEAM	RATED/RETARDANT	RATED/RETARDANT	PANEL	PANEL BOARD
BO	BOTTOM OF	FRP	FIBERGLASS	PR	PAIR
BOT	BOTTOM	FRP	REINFORCED	PROJ	PROJECT
CAB	CABINET	POLYESTER	POLYESTER	PROP	PROPERTY
CEM	CEMENT	FRTW	FIRE RETARDANT	PWR	POWER
CER	CERAMIC	TREAT	TREATED WOOD	QT	QUANTITY
CG	CORNER GUARD	FT	EDGE FINISH	R	RISER
CJ	CONTROL JOINT	FURR	FURRING	RAD	RADIUS
CL	CLOSET	FR	FIRE	RD	ROOF DRAIN
CLKG	CAULKING	G	GRAVITIC	RE	REFER TO
CLNG	CEILING	GA	GALVANIZED	REFL	REFLECTED
CLR	CLEAR	GALV	GALVANIZED	REINF	REINFORCED
CMU	CONCRETE	GB	GRAB BAR	REQ	REQUIRED
CON	CONCRETE	CONTR	CONTRACTOR	RF	RESILIENT FLOORING
CONC	CONCRETE	G	GLASS	RM	ROOM
CONC	CONCRETE	G	GLASS	RO	ROUGH OPENING
CONC	CONCRETE	G	GLASS	S	SOUTH
CONC	CONCRETE	G	GLASS	SC	SOLID CORE
CONC	CONCRETE	G	GLASS	SCHED	SCHEDULE
CONC	CONCRETE	G	GLASS	SD	SOAP DISPENSER
CORR	CORROSION	HB	HOSE BIBB	SECT	SECTION
CT	CARPET TILE	HC	HANDICAPPED	SF	SQUARE FEET
CTR	CENTER	HD	HEAD	SH	SHELF
CTR	CENTER	HDWD	HARDWOOD	SHT	SHEET
CD	DESIGN CONTROL	HDWR	HARDWARE	SIM	SIMILAR
DET, DTL	DETAIL	HM	HOLLOW METAL	SPEC	SPECIFICATION
DIA	DIAMETER	HORIZ	HORIZONTAL	SQ	SQUARE
DIFF	DIFFUSER	HR	HOUR	SS	STAINLESS STEEL
HT	HEIGHT	HT	HEIGHT	STD	STANDARD
DIM	DIMENSION	HVAC	HEATING	STL	STEEL
DISP	DISPENSER	HVAC	HEATING, VENTILATING,	STOR	STORAGE
DN	DOWN	COND	CONDENSATION	STRUC	STRUCTURAL
DO	DOOR OPENING	ID	INSIDE DIAMETER	SUSP	SUSPENDED
DR	DOOR	IN	INCH	T	TEMPERED
DWG(S)	DRAWING, DRAWINGS	INSUL	INSULATION	T	TILE
DWR	DRAWER	INT	INTERIOR	TEL	TELEPHONE
E	EAST	JAN	JANITOR	TO	TOP OF
E	EAST	JST	JOIST	TT	TOILET TISSUE
E	EAST	JOINT	JOINT	DISP	DISPENSER
EA	EACH	KIT	FIRST AID KIT	TYP	TYPICAL
EXT	EXTERIOR	KP	KICK PLATE	UNO	UNLESS NOTED
EIFS	EXTERIOR FINISH SYSTEM	LAM	LAMINATE	OTHERWISE	OTHERWISE
ELEV	ELEVATION	LV	LAVATORY	VCT	VINYL COMPOSITION TILE
ELEC	ELECTRIC, ELECTRICAL	LT	LIGHT	VERT	VERTICAL
ELEC	ELECTRIC, ELECTRICAL	MACH	MACHINE	VEST	VESTIBULE
ELEC	ELECTRIC, ELECTRICAL	MATL	MATERIAL	W	WEST
ELEV	ELEVATOR	MAX	MAXIMUM	W/O	WITHOUT
EMER	EMERGENCY	MECH	MECHANICAL	WC	WATER CLOSET
ENCL	ENCLOSURE	MEMB	MEMBRANE	WD	WOOD
EQ	EQUAL	MFR	MANUFACTURER	WP	WATERPROOF
EQUIP	EQUIPMENT	MIN	MINIMUM	WT	WEIGHT
EW	ELECTRIC WATER	MR	MIRROR	MISC	MISCELLANEOUS
EXH	EXHAUST	MO	MASONRY OPENING	COOLER	COOLER
EXIST	EXISTING	MTD	MOUNTED	EXHAUST	EXHAUST
EXP	EXPANSION, EXPOSED	MTG	MEETING MOUNTING	EXIST	EXISTING
EXT	EXTERIOR	MTG	MOUNTING	EXP	EXPANSION
		MUL	MULLION	EXT	EXTERIOR

ABBREVIATIONS J01

	WALL TYPE		ELEVATION INDICATOR		NEW WALL
	FURNITURE, FIXTURE OR EQUIPMENT TYPE		DETAIL INDICATOR		EXISTING WALL TO REMAIN
	KEYNOTE		ELEVATION TAG		EXISTING WALL TO BE REMOVED
	INTERIOR SECTION NUMBER SHEET NUMBER		INTERIOR ELEVATION NUMBER SHEET NUMBER	101	DOOR NUMBER
	WINDOW TYPE		INTERIOR ELEVATION NUMBER SHEET NUMBER		NEW DOOR
	SPECIALTY TYPE		DETAIL NUMBER SHEET NUMBER		EXISTING DOOR TO REMAIN
	REVISION NUMBER		EXTERIOR ELEVATION NUMBER SHEET NUMBER		EXISTING DOOR TO BE REMOVED
	ROOM NAME AND NUMBER		NORTH ARROW		
	BREAK LINE				
	CENTER LINE				
	COLUMN NUMBER				
	STAIR DIRECTION INDICATOR				

SYMBOLS LEGEND A01

design-form
engineering
Cert./License # 23005532
700 W. Pease Road West, Suite 460 Cincinnati, OH 45203 Telephone: (513) 421-2210
Timothy L. Rabarding, PE

Sprint
#1287 PINELLAS PARK FL
5001 PARK BLVD
PINELLAS PARK, FL 33781

MARK DATE DESCRIPTION
SHEET TITLE
SPECIFICATIONS

PROJECT NUMBER: SPR1287
SHEET AUTHOR: CHAD GLEASON
CHECKED BY:
DATE: SEPTEMBER 28, 2017
SHEET: **A03**