



REFLECTED CEILING PLAN L01

Order Plans

- CEILING TYPE
 CEILING HEIGHT ABOVE FINISHED FLOOR
 CLG-1 24" x 48" LAY-IN CEILING, STANDARD COMMERCIAL GRADE ACoustical TILE
 LAY-IN TILE GRID: STANDARD COMMERCIAL GRADE 15/16" CEILING GRID
 LOCATION: REFER TO REFLECTED CEILING PLAN
 FIRE RATING: MEETS PER: ASTM E84, BS476 PARTS 6 & 7, DIN 4102, NFP 92-501 & NFP 92-510
 COLOR: WHITE 010
- CLG-2 24" x 48" LAY-IN CEILING, ARMSTRONG, SERIES: DUNE 1776, ANGLED TEGULAR, WHITE
 LAY-IN TILE GRID: ARMSTRONG, SERIES: PRELUDE ML 15/16" EXPOSED TEE, WHITE
 LOCATION: REFER TO REFLECTED CEILING PLAN
 FIRE RATING: MEETS PER: ASTM E84, BS476 PARTS 6 & 7, DIN 4102, NFP 92-501 & NFP 92-510

SYMBOL	MARK	DESCRIPTION
	C	7" VERTICAL COMPACT FLUORESCENT
	CE	7" VERTICAL COMPACT FLUORESCENT WITH EMERGENCY BATTERY PACK
	EX1	WALL MOUNTED EXIT LIGHT PER CODE
	H	2X4 LED FLAT PANEL LIGHTING
	HE	2X4 LED FLAT PANEL LIGHTING WITH EMERGENCY BATTERY PACK
		CEILING-MOUNTED WIRELESS ACCESS POINT (MODEL 205) BY SPRINT VENDOR. RE: KEY NOTE 7
		CEILING-MOUNTED WIRELESS ACCESS POINT (MODEL 225) BY SPRINT VENDOR. RE: KEY NOTE 7
		CEILING-MOUNTED DATA BOX
		OPEN-ENDED DATA CABLE ABOVE CEILING
		CEILING-MOUNTED DUPLEX OUTLET
		JUNCTION BOX ABOVE CEILING

1. CONNECT EMERGENCY LIGHTS, EXIT SIGNS, AND NIGHT LIGHTS TO A CONSTANT HOT PHASE CONDUCTOR, DO NOT SWITCH.
2. ALL LIGHTS AND OTHER CEILING MOUNTED ITEMS TO BE CENTERED IN GRID UNLESS NOTED OTHERWISE.
3. COORDINATE INSTALLATION OF ALL SECURITY CAMERAS AND MONITORING SYSTEMS WITH SPRINT PM.

1. PROVIDE ACCESSIBLE JUNCTION BOX FOR EXTERIOR SIGNAGE RE: ELECTRICAL.
2. PROVIDE EMERGENCY EXIT SIGNS AS REQUIRED BY CODE. RE: ELECTRICAL.
3. PROVIDE OUTLET FLUSH-MOUNTED IN CEILING. OUTLET AND COVER TO BE WHITE.
4. NIGHT LIGHTS TO REMAIN ON 24/7 - DO NOT SWITCH.
5. [Symbol]
6. CABLE VENDOR TO PROVIDE PLENUM RATED CAT 5e CABLE LABELED "SHOPPERTRAK" AT LAN RACK END. RUN CABLE ABOVE CEILING FROM DATA RACK TO PLENUM ABOVE FRONT DOOR. TIE OFF ADDITIONAL 15' OF CABLE AT APPROXIMATE "SHOPPERTRAK" LOCATION SHOWN. VERIFY ROUTE AND LOCATION WITH GC. SUPPORT CABLE FROM STRUCTURE USING APPROVED HANGERS - DO NOT LAY ON CEILING TILE.
7. CABLE VENDOR TO PROVIDE PLENUM RATED CAT 5e CABLE FOR CONNECTION TO WIRELESS DEVICE. RUN CABLE ABOVE CEILING FROM DATA RACK TO A JUNCTION BOX IN PLENUM AT LOCATIONS SHOWN. VERIFY ROUTE AND LOCATION WITH GC. SUPPORT CABLE FROM STRUCTURE USING APPROVED HANGERS - DO NOT LAY ON CEILING TILE.
8. PAINT EXPOSED GYP BOARD SOFFITS/HEADERS P-2.
9. PROVIDE ACCESSIBLE JUNCTION BOX ABOVE CEILING FOR FIXTURE POWER. RE: ELECTRICAL.
10. START CEILING GRID AT THIS POINT OFF CENTERLINE OF STORE AND/OR EDGE OF EXISTING WALL.
11. POWER AND DATA OUTLET IN CEILING FOR NSC DEVICE. RE: ELECTRICAL. CABLE VENDOR TO PROVIDE PLENUM RATED CAT 5e CABLE FOR CONNECTION TO DEVICE. RUN CABLE ABOVE CEILING FROM DATA RACK TO A CEILING MOUNTED DATA OUTLET. VERIFY ROUTE AND LOCATION WITH GC. SUPPORT CABLE FROM STRUCTURE USING APPROVED HANGERS - DO NOT LAY ON CEILING TILE.

NOT USED A23

CEILING FINISH SCHEDULE A16

CEILING PLAN LEGEND A08

CEILING PLAN KEY NOTES A01

design-forum.
architect, inc.

700 W. Erie-Rose Way, Suite 460 Cincinnati, OH 45203 Telephone: (513) 421-2210
Donald J. Reihman, Architect In Charge 7785

Sprint

#1408 DURHAM

2707 GUESS RD, SUITE 110
DURHAM, NC 27705

DATE	DESCRIPTION

SHEET TITLE
REFLECTED CEILING PLAN

PROJECT NUMBER
SPR1408

SHEET AUTHOR
CHAD OLESON

DATE
SEPTEMBER 26, 2017

SHEET
A12