

406 - CURB RAMPS, CONTINUED

SECTION 406.5 - LOCATION
CURB RAMPS AND THE RAMP SIDES OF CURB RAMPS SHALL BE LOCATED SO THAT THEY DO NOT PROJECT INTO VEHICULAR TRAFFIC LANE...

SECTION 410 - PLATFORM LIFTS
GENERAL PLATFORM LIFTS SHALL COMPLY WITH ASME A18.1 [1999 EDITION OR 2003] INCORPORATE BY REFERENCE, SEE REFERENCES STANDARD IN CHAPTER 1...

502-503 - PARKING AND PASSENGER LOADING ZONES

SECTION 502.2 - VEHICLES SPACES
CAR PARKING SPACES SHALL BE 9' WIDE MIN. AND VAN PARKING SPACES SHALL BE 13'2" WIDE MIN. SHALL BE MARKED TO DEFINE THE WORK AND SHALL HAVE ADJACENT ACCESSIBLE SPACES...

504 - STAIRS

SECTION 504.2 - TREADS AND RISERS
ALL STEPS ON A FLIGHT OF STAIRS SHALL HAVE UNIFORM RISE HEIGHTS AND UNIFORM TREAD DEPTHS. RISERS SHALL BE 4" HIGH MIN. AND 7" HIGH MAX. TREADS SHALL BE 11" DEEP MIN.

505 - HANDRAILS

SECTION 505.1 - GENERAL
HANDRAILS PROVIDED ALONG WALKING SURFACES COMPLYING WITH 403, REQUIRED AT RAMPS COMPLYING WITH 405, AND REQUIRED AISLS COMPLYING WITH 504 SHALL COMPLY WITH 505.

602 - DRINKING FOUNTAINS

SECTION 602.2 CLEAR FLOOR SPACE
UNITS SHALL HAVE A CLEAR FLOOR OR GROUND SPACE COMPLYING WITH 305 POSITIONED FOR A FORWARD APPROACH AND CENTERED ON THE UNIT. KNEE AND TOE CLEARANCE COMPLYING WITH 305 SHALL BE PROVIDED.

603 - TOILET AND BATHING ROOMS

SECTION 603.2.1. TURNING SPACE
TURNING SPACE COMPLYING WITH 305 SHALL BE PROVIDED WITHIN THE ROOM.

603 - TOILET AND BATHING ROOMS, CONTINUED

SECTION 603.1 - MIRRORS
MIRRORS LOCATED ABOVE LAVATORIES OR COUNTERTOPS SHALL BE INSTALLED WITH THE BOTTOM EDGE OF THE REFLECTIVE SURFACE 42" MAX. ABOVE THE FINISH FLOOR OR GROUND...

604 - WATER CLOSETS AND TOILET COMPARTMENTS

SECTION 604.2 - LOCATION
THE WATER CLOSET SHALL BE POSITIONED WITH A WALL OR PARTITION TO THE REAR AND THE ONE SIDE. THE CENTERLINE OF THE WATER CLOSET SHALL BE 16" MIN. TO 18" MAX. FROM THE SIDE OF WALL OR PARTITION...

604.3 - CLEARANCE

SECTION 604.3.1 - SIZE
CLEARANCE AROUND A WATER CLOSET SHALL BE 60" MIN. MEASURED PERPENDICULAR FROM THE SIDE WALL AND 56" MIN. MEASURED PERPENDICULAR FROM THE REAR WALL.

604.4 - SEATS

SECTION 604.4.1 - GRAB BARS - SIDE WALL
THE SIDE WALL GRAB BAR SHALL BE 42" LONG MIN. LOCATED 12" MAX. FROM THE REAR WALL AND EXTENDING 54", MINIMUM FROM THE REAR WALL.

604.5 - FLUSH CONTROLS

SECTION 604.5.1 - GENERAL
FLUSH CONTROLS SHALL BE HAND OPERATED OR AUTOMATIC. HAND OPERATED FLUSH CONTROLS SHALL COMPLY WITH 309. FLUSH CONTROLS SHALL BE LOCATED ON THE OPEN SIDE OF THE WATER CLOSET EXCEPT IN AMBULATORY ACCESSIBLE COMPARTMENTS...

604.6 - DISPENSERS

SECTION 604.6.1 - SIZE
WHEELCHAIR ACCESSIBLE COMPARTMENTS SHALL BE 60" WIDE MIN. MEASURED PERPENDICULAR TO THE SIDE WALL, AND 36" DEEP MINIMUM FOR WALL-HUNG WATER CLOSETS...

604.7 - TOILET COMPARTMENTS

SECTION 604.7.1 - SIZE
WHEELCHAIR ACCESSIBLE COMPARTMENTS SHALL BE 60" WIDE MIN. MEASURED PERPENDICULAR TO THE SIDE WALL, AND 36" DEEP MINIMUM FOR WALL-HUNG WATER CLOSETS...

604.8 - TOILET COMPARTMENTS

SECTION 604.8.1.1 - SIZE
WHEELCHAIR ACCESSIBLE COMPARTMENTS SHALL BE 60" WIDE MIN. MEASURED PERPENDICULAR TO THE SIDE WALL, AND 36" DEEP MINIMUM FOR WALL-HUNG WATER CLOSETS...

604.8.1.2 - DOORS

SECTION 604.8.1.2 - DOORS
TOILET COMPARTMENTS DOORS, INCLUDING DOOR HARDWARE, SHALL COMPLY WITH 404 EXCEPT THAT IF THE APPROACH IS TO THE LATCH SIDE OF THE COMPARTMENT DOOR, CLEARANCE BETWEEN THE DOOR SIDE OF THE COMPARTMENT AND ANY OBSTRUCTION SHALL BE 42" MIN. DOORS SHALL BE LOCATED IN THE FRONT PARTITION...

604.8.1.3 - TOE CLEARANCE

SECTION 604.8.1.3 - TOE CLEARANCE
THE FRONT PARTITION ON AND AT LEAST ONE SIDE PARTITION SHALL PROVIDE A TOE CLEARANCE OF 9" MIN. ABOVE THE FINISH FLOOR AND 4" DEEP MIN. BEYOND THE COMPARTMENT SIDE FACE OF THE PARTITION...

604.8.2.1 - SIZE

SECTION 604.8.2.1 - SIZE
AMBULATORY ACCESSIBLE COMPARTMENTS SHALL HAVE A DEPTH OF 60" MIN. AND A WIDTH OF 36" MIN. AND 37" MAX.

604.8.2.2 - DOORS

SECTION 604.8.2.2 - DOORS
TOILET COMPARTMENT DOORS, INCLUDING DOOR HARDWARE, SHALL COMPLY WITH 404 EXCEPT THAT IF THE APPROACH IS TO THE LATCH SIDE OF THE COMPARTMENT DOOR, CLEARANCE BETWEEN THE DOOR SIDE OF THE COMPARTMENT AND ANY OBSTRUCTION SHALL BE 42" MIN. DOORS SHALL BE LOCATED IN THE FRONT PARTITION...

604.8.3.1 - COAT HOOKS AND SHELVES

SECTION 604.8.3.1 - COAT HOOKS AND SHELVES
COAT HOOKS SHALL BE LOCATED WITHIN ONE OF THE REACH RANGES SPECIFIED IN 308. SHELVES SHALL BE LOCATED 42" MIN. AND 48" MAX. ABOVE THE FINISH FLOOR.

604 - WATER CLOSETS AND TOILET COMPARTMENTS, CONTINUED

SECTION 604.1.3 - TOE CLEARANCE
THE FRONT PARTITION ON AND AT LEAST ONE SIDE PARTITION SHALL PROVIDE A TOE CLEARANCE OF 9" MIN. ABOVE THE FINISH FLOOR AND 4" DEEP MIN. BEYOND THE COMPARTMENT SIDE FACE OF THE PARTITION...

604.2.1 - SIZE

SECTION 604.2.1 - SIZE
AMBULATORY ACCESSIBLE COMPARTMENTS SHALL HAVE A DEPTH OF 60" MIN. AND A WIDTH OF 36" MIN. AND 37" MAX.

604.2.2 - DOORS

SECTION 604.2.2 - DOORS
TOILET COMPARTMENT DOORS, INCLUDING DOOR HARDWARE, SHALL COMPLY WITH 404 EXCEPT THAT IF THE APPROACH IS TO THE LATCH SIDE OF THE COMPARTMENT DOOR, CLEARANCE BETWEEN THE DOOR SIDE OF THE COMPARTMENT AND ANY OBSTRUCTION SHALL BE 42" MIN. DOORS SHALL BE LOCATED IN THE FRONT PARTITION...

604.3.1 - COAT HOOKS AND SHELVES

SECTION 604.3.1 - COAT HOOKS AND SHELVES
COAT HOOKS SHALL BE LOCATED WITHIN ONE OF THE REACH RANGES SPECIFIED IN 308. SHELVES SHALL BE LOCATED 42" MIN. AND 48" MAX. ABOVE THE FINISH FLOOR.

605 - URINALS

SECTION 605.2 - HEIGHT AND DEPTH
URINALS SHALL BE STALL-TYPE OR WALL-HUNG WITH THE RIM AT 17" MAXIMUM ABOVE THE FINISHED FLOOR OR GROUND SURFACE. URINALS SHALL BE 13 1/2" DEEP MIN. MEASURED FROM THE OUTER FACE OF THE URINAL RIM TO THE BACK OF THE RIM.

605.3 - CLEAR FLOOR SPACE

SECTION 605.3 - CLEAR FLOOR SPACE
A CLEAR FLOOR OR GROUND SPACE, INCLUDING THE PARTITION POSITIONED FOR FORWARD APPROACH SHALL BE PROVIDED.

605.4 - FLUSH CONTROLS

SECTION 605.4 - FLUSH CONTROLS
FLUSH CONTROLS SHALL BE HAND OPERATED OR AUTOMATIC. HAND OPERATED FLUSH CONTROLS SHALL COMPLY WITH 309.

606 - LAVATORIES & SINKS

SECTION 606.2 - CLEAR FLOOR SPACE
A CLEAR FLOOR SPACE COMPLYING WITH 305, POSITION FOR A FORWARD APPROACH, AND KNEE AND TOE CLEARANCE COMPLYING WITH 306 SHALL BE PROVIDED.

606.3 - HEIGHT

SECTION 606.3 - HEIGHT
LAVATORIES AND SINKS SHALL BE INSTALLED WITH THE FRONT OF THE HIGHER OF THE RIM OR COUNTER SURFACE 34" MAX. ABOVE THE FINISH FLOOR OR GROUND.

606.4 - FAUCETS

SECTION 606.4 - FAUCETS
CONTROLS FOR FAUCETS SHALL COMPLY WITH 309. HAND OPERATED METERING FAUCETS SHALL REMAIN OPEN FOR 10 SECONDS MIN.

606.5 - EXPOSED PIPES AND SURFACES

SECTION 606.5 - EXPOSED PIPES AND SURFACES
WATER SUPPLY AND DRAIN PIPES UNDER LAVATORIES AND SINKS SHALL BE INSULATED OR OTHERWISE CONFIGURED TO PROTECT AGAINST CONTACT. THERE SHALL BE NO SHARP OR ABRASIVE SURFACES UNDER THE LAVATORIES AND SINKS.

609 - GRAB BARS

SECTION 609.2 - CROSS SECTION
GRAB BARS SHALL HAVE A CROSS SECTION COMPLYING WITH 609.2.1 OR 609.2.2.

609.2.1 - CIRCULAR CROSS SECTION

SECTION 609.2.1 - CIRCULAR CROSS SECTION
GRAB BARS WITH CIRCULAR CROSS SECTIONS SHALL HAVE AN OUTSIDE DIAMETER OF 1 1/4" MINIMUM AND 2" MAX.

609.2.2 - NON-CIRCULAR CROSS SECTION

SECTION 609.2.2 - NON-CIRCULAR CROSS SECTION
GRAB BARS WITH NON-CIRCULAR CROSS SECTIONS SHALL HAVE A CROSS SECTION DIMENSIONS OF 2" MAX. AND A PERIMETER DIMENSION OF 4" MIN. AND 4 1/2" MAX.

609 - GRAB BARS, CONTINUED

SECTION 609.3 - SPACING
THE SPACE BETWEEN THE WALL AND THE GRAB BAR SHALL BE 1 1/2". THE SPACE BETWEEN THE GRAB BAR AND THE PROJECTING OBJECTS BELOW AND AT THE FOOT SHALL BE 1 1/2" MIN. THE SPACE BETWEEN THE GRAB BAR AND THE PROJECTING OBJECTS ABOVE SHALL BE 12" MIN.

609.4 - POSITION OF GRAB BARS

SECTION 609.4 - POSITION OF GRAB BARS
GRAB BARS SHALL BE INSTALLED IN A HORIZONTAL POSITION 33" MIN. AND 36" MAX. ABOVE THE FINISH FLOOR MEASURED TO THE TOP OF THE GRIPPING SURFACE EXCEPT THAT AT WATER CLOSETS FOR CHILDREN'S USE COMPLYING 604.8, GRAB BARS SHALL BE INSTALLED IN A HORIZONTAL POSITION 18" MIN. AND 27" MAX. ABOVE THE FINISH FLOOR MEASURED TO THE TOP OF THE GRIPPING SURFACE...

609.5 - SURFACE HAZARDS

SECTION 609.5 - SURFACE HAZARDS
GRAB BARS AND ANY WALL OR OTHER SURFACES ADJACENT TO GRAB BARS SHALL BE FREE OF SHARP OR ABRASIVE ELEMENTS AND SHALL HAVE ROUNDED EDGES.

609.6 - FITTINGS

SECTION 609.6 - FITTINGS
GRAB BARS SHALL NOT ROTATE WITH THEIR FITTINGS.

609.7 - INSTALLATION

SECTION 609.7 - INSTALLATION
GRAB BARS SHALL BE INSTALLED IN ANY MANNER THAT PROVIDES A GRIPPING SURFACE AT THE INSTALLED LOCATIONS AND DOES NOT OBSTRUCT THE REQUIRED CLEAR FLOOR SPACE.

609.8 - STRUCTURAL STRENGTH

SECTION 609.8 - STRUCTURAL STRENGTH
ALLOWABLE STRESSES SHALL NOT BE EXCEEDED FOR MATERIALS USED IN VERTICAL OR HORIZONTAL POSITIONS. LOADS OF 250 POUNDS IS APPLIED AT ANY POINT ON THE GRAB BAR, FASTENER, MOUNTING DEVICE, OR SUPPORTING STRUCTURE.

702 - FIRE ALARM SYSTEMS

SECTION 702.1 - GENERAL
FIRE ALARM SYSTEMS SHALL HAVE PERMANENTLY INSTALLED AUDIBLE AND VISUAL ALARMS WITH TYPED 11999 or 2002 EXCEPT INCORPORATED BY REFERENCE TO REFERENCES STANDARD IN CHAPTER 1...

703 - SIGNS

703.1 - GENERAL

SECTION 703.1 - GENERAL
SIGNS SHALL COMPLY WITH 703. WHERE BOTH VISUAL AND TACTILE CHARACTERS ARE REQUIRED, EITHER ONE SIGN WITH BOTH VISUAL AND TACTILE CHARACTERS, OR TWO SEPARATE SIGNS, ONE WITH VISUAL AND ONE WITH TACTILE CHARACTERS, SHALL BE PROVIDED.

703.2 - RAISED CHARACTERS

SECTION 703.2 - RAISED CHARACTERS
RAISED CHARACTERS SHALL COMPLY WITH 703.2 AND SHALL BE DUPLICATED IN BRAILLE COMPLYING WITH 703.3. RAISED CHARACTERS SHALL BE INSTALLED IN ACCORDANCE WITH 703.4.

703.2.1 - DEPTH

SECTION 703.2.1 - DEPTH
RAISED CHARACTERS SHALL BE 1/32" MIN. ABOVE THE BACKGROUND.

703.2.2 - CASE

SECTION 703.2.2 - CASE
CHARACTERS SHALL BE UPPERCASE.

703.2.3 - STYLE

SECTION 703.2.3 - STYLE
CHARACTERS SHALL BE SANS SERIF. CHARACTERS SHALL NOT BE TALIC, OBLIQUE, SCRIPT, HIGHLY DECORATIVE, OR OF OTHER UNUSUAL FORMS.

703.2.4 - CHARACTER PROPORTIONS

SECTION 703.2.4 - CHARACTER PROPORTIONS
CHARACTERS SHALL BE SELECTED FROM FONTS WHERE THE WIDTH OF THE UPPERCASE LETTER 'O' IS 55 PERCENT MIN. AND 110 PERCENT MAX. OF THE HEIGHT OF THE UPPERCASE LETTER 'T'.

703.2.5 - CHARACTER HEIGHT

SECTION 703.2.5 - CHARACTER HEIGHT
CHARACTER HEIGHT MEASURED VERTICALLY FROM THE BASELINE OF THE CHARACTER SHALL BE 5/8" MIN. AND 2" MAX. BASED ON THE HEIGHT OF THE UPPERCASE LETTER 'T'.

703.2.6 - STROKE THICKNESS

SECTION 703.2.6 - STROKE THICKNESS
STROKE THICKNESS OF THE UPPERCASE LETTER 'T' SHALL BE 15 PERCENT MAX. OF THE HEIGHT OF THE CHARACTER.

703.2.7 - CHARACTER SPACING

SECTION 703.2.7 - CHARACTER SPACING
CHARACTER SPACING SHALL BE MEASURED BETWEEN THE TWO CLOSEST POINTS OF ADJACENT RAISED CHARACTERS WITHIN A MESSAGE EXCLUDING WORD SPACES. WHERE CHARACTERS HAVE RECTANGULAR CROSS SECTIONS, SPACING BETWEEN INDIVIDUAL RAISED CHARACTERS SHALL BE 1/8" MINIMUM AND 4 TIMES THE RAISED CHARACTER STROKE WIDTH MAXIMUM. WHERE CHARACTERS HAVE OTHER CROSS SECTIONS, SPACING BETWEEN INDIVIDUAL RAISED CHARACTERS SHALL BE 1/4" MIN. AND 4 TIMES THE RAISED CHARACTER STROKE WIDTH MAXIMUM AT THE BASE OF THE CROSS SECTIONS, AND 1/8" MIN. AND 4 TIMES THE RAISED CHARACTER STROKE WIDTH MAX. AT THE TOP OF THE CROSS SECTIONS. CHARACTERS SHALL BE SEPARATED FROM RAISED BORDERS AND DECORATIVE ELEMENTS 3/4" MIN.

703.2.8 - LINE SPACING

SECTION 703.2.8 - LINE SPACING
SPACING BETWEEN THE BASELINES OF SEPARATE LINES OF RAISED CHARACTERS WITHIN A MESSAGE SHALL BE 135 PERCENT MIN. AND 170 PERCENT MAX. OF THE RAISED CHARACTER HEIGHT.

703 - SIGNS, CONTINUED

SECTION 703.4.2 - LOCATION
WHERE A TACTILE SIGN IS PROVIDED AT A DOOR, THE SIGN SHALL BE LOCATED ALONGSIDE THE DOOR AT THE LATCH SIDE. WHERE A TACTILE SIGN IS PROVIDED AT A DOUBLE DOOR WITH ONE ACTIVE LEAF, THE SIGN SHALL BE LOCATED ON THE INACTIVE LEAF. WHERE A TACTILE SIGN IS PROVIDED AT A DOUBLE DOOR WITH TWO ACTIVE LEAFS, THE SIGN SHALL BE LOCATED TO THE RIGHT OF DOUBLE DOORS, WHERE THERE IS NO WALL SPACE AT THE LATCH SIDE OF A SINGLE DOOR OR AT THE RIGHT SIDE OF DOUBLE DOORS. SIGNS SHALL BE LOCATED ON THE NEAREST ADJACENT WALL SIGNS CONTAINING TACTILE CHARACTERS SHALL BE LOCATED TO A CLEAR FLOOR SPACE OF 48" WIDE BY 18" MIN. CENTERED ON THE TACTILE CHARACTER, IS PROVIDED BEYOND THE ARC OF ANY DOOR SWING BETWEEN THE CLOSED POSITION AND 45 DEGREE OPEN POSITION.

703.5 - VISUAL CHARACTERS

SECTION 703.5.1 - FINISH AND CONTRAST
CHARACTERS SHALL BE SET AGAINST A BACKGROUND OF A CONTRAST WITH THEIR BACKGROUND WITH EITHER LIGHT OR DARK BACKGROUND. CHARACTERS ON A LIGHT BACKGROUND SHALL BE DARK. CHARACTERS ON A DARK BACKGROUND SHALL BE LIGHT.

703.5.2 - HEIGHT FROM FINISH FLOOR OR GROUND

SECTION 703.5.2 - HEIGHT FROM FINISH FLOOR OR GROUND
VISUAL CHARACTERS SHALL BE 48" MINIMUM ABOVE THE FINISH FLOOR OR GROUND.

703.5.3 - CASE

SECTION 703.5.3 - CASE
CHARACTERS SHALL BE UPPERCASE. CHARACTERS ON A COMBINATION OF BOTH VISUAL AND TACTILE CHARACTERS SHALL BE UPPERCASE.

703.5.4 - STYLE

SECTION 703.5.4 - STYLE
CHARACTERS SHALL BE SANS SERIF. CHARACTERS SHALL NOT BE TALIC, OBLIQUE, SCRIPT, HIGHLY DECORATIVE, OR OF OTHER UNUSUAL FORMS.

703.6 - PICTOGRAMS

703.6.1 - PICTOGRAMS FIELD

SECTION 703.6.1 - PICTOGRAMS FIELD
PICTOGRAMS SHALL HAVE A FIELD HEIGHT OF 6" MINIMUM. CHARACTERS AND SIGNS SHALL NOT BE LOCATED IN THE PICTOGRAM FIELD.

703.6.2 - FINISH AND CONTRAST

SECTION 703.6.2 - FINISH AND CONTRAST
PICTOGRAMS SHALL HAVE A FINISH AND CONTRAST WITH THEIR FIELD WITH EITHER A LIGHT PICTOGRAM ON A DARK FIELD OR A DARK PICTOGRAM ON A LIGHT FIELD.

703.6.3 - FINISH AND CONTRAST

SECTION 703.6.3 - FINISH AND CONTRAST
PICTOGRAMS SHALL HAVE TEXT DESCRIPTIONS LOCATED DIRECTLY BELOW THE PICTOGRAM FIELD. TEXT DESCRIPTIONS SHALL COMPLY WITH 703.2, 703.3, 703.4.

703.7 - SYMBOLS OF ACCESSIBILITY

703.7.1 - FINISH AND CONTRAST

SECTION 703.7.1 - FINISH AND CONTRAST
SYMBOLS OF ACCESSIBILITY AND THEIR BACKGROUND SHALL HAVE A NON-GLARE FINISH. SYMBOLS OF ACCESSIBILITY SHALL CONTRAST WITH THEIR BACKGROUND WITH EITHER A LIGHT SYMBOL ON A DARK BACKGROUND OR A DARK SYMBOL ON A LIGHT BACKGROUND.

703.7.2 - SYMBOLS

SECTION 703.7.2 - SYMBOLS
THE INTERNATIONAL SYMBOL OF ACCESSIBILITY SHALL COMPLY WITH FIGURE 703.7.2.1.

703.7.2.1 - INTERNATIONAL SYMBOL OF ACCESSIBILITY

SECTION 703.7.2.1 - INTERNATIONAL SYMBOL OF ACCESSIBILITY
THE INTERNATIONAL SYMBOL OF ACCESSIBILITY SHALL COMPLY WITH FIGURE 703.7.2.1.

902 - DINING SURFACES AND WORK SURFACES

902.2 - CLEAR FLOOR OR GROUND SPACE

SECTION 902.2 - CLEAR FLOOR OR GROUND SPACE
A CLEAR FLOOR SPACE COMPLYING WITH 305 POSITIONED FOR A FORWARD APPROACH SHALL BE PROVIDED. KNEE AND TOE CLEARANCE COMPLYING WITH 306 SHALL BE PROVIDED.

902.3 - HEIGHT

SECTION 902.3 - HEIGHT
THE TOPS OF DINING SURFACE AND WORK SURFACES SHALL BE 28" MIN. AND 34" MAX. ABOVE THE FINISH FLOOR OR GROUND.

902.4 - INSTALLATION HEIGHT AND LOCATION

SECTION 902.4 - INSTALLATION HEIGHT AND LOCATION
TACTILE CHARACTERS ON SIGNS SHALL BE LOCATED 48" MIN. ABOVE THE FINISH FLOOR OR GROUND SURFACE. MEASURED FROM THE BASELINE OF THE LOWEST TACTILE CHARACTER AND 40" MAX. ABOVE THE FINISH FLOOR OR GROUND SURFACE. MEASURED FROM THE BASELINE OF THE HIGHEST TACTILE CHARACTER.

902.5 - EXPOSED PIPES AND SURFACES

SECTION 902.5 - EXPOSED PIPES AND SURFACES
WATER SUPPLY AND DRAIN PIPES UNDER LAVATORIES AND SINKS SHALL BE INSULATED OR OTHERWISE CONFIGURED TO PROTECT AGAINST CONTACT. THERE SHALL BE NO SHARP OR ABRASIVE SURFACES UNDER THE LAVATORIES AND SINKS.

902.6 - CROSS SECTION

SECTION 902.6 - CROSS SECTION
GRAB BARS SHALL HAVE A CROSS SECTION COMPLYING WITH 609.2.1 OR 609.2.2.

902.7 - CIRCULAR CROSS SECTION

SECTION 902.7 - CIRCULAR CROSS SECTION
GRAB BARS WITH CIRCULAR CROSS SECTIONS SHALL HAVE AN OUTSIDE DIAMETER OF 1 1/4" MINIMUM AND 2" MAX.

902.8 - NON-CIRCULAR CROSS SECTION


SECTION 902.8 - NON-CIRCULAR CROSS SECTION
GRAB BARS WITH NON-CIRCULAR CROSS SECTIONS SHALL HAVE A CROSS SECTION DIMENSIONS OF 2" MAX. AND A PERIMETER DIMENSION OF 4" MIN. AND 4 1/2" MAX.

Table with columns: NO., DATE, DRAWN BY, CHECKED BY, REVISION, etc.



PREMIER HOLDINGS OF GEORGIA, LLC
3836 Stewart Road, Unit A
Doraville, GA 30046

2126 Morris Avenue
James M. Buckstein
Architect AIA



PROJECT #170201.4
IMAGE 09/09 - JULY 2012 STANDARDS

BURGER KING
544 W PINE ST
LAWRENCEVILLE, GA 30045

ADA GUIDELINES

T1.4