

Order Plans

GENERAL NOTES

DIVISION NOTES:

A. DIVISION 1 - GENERAL REQUIREMENTS:

1.01. COMPLETE CONTRACT DOCUMENTS: THE COMPLETE DRAWINGS, SPECIFICATIONS, ADDENDA, AND CLARIFICATIONS ISSUED BY FIELD ORDER OF SIMILAR INSTRUMENTS CONSTITUTE THE CONTRACT DOCUMENTS AND SHALL REMAIN INTACT. THE GENERAL CONTRACTOR IS FULLY RESPONSIBLE FOR COMPLIANCE WITH THE REQUIREMENTS INCLUDED, OR REASONABLE INFERRED THEREON. THE CONSTRUCTION MANAGER OR GENERAL CONTRACTOR AS APPLICABLE MUST NOT ISSUE FIELD ORDERS OR OTHERWISE CAUSE INCOMPLETE CONTRACT INFORMATION TO BE PROVIDED TO PARTIES TO THE CONTRACT, INCLUDING ASSOCIATED SUB-CONTRACTORS, OR SUB-SUB-CONTRACTORS. 1.02. MULTI-TRADE COORDINATION: ALL WORK SHALL BE COORDINATED WITH THE WORK OF OTHER TRADES TO AVOID INTERFERENCES AND CONFLICTS. SUB-CONTRACTORS SHALL WORK TOGETHER IN THE REVIEW OF WORK AND COORDINATION OF SYSTEMS IN PLenum AREAS, AND OTHER LOCATIONS WHERE CAREFUL COORDINATION IS NECESSARY TO EXECUTE THE WORK IN LIMITED SPACES. NO ALLOWANCES WILL BE MADE FOR THE FAILURE TO COORDINATE BETWEEN DISCIPLINES, SYSTEMS OR EQUIPMENT. UNCOORDINATED WORK THAT RESULTS IN THE INEFFICIENT USE OF AVAILABLE SPACE MAY BE SUBJECT TO REJECTION OF INSTALLED WORK. WHERE COMPLEXITY OF THE INSTALLED WORK OR WHERE WORK INSTALLED IN COMPACT SPACES NECESSITATES CAREFUL COORDINATION FOR SUCCESSFUL INSTALLATION, THE GENERAL CONTRACTOR IS STRONGLY ENCOURAGED TO UNDERTAKE A SYSTEMS COORDINATION PROGRAM THAT INCLUDES THREE-DIMENSIONAL MODELING OF THE REQUIRED WORK PRIOR TO INSTALLATION, WHETHER OR NOT REQUIRED ELSEWHERE BY THE CONTRACT DOCUMENTS. 1.03. VERIFICATION: THE GENERAL CONTRACTOR SHALL FIELD VERIFY ALL EXISTING CONDITIONS, CONSTRUCTION, MATERIALS, METHODS OF CONSTRUCTION, GRADES AND ELEVATIONS, AND NOTIFY THE ARCHITECT OF ANY DISCREPANCIES OR CONFLICTS WITH THE DOCUMENTS PRIOR TO BID, CONSTRUCTION, AND/OR INSTALLATION OF ASSOCIATED WORK. COMMENCEMENT OF WORK CONSTITUTES ACCEPTANCE THAT THE EXISTING CONDITIONS ARE CONSISTENT WITH THOSE OF THE CONTRACT DOCUMENTS. ANY CHANGE ORDER REQUEST ASSOCIATED WITH AN IDENTIFIABLE EXISTING CONDITION, WHETHER IN CONFLICT OR COMPLIANCE WITH THE CONTRACT DOCUMENTS, WILL NOT BE ACCEPTED. THIS PROVISION SHALL NOT APPLY TO WORK PERFORMED UNDER PRICE OR ALLOWANCE FEE STRUCTURES. 1.04. DISCREPANCIES: THE GENERAL CONTRACTOR SHALL NOTIFY THE ARCHITECT PROMPTLY UPON IDENTIFICATION OF ANY DISCREPANCIES OR CONFLICTS IN THE CONTRACT DOCUMENTS, WITH THE OBJECTIVE OF RESOLVING THE CONFLICT OR DISCREPANCY IN A TIMELY MANNER AND PRIOR TO ANY IMPACT TO THE CONTRACT TIME OR PRICE. THE GENERAL CONTRACTOR SHALL INCLUDE THE MORE EXPENSIVE, COMPLEX, AND TIME CONSUMING COMPONENTS OF ANY DISCREPANCIES IN THE BASE BID PRICE. FAILURE TO NOTIFY THE ARCHITECT PROMPTLY OF A KNOWN DISCREPANCY CONSTITUTES ACCEPTANCE OF FULL RESPONSIBILITY FOR THE ASSOCIATED COST AND SCHEDULE IMPACT. 1.05. DRAWING SCALE: REPROGRAPHIC TECHNIQUES MAY RENDER DRAWINGS DIFFERENTLY THAN THE INTENDED PRINTED SCALE. THEREFORE, DO NOT RELY UPON THE SCALE OF ANY PRINTED DRAWINGS. CONTACT THE ARCHITECT FOR REQUIRED DIMENSIONS THAT ARE NOT PROVIDED IN SCALE DIMENSIONS OR OTHERWISE NOTED AS "CLEAR", "MIN", OR "MAX" SHALL BE STRICTLY ENFORCED. 1.06. DIMENSIONAL STANDARDS: STANDARD DIMENSION CONVENTIONS UTILIZED HEREIN CALL FOR DIMENSIONS TO FACE OF STUD MASONRY OF FINISHED PARTITION, FACE OF FINISH, OR CENTERLINE OF COLUMN LINE OR OTHER REFERENCE LINE, UNLESS OTHERWISE NOTED OR GRAPHICALLY ILLUSTRATED. DIMENSIONS NOTED AS "CLEAR", "MIN", OR "MAX" SHALL BE STRICTLY ENFORCED. 1.07. BIM SOFTWARE: THE GENERAL CONTRACTOR SHALL SECURE AND PAY FOR ALL NECESSARY AND REQUIRED PERMITS AND APPROVALS FROM JURISDICTIONAL AUTHORITIES, PRIOR TO COMMENCING THE WORK. THIS REQUIREMENT SHALL APPLY TO ON-SITE AND OFF-SITE WORK REQUIRED BY THE CONTRACT DOCUMENTS. 1.09. CODE COMPLIANCE: THE WORK SHALL BE PERFORMED IN STRICT COMPLIANCE WITH ALL APPLICABLE LAWS, CODES, AND ORDINANCE. THE GENERAL CONTRACTOR AND SUB-CONTRACTORS SHALL PERFORM THEIR WORK IN COMPLIANCE WITH ALL APPLICABLE BUILDING CODES, LAWS, REGULATIONS, AND ORDINANCES. GENERAL CONTRACTOR AND ALL SUB-CONTRACTORS SHALL CAREFULLY READ AND FAMILIARIZE THEMSELVES WITH THE CODE COMPLIANCE DATA INCLUDED IN THE ORIGINAL DRAWINGS AND SPECIFICATIONS. 1.10. NON-COMBUSTIBLE CONSTRUCTION TYPES: THE PROPOSED BUILDING STRUCTURE IS NON-COMBUSTIBLE IN ACCORDANCE WITH APPLICABLE CODES, AND THEREFORE REQUIRES NON-COMBUSTIBLE CONSTRUCTION TECHNIQUES. ALL NEW CONSTRUCTION SHALL BE IN COMPLIANCE WITH APPLICABLE REQUIREMENTS, INCLUDING WOOD BLOCKING, FURRING, FRAMING, SHEATHING, BACK-BORDS, AND RELATED WORK. FIRE RETARDANT TREATED (FRT) IS PERMITTED WHERE ALLOWED BY CODE. SEE CODE COMPLIANCE DRAWINGS FOR DETAILED INFORMATION AND REQUIREMENTS. 1.11. TEMPORARY GUARDS: THE GENERAL CONTRACTOR SHALL INSTALL AND MAINTAIN TEMPORARY GUARDS AT ALL SLAB EDGES, PIT EDGES, ELEVATED PLATFORM EDGES, AND SIMILAR CONDITIONS WHERE REQUIRED BY OSHA, ANY APPLICABLE CODE OR ORDINANCE, AND AT MINIMUM ALL CHANGES IN ELEVATION IN EXCESS OF THREE (3') FEET. FALL PROTECT BOTH SIDES OF STAIRS AND LADDERS. TEMPORARY GUARDS MUST MAINTAIN THE PERMANENT GUARDS ARE INSTALLED. 1.12. LIFE-SAFETY MEASURES DURING CONSTRUCTION: THE GENERAL CONTRACTOR SHALL COMPLY WITH ALL REGULATIONS REQUIRED BY OSHA, CODE, AND OTHER APPLICABLE REGULATORY AUTHORITIES. 1.13. MEANS OF ACCESS: THE GENERAL CONTRACTOR SHALL MAINTAIN CLEAR AND UNOBSTRUCTED MEANS OF ACCESS AT ALL TIMES DURING CONSTRUCTION, WITHOUT EXCEPTION. 1.14. CONSTRUCTION LOADS: THE GENERAL CONTRACTOR SHALL NEVER LOAD NEW OR EXISTING CONSTRUCTION BEYOND ITS DESIGN CAPACITY WITH STORED MATERIAL, CONSTRUCTION EQUIPMENT, TEMPORARY BRACINGS, OR EQUIPMENT WITH MATERIAL MOVEMENT, HOSTING, OR STORAGE. SIMILAR CHARGES SHALL BE PROHIBITED. 1.15. GENERAL CLEANUP: THE GENERAL CONTRACTOR SHALL INCLUDE ONGOING CLEAN-UP OF THE PROJECT AND DURING INSTALLATION. REMOVAL OF TRASH AND WASTE MATERIALS, ON A REGULAR BASIS DURING CONSTRUCTION. RECYCLING OF CONSTRUCTION WASTE IS ENCOURAGED. 1.16. OWNER FURNISHED EQUIPMENT: LOOSE FINISHINGS, WORKSTATIONS, OFFICE EQUIPMENT, COPIERS, VIDEOS, MACHINES, TOOLS, EQUIPMENT, AND SIMILAR ITEMS THAT ARE NOT LABELED "OWNER FURNISHED" OR "F.O.T.", AND SHOWN DASHED OR IN GRAY-TONE SHALL BE CONSIDERED OWNER FURNISHED EQUIPMENT. OWNER FURNISHED EQUIPMENT IS SHOWN FOR THE GENERAL CONTRACTOR'S KNOWLEDGE AND UNDERSTANDING TO FACILITATE COORDINATION WITH THE OWNER'S WORK. THE GENERAL CONTRACTOR SHALL CAREFULLY REVIEW THE SCOPE OF WORK, AND REQUEST CLARIFICATION FROM THE ARCHITECT IN THE EVENT OF ANY UNCERTAINTY ABOUT THE DEFINITION OF OWNER FURNISHED WORK. 1.17. OPTIONAL - RENOVATION PARTITION DESIGNATION: EXISTING PARTITIONS SCHEDULED TO BE REMOVED ARE ILLUSTRATED AS DASHED LINES ON THE PLANS LABELED "DEMOLITION PLANS". EXISTING PARTITIONS TO REMAIN ARE ILLUSTRATED IN GRAY-TONE (SCREENED). NEW WORK IS ILLUSTRATED IN BLACK-LINE. 1.18. OPTIONAL - RENOVATION PROTECTION: EXISTING OCCUPIED AREAS, AND WORK TO REMAIN AFTER CONSTRUCTION, SHALL BE PROTECTED DURING CONSTRUCTION ACTIVITIES. PROTECTION SHALL ENCOMPASS CONSTRUCTION OF TEMPORARY BARBERS, MAINTENANCE OF EXISTING MECHANICAL, FIRE PROTECTION, AND ELECTRICAL SYSTEMS, AND PHYSICAL PROTECTION OF WORK TO REMAIN THAT IS SUBJECT TO DAMAGE FROM CONSTRUCTION ACTIVITIES. THE GENERAL CONTRACTOR SHALL REPAIR OR REPLACE EXISTING WORK SCHEDULED TO REMAIN, THAT IS DAMAGED DURING CONSTRUCTION DUE TO INSUFFICIENT PROTECTION. 1.19. OPTIONAL - TEMPORARY BRACING: THE GENERAL CONTRACTOR SHALL, PRIOR TO REMOVAL OF ANY EXISTING STRUCTURAL ELEMENTS, TEMPORARILY SHORE AND/OR BRACE EXISTING CONSTRUCTION TO REMAIN AS REQUIRED TO SUPPORT EXISTING LOADS AND/OR LOADS IMPOSED DURING CONSTRUCTION. FURTHER, THE GENERAL CONTRACTOR SHALL DESIGN, INSTALL AND MAINTAIN ANY TEMPORARY BRACING OR SUPPORT FRAMING REQUIRED TO SUPPORT NEW CONSTRUCTION COMPONENTS WHICH ARE NOT FULLY SECURED IN A COMPLETE STRUCTURAL ASSEMBLY, OR ARE OTHERWISE SUBJECT TO LOADS IN EXCESS OF THE POST-CONSTRUCTION LOADS FOR WHICH THE ELEMENT IS DESIGNED.

B. DIVISION 2 - EXISTING CONDITIONS

2.01. POSITIVE DRAINAGE AT BUILDING: SLOPE EXTERIOR GRADE AWAY FROM THE BUILDING IN ACCORDANCE WITH THE INTERNATIONAL BUILDING CODE. 2.02. SITE PAVING EXPANSION AND CONTROL JOINTS: WHETHER SPECIFICALLY INDICATED OR NOT, FURNISH AND INSTALL CONTROL JOINTS IN ALL SITE CONCRETE PAVING FOR PEDESTRIAN TRAFFIC AT AN INTERVAL OF NO MORE THAN FIVE FEET (5') EACH WAY. IN ADDITION, FURNISH AND INSTALL CONTROL JOINTS AT NO MORE THAN THIRTY FOOT (30') INTERVAL, EACH WAY. ALL EXPANSION JOINTS, INCLUDING THOSE BETWEEN HORIZONTAL PAVING AND VERTICAL ADJUSTMENTS, SHALL RECEIVE SPECIFIED JOINT FILLER, AS SPECIFIED IN SECTION 07900. C. DIVISION 3 - CONCRETE 3.01. SLAB-ON-GRADE: SEE SPECIFICATION SECTION 03300 FOR DETAILED REQUIREMENTS OF SLAB-ON-GRADE CONSTRUCTION, INCLUDING REQUIREMENTS FOR REINFORCING, CONCRETE AD-MIXTURES, VAPOR BARRIER, AND SURFACE TREATMENTS (IF ANY). ALL SLAB-ON-GRADE CONSTRUCTION SHALL BE INSTALLED OVER MINIMUM FOUR INCH (4") THICK COMPACTED POROUS DRAINAGE LAYER. 3.02. SLAB EXPANSION AND CONTROL JOINTS: SEE STRUCTURAL DRAWINGS FOR REQUIRED SLAB EXPANSION AND CONTROL JOINTS. ALL EXPANSION JOINTS AND CONTROL JOINTS IN FLOOR SLABS, AND BETWEEN FLOOR SLABS AND VERTICAL ADJUSTMENTS SHALL RECEIVE TRAFFIC BEARING SEALANT JOINT MATERIAL. 3.03. CORE DRILLING PROHIBITED: THE GENERAL CONTRACTOR SHALL NOTIFY THE ARCHITECT IN WRITING OF THE LOCATION AND DIMENSION OF ANY PROPOSED CORES THROUGH STRUCTURAL FLOOR SLABS, PRIOR TO COMMENCING CORING ACTIVITIES. CORE DRILLING IS STRICTLY PROHIBITED (SLEEVES ONLY) IN ANY POST-TENSIONED STRUCTURED FLOOR SLAB ASSEMBLIES. D. DIVISION 4 - MASONRY 4.01. SEAL VENEER ANCHORS: ALL EXTERIOR VENEER SYSTEM ANCHORS SHALL BE SET IN FULL, FRESH BED OF THINLY GRADE AIR-MOISTURE BARRIER COATING, OR DOW 795 OR EQUIVALENT AT THE PLANE OF THE AIR-MOISTURE BARRIER. E. DIVISION 5 - METALS 5.01. EMBEDDED STEEL: ALL MISCELLANEOUS STEEL ITEMS INCLUDING STEEL EDGE ANGLES, EMBEDDED PLATE, AND SIMILAR WORK SHALL BE GALVANIZED. THIS PROVISION DOES NOT APPLY TO REINFORCING STEEL, WHICH SHALL COMPLY WITH SPECIFICATION DIVISION 03300. F. DIVISION 6 - WOOD, PLASTICS & COMPOSITES 6.01. WOOD IN CONTACT WITH CONCRETE/MASONRY: ALL WOOD IN CONTACT WITH CONCRETE OR MASONRY CONSTRUCTION SHALL BE PRESSURE TREATED (PT). 6.02. FIELD VERIFICATION: THE CASEWORK OR MILLWORK CONTRACTOR SHALL OBTAIN AND VERIFY ALL FIELD MEASUREMENTS AND CONDITIONS AFFECTING HIS WORK AND SHALL BE RESPONSIBLE FOR ALL DETAILS AND DIMENSIONS AFFECTING PRECISION AND PROPER ASSEMBLY OF HIS PRODUCTS. 6.03. MILLWORK BASE: PROVIDE FINISHED BASE TO MATCH MATERIAL AND FINISH OF ADJACENT SCHEDULED WALL BASE, AT TOE-KICK, AT ALL EXPOSED FRONT, SIDE, AND REAR FACES OF MILLWORK OR CASEWORK. 6.04. MILLWORK SPLASH: PROVIDE BACKSPLASH COUNTERTOPS UNLESS OTHERWISE INDICATED ON PLAN. PROVIDE SIDESPLASH MATERIAL, DIMENSION, AND FINISH EVERYWHERE AT ALL EXPOSED BACKSPLASH AND VERTICAL WALL SURFACE AT ONE OR MORE OF ITS SIDES UNLESS OTHERWISE INDICATED ON PLAN. G. DIVISION 7 - THERMAL & MOISTURE PROTECTION 7.01. CONTINUOUS SEALANTS: CONTINUOUSLY SEAL JUNCTIONS OF ALL DOORS AND WINDOW FRAMES TO THE MASONRY, CONCRETE, TRIM, CASING, AND SIMILAR CONSTRUCTION. ALL EXTERIOR SURFACE CONTROL AND EXPANSION JOINTS SHALL BE PROPERLY SEALED WITH FLEXIBLE JOINT. 7.02. SLOPE OF EXTERIOR SURFACES: ALL EXTERIOR SURFACES SHALL BE SLOPED TO DRAIN, WITH MINIMUM SLOPE OF ONE PERCENT. PROVIDE TAPERED INSULATION, CROCKETS AS NECESSARY TO ACHIEVE THE MINIMUM SLOPE IS ACHIEVED. 7.03. FURNISH: FURNISH AND INSTALL COMPATIBLE ROOF WALK-PADS AT ALL MEMBRANE ROOF JOINTS THAT ARE TRAVELED TO ACCESS SERVICEABLE ROOFTOP EQUIPMENT SUCH AS TELEPHONES, FANS, ELECTRICAL EQUIPMENT, AND SIMILAR EQUIPMENT REQUIRING SERVICE ACCESS. 7.04. EXPANSION JOINTS COVERS: ALL BUILDING EXPANSION JOINTS EXPOSED TO VIEW IN FLOOR, PARTITION, AND/OR CEILING ASSEMBLIES SHALL RECEIVE COLOR-COORDINATED PRE-FABRICATED EXPANSION JOINT COVER ASSEMBLY DESIGNED TO ALLOW THE REQUIRED MOVEMENT, AND TO PROVIDE UL APPROVED FIRE RATED ASSEMBLY WHERE REQUIRED. H. DIVISION 8 - OPENINGS 8.01. FIRE DOORS AND FRAMES: ALL FIRE DOORS AND FRAMES SHALL BE LABELED BY AN APPROVED AGENCY PER NFPA 80, AND SHALL BE PERMANENTLY AFFIXED THERETO, AND THE LIFE OF THE LABEL AND THE ATTACHMENT THEREOF CAN REASONABLY BE EXPECTED TO EQUAL THE LIFE OF THE COMPONENT TO WHICH IT IS ATTACHED. LABELS MUST BE PROVIDED BY A MANUFACTURER THAT HAS BEEN APPROVED BY A LABORATORY OR ORGANIZATION TO PROVIDE TESTING AND FOLLOW-UP SERVICES FOR FIRE-RATED OPENING ASSEMBLIES. LABELS SHALL BE RAISED OR EMBOSSED ON METAL LABELS OR STAMPED INTO METAL FRAMES. PLASTIC OR PAPER LABELS ARE UNACCEPTABLE. THE LABEL MUST BE VISIBLE AND LEGIBLE AT ALL TIMES AND SHALL NOT BE PAINTED. FAILURE TO COMPLY WITH THIS REQUIREMENT WILL REQUIRE PAINTER TO REIMBURSE OWNER FOR COSTS OF RE-LABELING RATED DOORS AND FRAMES. ALL LABELS SHALL INCLUDE THE FIRE RESISTANCE RATING IN HOURS AND/OR MINUTES, LABELS ON FRAMES WITH TRANSOMS AND/OR SIDELIGHTS MUST INDICATE THAT THE OPENING ASSEMBLY INCLUDES SAME. 8.02. TEMPERED GLASS: PROVIDE TEMPERED SAFETY GLASS EVERYWHERE REQUIRED BY APPLICABLE CODE, INCLUDING ANY GLASS IN DOORS, OPERABLE WINDOWS, ADJACENT TO DOORS OR OPERABLE WINDOWS, WITHIN 36" OF THE ADJACENT FLOOR OR GRADE LEVEL, OR OTHERWISE WHERE REQUIRED BY CODE. 8.03. BLOCKING: FURNISH AND INSTALL ALL BLOCKING IN METAL STUD FRAMED WALLS AND PARTITIONS THAT ARE SCHEDULED TO RECEIVE DOOR BUMPER STOPS, MAGNETIC LOOK DEVICES, AND SIMILAR DOOR RELATED DEVICES THAT WILL SUBJECT THE PARTITION TO DOOR MOVEMENT LOADS AND IMPACT. 8.04. HOLLOW METAL FRAMES: COORDINATE THE THROAT DEPTH OF ALL HOLLOW METAL FRAMES WITH THE DEPTH OF THE PARTITION SCHEDULED TO RECEIVE THE DOOR OR WINDOW FRAME.

I. DIVISION 9 - FINISHES

9.01. INDOOR ENVIRONMENTAL CONDITIONS: NO INTERIOR SOFT CONSTRUCTION (IE. DRYWALL, COINGS, CARPET, MILLWORK, OR SIMILAR WORK THAT IS SUBJECT TO TEMPERATURE AND HUMIDITY INSTABILITY) SHALL COMMENCE, NOR SHALL MATERIALS BE STORED ON SITE, UNTIL STABLE INTERIOR ENVIRONMENTAL CONDITIONS ACCEPTABLE TO THE PRODUCT MANUFACTURER ARE PROVIDED AND IN PLACE FOR A DURATION SUFFICIENT TO ESTABLISH CONSISTENT AND ACCEPTABLE INDOOR TEMPERATURE AND HUMIDITY LEVELS. FAILURE TO PROVIDE AN INDOOR ENVIRONMENT IN STRICT COMPLIANCE WITH THE PRODUCT MANUFACTURER'S PRINTED REQUIREMENTS WILL SUBJECT THE INSTALLING CONTRACTOR TO FULL RESPONSIBILITY FOR ANY COSTS ASSOCIATED WITH RE-WORK DUE TO MOLD OR MILDEW GROWTH, WARPING, CURPING, DELAMINATION, OR SIMILAR DETERIORATION OF THE STORED OR INSTALLED CONSTRUCTION. 9.02. FLOOR & WALL TILE: INSTALL FLOOR AND WALL TILE IN ALL SCHEDULED AREAS IN ACCORDANCE WITH APPLICABLE TILE COUNCIL OF AMERICA (TCA) METHOD. 9.03. FLOOR FINISH TRANSITIONS: UNLESS OTHERWISE INDICATED, TRANSITION FLOOR FINISHES AT CENTERLINE OF DOOR IN CLOSED LOCATION. TRANSITION FLOOR MATERIAL UNDER CENTER OF DOORS & WHERE NOTED. PROVIDE SCHEDULED TRANSITION MATERIALS AT CHANGES IN FLOOR MATERIAL TYPE. 9.04. PARTITIONS: SEE PARTITION NOTES AND SPECIFICATIONS FOR REQUIREMENTS OF PARTITION CONSTRUCTION. 9.05. EQUIPMENT ACCESS DOORS: THE GENERAL CONTRACTOR SHALL PROVIDE PROPOSED LOCATION OF CEILING ACCESS DOORS TO THE ARCHITECT FOR APPROVAL. ACCESS DOORS SHALL BE PAINTED TO MATCH ADJACENT FINISH. 9.06. CASEWORK AND MILLWORK ANCHORAGE: COORDINATE INSTALLATION OF IN-WALL STEEL ANCHORAGE, GROUNDOS, AND REQUIRED BLOCKING WITH OTHER TRADES FOR PRECISE LOCATION.

J. DIVISION 10 - SPECIALTIES

K. DIVISION 11 - EQUIPMENT

L. DIVISION 12 - FINISHINGS

12.01. LOCKABLE CASEWORK: ALL CABINETS TO BE LOCKABLE WITH THE PORTION OF UPPER & LOWER TYPICAL CLASSROOM & BREAK ROOM CABINETS & FILE DRAWERS TO BE LOCKABLE. 12.02. CASEWORK BASE: PROVIDE FINISHED BASE TO MATCH MATERIAL & FINISH OF ADJACENT WALL BASE, AT TOE-KICK, AT ALL EXPOSED FRONT, SIDE, AND REAR FACES UNLESS OTHERWISE INDICATED ON PLAN. PROVIDE SIDESPLASH MATERIAL, DIMENSION, FINISH EVERYWHERE A COMPLETE TOP BACKSPLASH AND VERTICAL SURFACE AT ONE OR MORE OF ITS SIDES UNLESS OTHERWISE INDICATED ON PLAN. M. DIVISION 13 - SPECIAL CONSTRUCTION (PRE-CAST/CAST IN PLACE CONCRETE) 13.01. STRUCTURAL FOUNDATION COORDINATION: COORDINATE EXACT BOTTOM OF CONCRETE SHAFT WITH THE REQUIREMENTS OF SELECTED ELEVATOR MANUFACTURER. EXACT LOCATION OF SLUMP PITS AS INDICATED BY SELECTED ELEVATOR MANUFACTURER. AREA BETWEEN BOTTOM OF SLAB & ELEVATOR SHAFT & STRUCTURAL CONCRETE MAT FOOTING TO BE FORDUM. 14.02. STRUCTURAL CONCRETE WALL COORDINATION: COORDINATE ALL REQUIRED ELEVATOR SHAFT WALL PENETRATIONS, EMBED LOCATIONS, SPECIAL HOSTWAY INFILL BRACKETS (REQUIRED FOR INSTALLATION IN SHAFT PROVIDED), WALL MOUNTED LADDERS, EIGHTH SELECTED ELEVATOR MANUFACTURER. 14.03. STRUCTURAL CMU WALL COORDINATION: COORDINATE ALL REQUIRED ELEVATOR SHAFT WALL PENETRATIONS, EMBED LOCATIONS, SPECIAL HOSTWAY INFILL BRACKETS (IF REQUIRED FOR INSTALLATION IN SHAFT PROVIDED), ROUGH OPENINGS FOR DOORS, ETC. WITH SELECTED ELEVATOR MANUFACTURER. 14.04. ELECTRICAL COORDINATION: COORDINATE A MINIMUM QUANTITY (2) PER CAB. ELEVATOR DISCONNECTS WITH SELECTED ELEVATOR MANUFACTURER.

O. DIVISION 21 - FIRE SUPPRESSION

21.01. FIRE PROTECTION SYSTEMS: WHERE REQUIRED, INSTALL FIRE PROTECTION SYSTEMS IN STRICT ACCORDANCE WITH APPLICABLE CODES AND ORDINANCES, INCLUDING NFPA. ALL EQUIPMENT UTILIZED IN THE FIRE PROTECTION SYSTEM SHALL BE LISTED BY UNDERWRITERS LABORATORIES (UL). 21.02. FIRE PROTECTION SYSTEM DESIGN: WHERE DESIGN OF THE FIRE PROTECTION SYSTEM IS THE RESPONSIBILITY OF THE CONTRACTOR AS REQUIRED BY A PERFORMANCE SPECIFICATION, THE SYSTEM DESIGN SHALL BE SUPERVISED BY AN INDIVIDUAL WHO IS A REGISTERED FIRE PROTECTION ENGINEER AND/OR IS CERTIFIED AT LEVEL III OR HIGHER IN FIRE PROTECTION ENGINEERING TECHNOLOGY AUTOMATIC SPRINKLER SYSTEM LAUNCHED BY THE NATIONAL INSTITUTE FOR CERTIFICATION IN ENGINEERING TECHNOLOGY (NICET). P. DIVISION 22 - PLUMBING 22.01. CONCEALED PIPING: ALL PIPING, OUTWORK, ELECTRICAL RACEWAYS & CONDUITS SHALL BE CONCEALED IN THE BUILDING CONSTRUCTION. THE GENERAL CONTRACTOR SHALL INCLUDE, IN THE BASE BID, REQUIRED FURRING TO CONCEAL THESE SYSTEMS WHETHER OR NOT THE FRAMING AND FURRING IS ILLUSTRATED IN THE DRAWINGS. 22.02. SECURE PIPING: THE ALL PIPING "HARD" TO STRUCTURE. 22.03. GAS PIPING EXPOSED ON ROOF: WHERE GAS PIPING IS EXPOSED ON THE ROOF, PAINT GAS PIPING "YELLOW". 22.04. PLUMBING FIXTURES: CAREFULLY REVIEW THE DIMENSIONAL STANDARDS FOR INSTALLED PLUMBING FIXTURES, AND PLAN THE WORK TO ASSURE FULL COMPLIANCE OF CODE REQUIRED FIXTURE CLEARANCES. Q. DIVISION 23 - HEATING, VENTILATING, & AIR-CONDITIONING 23.01. MEP DEVICE FIXTURE COORDINATION: COORDINATE LOCATIONS FOR DIFFUSERS, AND RETURN AIR GRILLES TO THE GREATEST EXTENT POSSIBLE IN ORDER TO MAINTAIN LIGHTING LAYOUT INDICATED IN THE DRAWINGS. MEP & FP CONTRACTORS SHALL COORDINATE WORK WITH OTHER DISCIPLINES PRIOR TO INSTALLATION. R. DIVISION 24 - ELECTRICAL 24.01. MEP DEVICE FIXTURE COORDINATION: COORDINATE LOCATIONS FOR DIFFUSERS, AND RETURN AIR GRILLES TO THE GREATEST EXTENT POSSIBLE IN ORDER TO MAINTAIN LIGHTING LAYOUT INDICATED IN THE DRAWINGS. MEP & FP CONTRACTORS SHALL COORDINATE WORK WITH OTHER DISCIPLINES PRIOR TO INSTALLATION. ALL ELECTRICAL ITEMS INDICATED IN OR ON CABINETRY OR MILLWORK SHALL BE SUPPLIED, INSTALLED AND COORDINATED BY THE ELECTRICAL CONTRACTOR, UNLESS OTHERWISE NOTED. 24.02. CENTER CEILING DEVICES: CENTER LIGHTS, SUPPLY DIFFUSERS, RETURN GRILLES, SPRINKLER HEADS, ETC. IN CEILING PANELS IF NOT OTHERWISE INDICATED. 24.03. ELECTRICAL BOXES IN RATED PARTITIONS: WHERE ELECTRICAL BOXED ARE INSTALLED IN FIRE-RATED METAL STUD PARTITIONS, INSTALL BOXES NO LARGER THAN SIXTYN SQUARE INCHES (16 5/8" IN AREA, AND DO NOT EXCEED ONE-HUNDRED SQUARE INCHES (100 SQ) OF METALLIC BOX PER ONE-HUNDRED SQUARE FEET (100 SF) OF FIRE-RATED WALL AREA. WHERE ELECTRICAL REQUIREMENTS DICTATE A HIGHER RATION, TREAT THE ELECTRICAL BOXES WITH CODE APPROVED METHOD TO ASSURE CONTINUOUS RATING. FURTHER, DO NOT INSTALL ELECTRICAL BOXES BACK-TO-BACK IN THE SAME STUD CAVITY WITHOUT APPROVED FIRE-RATED TREATMENT. 24.04. ELECTRICAL DEVICES IN OR NEAR MILLWORK: CAREFULLY LOCATE ELECTRICAL BOXES FOR DEVICES IN OR NEAR MILLWORK AND/OR CASEWORK TO ASSURE COORDINATED INSTALLATION. LOCATE ELECTRICAL DEVICES ABOVE COUNTERTOP SUCH THAT THE DEVICE COVER PLATE WILL NOT INTERFERE WITH SCHEDULED BACKSPLASH OR SIDESPLASH.

INDEX OF DRAWINGS table with columns: Sheet Name, Issue Date. Rows include: 0.0 GENERAL (T1 TITLE SHEET, G1.01 INDEX & GENERAL INFORMATION, G1.11 GENERAL INFORMATION, G1.21 PARTITION TYPES - INTERIOR, G1.31 FIRESTOPPING - THRU-PENETRATION SYSTEMS, G2.01 LIFE SAFETY PLAN), 1.0 CIVIL (G0.1 GENERAL NOTES, G0.2 EXISTING CONDITIONS, G0.3 DEMOLITION PLAN, C1.0 SITE LAYOUT & UTILITY PLAN, G2.0 GRADING AND DRAINAGE PLAN, C3.0 EROSION AND SEDIMENT CONTROL PLAN, G4.0 CONSTRUCTION DETAILS, G4.1 CONSTRUCTION DETAILS), 2.0 LANDSCAPE (L1.00 LANDSCAPE PLAN, L1.01 IRRIGATION SYSTEMS), 3.0 ARCHITECTURE (A.01 FLOOR PLAN, A.02 FLOOR PLAN, A.3 REFLECTING POOLING PLAN, A3.0 ROOF PLAN, A3.02 ROOF DETAILS, A3.01 FLOOR ELEVATIONS, A3.01 BUILDING SECTION 4 SECTION DETAILS, A3.01 WALL SECTIONS, A5.12 WALL SECTIONS, A5.31 VERTICAL CIRCULATION, A5.32 VERTICAL CIRCULATION, A6.01 DOOR SCHEDULE, LEGEND, & DETAILS, A6.02 DOOR DETAILS, A6.1 WINDOW LEGEND AND DETAILS, CAST STONE LEGEND, A7.01 INTERIOR ELEVATIONS, A7.02 INTERIOR ELEVATIONS, A7.1 MILLWORK DETAILS, A8.01 FINISH SCHEDULE & LEGEND, A8.02 FINISH PLAN & DETAILS, A8.03 SIGNAGE TYPES & SCHEDULE), 4.0 Structural (S1.01 GENERAL NOTES, S1.02 SCHEDULE OF SPECIAL INSPECTIONS, S1.03 TYPICAL DETAILS, S1.04 COMPONENT AND CLADDING-WIND PRESSURES, S2.01 FLOOR AND FOUNDATION PLAN, MEZZANINE AND ROOF FRAMING PLAN, S3.01 SECTIONS, S3.02 SECTIONS, S3.03 SECTIONS), 5.0 MECHANICAL (M0.01 HVAC - SCHEDULES, LEGENDS, AND NOTES, M0.02 HVAC - DETAILS, M1.01 HVAC - FLOOR PLANS), 6.0 PLUMBING (P0.01 SCHEDULE, LEGENDS, NOTES, & DETAILS, P1.01 FLOOR PLANS), 7.0 ELECTRICAL (E0.01 ELECTRICAL SITE PLAN, E1.01 LIGHTING & POWER PLANS, E1.02 AUXILIARY & MEZZ. PLANS, E2.01 PANEL SCHEDULES & DETAILS, E2.02 ELECTRICAL DETAILS, E2.03 ELECTRICAL LEGEND & NOTES), 55

ISSUE DATE table with columns: BID ISSUE, DATE. Rows: BID ISSUE 11/30/2017

Oneonta Community Development Center 100 1st Ave W. Oneonta, AL 35121 GMC # ABHM170022

INDEX & GENERAL INFORMATION G1.01 sheet of

2701 1st Avenue S Birmingham, AL 35233 T 205.873.4482 GMCNETWORK.COM

