



Order Plans @

GENERAL NOTES THIS SHEET:

- A. ALL HW, CW AND VENT PIPING SHALL BE RUN ABOVE CEILING UNLESS NOTED OTHERWISE. ROUTE ALL PIPING TIGHT TO STRUCTURE. OFFSET UNDER BEAMS AS REQUIRED. SEE SPECIFICATIONS FOR PIPING INSULATION REQUIREMENTS.
- B. ALL WASTE AND STORM DRAIN PIPING SHALL BE RUN ABOVE SLAB UNLESS NOTED OTHERWISE.
- C. SEE PLUMBING RISERS FOR PIPE SIZES AND SHUT OFF VALVES NOT SHOWN ON PLANS.
- D. COORDINATE EXACT ROUTING OF ALL PIPING SO AS NOT TO CONFLICT WITH OTHER TRADES INCLUDING DUCTWORK AND ELECTRICAL. ROUTE ALL PIPING TIGHT TO STRUCTURE. PROVIDE OFFSETS AROUND BEAMS AS NECESSARY.
- E. HANG ALL PIPING FROM SLAB.

SPECIFIC NOTES THIS SHEET:

- 1 EXISTING BUILDING IS PROTECTED WITH A FULLY AUTOMATIC SPRINKLER SYSTEM. CONTRACTOR TO MODIFY EXISTING SYSTEM AS REQUIRED TO ACCOMMODATE THE NEW CEILING AND FLOOR PLAN. CONTRACTOR SHALL COORDINATE ROUTING OF ALL PIPING WITH ALL TRADES PRIOR TO SUBMISSION OF SHOP DRAWINGS TO THE MECHANICAL ENGINEER AND STATE FIRE MARSHAL. ALL PIPING SHALL BE ROUTED CONCEALED WHERE POSSIBLE AND ANY EXPOSED PIPING SHALL BE PAINTED PER THE REQUIREMENTS OF THE ARCHITECT. CONTRACTOR SHALL PROVIDE A SYSTEM THAT MEETS ALL REQUIREMENTS OF NFPA 101, 13, 12, 20 AND 24. SEE SPECIFICATIONS FOR REQUIREMENTS.
- 2 2" VENT UP FROM FIRST FLOOR.
- 3 CONNECT 3" WASTE PIPING TO EXISTING WASTE IN PLUMBING CHASE. VERIFY EXACT LOCATION IN FIELD.
- 4 2" VENT UP THRU ROOF.

1 P2.0 FLOOR PLAN - PLUMBING NEW
1/4" = 1'-0"

THE INFORMATION CONTAINED IN THIS DOCUMENT IS PROPRIETARY TO LUCIEN T. VIVIEN JR. & ASSOC., INC. THE DOCUMENT MAY NOT BE DISCLOSED, DUPLICATED, OR USED FOR ANY PURPOSE, IN WHOLE OR IN PART, WITHOUT THE PRIOR WRITTEN CONSENT OF LUCIEN T. VIVIEN JR. & ASSOC., INC.

THESE PLANS AND SPECIFICATIONS HAVE BEEN PREPARED BY OR UNDER MY CLOSE PERSONAL SUPERVISION AND, TO THE BEST OF MY KNOWLEDGE AND BELIEF, THEY COMPLY WITH ALL CITY REQUIREMENTS WE ARE GENERALLY ADMINISTERING THE WORK.

LUCIEN T. VIVIEN JR. & ASSOCIATES
CONSULTING MEP ENGINEERS

LTV

3001 22ND STREET, METairie, LA 70002
Ph: 504.218.2400 | F: 504.218.2412 | www.ltvinc.com

NANO
ARCHITECTURE

000000 00000000 00000000

| REV | DATE | DESCRIPTION | BY |
|-----|------|-------------|----|
| | | | |

SEWERAGE AND WATER BOARD
OF NEW ORLEANS

CONTRACT 8155
ELECTRICAL STORAGE ROOM OFFICE RENOVATION

FLOOR PLAN - PLUMBING NEW **P2.0**

| | | |
|-----|-----|--|
| DR | DEV | DWG. No. 12148-W60 SCALE: 1/4" = 1'-0" DATE: 15 NOVEMBER 2017 SHEET: BID DOCUMENTS |
| INC | DEV | |
| CK | DEV | |
| AP | DEV | |