

REFRIGERATION SCHEDULE SYSTEM DTA

Table with columns for Equipment, Case Fixture Length, Walk-in Box Size, Refrigerant, System Elec, Condenser Type, HR Media, Water, SGL Lq Temp, SGL Lq Temp, DESIGN DB, ASHRAE Weather Station Location, and LEESBURG EXECUTIVE, VA. Includes equipment details like Case / Coil Model #, Case / Coil Manufacturer, Application, LBHX Model #, Evaporator Coil, Sub-Circuit Load, Circuit Load, Evap, Case, Walk-in, Air Temp, Circuit Control Valves, Defrost, Defrost Heaters, Voltage, Amps, Fan, Voltage, Amps, Lights, Anti-Sweat, Drain Pan.

General Notes: 1) Project coordinated with Kysor/Warren. 2) Walk-in expansion valves sized with liquid pressure regulating valve set at 128 psig. 3) Section Group A is subdivided by section group AB (subcooler load 45.3 MBH). Section Group AB is self-subcooled (subcooler load 129.9 MBH). Subcooler sized for 50°F liquid and 15°F approach. 4) Section Group B is subdivided by section group BB (subcooler load 15.3 MBH). Section Group BB is self-subcooled (subcooler load 129.9 MBH). Subcooler sized for 50°F liquid and 15°F approach. 5)

REFRIGERATION SCHEDULE SYSTEM DTB

Table with columns for Equipment, Case Fixture Length, Walk-in Box Size, Refrigerant, System Elec, Condenser Type, HR Media, Water, SGL Lq Temp, SGL Lq Temp, DESIGN DB, ASHRAE Weather Station Location, and LEESBURG EXECUTIVE, VA. Includes equipment details like Case / Coil Model #, Case / Coil Manufacturer, Application, LBHX Model #, Evaporator Coil, Sub-Circuit Load, Circuit Load, Evap, Case, Walk-in, Air Temp, Circuit Control Valves, Defrost, Defrost Heaters, Voltage, Amps, Fan, Voltage, Amps, Lights, Anti-Sweat, Drain Pan.

General Notes: 1) Owner's request: install refrigeration equipment manufacturer Kysor/Warren. 2) Walk-in expansion valves sized with liquid pressure regulating valve set at 128 psig. 3) Section Group B is subdivided by section group BB (subcooler load 15.3 MBH). Section Group BB is self-subcooled (subcooler load 129.9 MBH). Subcooler sized for 50°F liquid and 15°F approach. 4) Combined 208V circuit amperage of all cases on circuit exceeds allowable load of circuit breaker. First value indicates amperage of those cases wired as 208V. Second value indicates amperage of final case wired as 208V. 5)

Order Plans

Walmart.com

Walmart LEESBURG, VIRGINIA STORE NO. 1904. Includes a vertical logo and contact information.

ISSUE BLOCK 11/30/17. Includes a table with columns for Description, Date, and Status.

BID SET NOT FOR CONSTRUCTION

REFRIG SCHEDULES