



REMODEL STORE

OLD NAVY

CAP. INC.
STORE DEVELOPMENT
1 FOLSOM STREET
SAN FRANCISCO, CA 94105

REPS. I.D. 00000131847

STORE NUMBER: 5724

STORE LOCATION: BUCKHEAD STATION
1 BUCKHEAD LOOP NE
ATLANTA, GA 30326

DESIGN TYPE: P3
GENERATION: 18012
PROTOTYPE DATE: 08/31/17
OPENING: 2018

CONSULTANT INFO.

PROFESSIONAL STAMP:

ARCHITECT INFO:
brr
ARCHITECT OF RECORD:
BOYD W. BAU
6700 ANTIOCH PLAZA
SUITE 300
MEMPHIS, TN 38124
www.brrarch.com
TEL: 913-262-9095
FAX: 913-262-9044

ISSUE TYPE:
BID/PERMIT 01/05/18

EGRESS FLOOR PLAN SCALE 1/8" = 1'-0" 1

FIRE SPRINKLER / ALARM NOTE:
THIS BUILDING IS CURRENTLY EQUIPPED WITH A FIRE SPRINKLER/ALARM SYSTEM. ANY CHANGES TO THE SYSTEM WILL BE DONE UNDER A SEPARATE PERMIT. SEE MECHANICAL FOR TENANT INSTALLED SPRINKLERS.

NOTE:
SEE ELECTRICAL DRAWINGS FOR EMERGENCY LIGHTING

NOTE:
SEE ELECTRICAL DRAWINGS FOR HORN AND STROBE LOCATIONS

NOTE:
DIAGONAL DISTANCE = 200'-7"
1/3 OF THE DISTANCE IS REQUIRED TO SEPARATE EXITS
200'-7" / 3 = 67'-3" REQUIRED
PROVIDED DISTANCE = 185'-8"

AREA	SQ FOOTAGE	OCC. LOAD CALCULATION	EGRESS WIDTH REQUIRED	EGRESS WIDTH PROVIDED
MERCANTILE (INCLUDES SALES AREAS, CASHWRAP AREAS, DISPLAY AREAS, ADJACENT CLOSETS, FITTING ROOMS, RESTROOMS, JANITOR, EXIT CORRIDOR, TOILET ROOM VESTIBULE, ENTRY VESTIBULE)	13,543 SF	13,543 / 30 = 452 occ.	452 occ x 2" = 90.4"	EXIT DOOR # 1 136" PROVIDED
STORAGE (INCLUDES STOCK / PROCESSING AREA, ELECTRICAL AREA, EMPLOYEE AREA)	1,328 SF	1,328 / 300 = 5 occ.	5 occ x 2" = 1"	EXIT DOOR # 2 36" PROVIDED
BUSINESS (INCLUDES MANAGER'S DESK AREA, MANAGER'S OFFICE, DM OFFICE, TRAINING ROOM)	101 SF	101 / 100 = 2 occ.	2 occ. x 2" = 0.4"	
TOTAL	14,972 SF	459 OCCUPANTS	91.8" REQUIRED	172" PROVIDED
EGRESS PROVIDED IS GREATER THAN REQUIRED				
TRAVEL DISTANCE	MAXIMUM EXIT ACCESS TRAVEL DISTANCE ALLOWED PER 2012 IBC, TABLE 1016.2		250 LINEAR FT.	

SYMBOL	DESCRIPTION
	PATH OF TRAVEL - MINIMUM 36" WIDE. 32" WIDE @ DOORS FOR MAXIMUM OF 24" DEEP.
	FIRE EXTINGUISHER, MOUNT HANDLE @ 48" A.F.F.
	ILLUMINATED EXIT SIGN