



REMODEL STORE

**OLD NAVY**

CAP INC.  
STORE DEVELOPMENT  
FOLSOM STREET  
SAN FRANCISCO, CA 94105

REPS. I.D.: 0000131847

STORE NUMBER: 5724

STORE LOCATION: BUCKHEAD STATION  
1 BUCKHEAD LOOP NE  
ATLANTA, GA 30326

DESIGN TYPE: P3  
GENERATION: 18012  
PROTOTYPE DATE: 08/31/17  
OPENING: 2018

CONSULTANT INFO:

**M-Engineering**  
750 Brookridge Blvd.  
Westerville, Ohio 43081  
phone: 614.539.4533  
fax: 614.539.2222  
www.mengineering-us.com

PROFESSIONAL STAMP:

ARCHITECT INFO:

**brr**

ARCHITECT OF RECORD:  
BOYD W. RAU  
6709 ANTIPOCH PLAZA  
SUITE 300  
MEMPHIS, TN 38124  
www.brrarch.com  
TEL: 913-262-9095  
FAX: 913-262-9044

ISSUE TYPE:  
BID/PERMIT 01/05/18

**FIRE SPRINKLER PLAN**

1/8" = 1'-0"  
100

**SPRINKLER GENERAL NOTES**

1. THE ABBREVIATION GC, WHEREVER IT APPEARS IN THESE MECHANICAL AND ELECTRICAL DRAWINGS, SHALL REFER TO THE GENERAL CONTRACTOR.
2. THE CONTRACTOR FOR THIS DIVISION OF WORK IS REQUIRED TO READ THE SPECIFICATIONS AND REVIEW DRAWINGS FOR ALL DIVISIONS OF WORK AND IS RESPONSIBLE FOR THE COORDINATION OF THIS WORK AND THE WORK OF ALL SUBCONTRACTORS WITH ALL DIVISIONS OF WORK. IT IS THIS CONTRACTOR'S RESPONSIBILITY TO PROVIDE ALL SUBCONTRACTORS WITH A COMPLETE SET OF BID DOCUMENTS.
3. FIRE PROTECTION PLANS, SPRINKLER DRAWINGS, MUST BE ENGINEERED AND WET SIGNED BY A LANDLORD APPROVED, LICENSED REGISTERED FIRE PROTECTION CONTRACTOR WITH LOCAL JURISDICTION. FINAL INSTALLATION MUST COMPLY WITH NFPA 13 AND STATE AND LOCAL AUTHORITIES HAVING JURISDICTION.
4. SPRINKLER HEAD LAYOUT IS A SUGGESTED LAYOUT. COORDINATE SPRINKLER HEAD LAYOUTS AND PIPE ROUTING WITH ARCHITECTURAL PLANS, STRUCTURAL PLANS, HVAC CONTRACTOR, ELECTRICAL CONTRACTOR AND THE GC. THIS CONTRACTOR SHALL INCLUDE IN THE BID AND BE RESPONSIBLE FOR EXACT QUANTITY OF SPRINKLER HEADS REQUIRED FOR COVERAGE AND FINAL APPROVAL.
5. LOCATE SPRINKLER MAIN AND RELATED SHUT OFF VALVES IN AN ACCESSIBLE LOCATION WITHIN THE STOCKROOM.

**SPRINKLER CODED NOTES**

- 200 INSTALL SPRINKLER HEADS ABOVE AND BELOW DUCTWORK AS REQUIRED BY NFPA 13. COORDINATE INSTALLATION OF HEADS WITH HVAC CONTRACTOR AND G.C.
- 300 LANDLORD SPRINKLER MAIN.

SPRINKLER HEAD LEGEND		
SYMBOL	DESCRIPTION	REMARKS
⊗	BRONZE UPRIGHT HEAD	
⊗	BRONZE UPRIGHT HEAD - EXISTING	
●	CONCEALED HEAD	
○	NON-FREEZE SPRINKLER HEAD IN CAVITY	
⊙	RECESSED HEAD	

NOTE TO CONTRACTOR:  
SEE "GENERAL SHEETS" IN THIS SET FOR RESPONSIBILITY MATRIX ITEMS AND REFER TO SPECIFICATION BOOK FOR GENERAL NOTES.

CHANGES TO THE DESIGN OF ANY SYSTEM IDENTIFIED ON THESE DRAWINGS OR SPECIFICATIONS SHALL BE SUBMITTED TO THE ENGINEER OF RECORD FOR REVIEW AND APPROVAL PRIOR TO THE FABRICATION AND INSTALLATION. ANY MODIFICATIONS WITHOUT THE ORIGINATING ENGINEER'S WRITTEN AUTHORIZATION AND APPROVAL SHALL BE THE RESPONSIBILITY, AS WELL AS THE COST TO CORRECT SUCH MODIFICATION, OF THE CONTRACTOR.

**SPRINKLER SUBMITTAL REQUIREMENTS**

THIS FIRE PROTECTION CONTRACTOR SHALL PREPARE DETAILED SHOP DRAWINGS AND CALCULATIONS FOR THEIR WORK. SUBMIT TO THE G.C. FOR ARCHITECTURAL APPROVAL OF HEAD LOCATIONS AND TYPES.

THIS FIRE PROTECTION CONTRACTOR IS RESPONSIBLE FOR SUBMITTING COORDINATED DRAWINGS, HYDRAULIC CALCULATIONS, HEAD TYPES AND COLORS TO ALL AUTHORITIES HAVING JURISDICTION FOR APPROVAL. NO WORK SHALL BEGIN UNTIL ALL APPROVALS HAVE BEEN RECEIVED.

**RESPONSIBILITY MATRIX LEGEND**

STOREFRONT EXTRUSION

ITEM

L = LANDLORD  
O = OWNER (CAP INC.)  
GC = GENERAL CONTRACTOR  
E = EXISTING

FURNISHED BY

INSTALLED BY

COMMENTS

**RESPONSIBILITY MATRIX**

ITEM	FURNISHED BY	INSTALLED BY	COMMENTS
SPRINKLER MAIN TO LEASE SPACE	E	E	
SPRINKLER BRANCHES AND LATERAL GRID PIPING	GC/E	GC	
BACK-FLOW PREVENTOR AND FLOW DETECTOR	GC	GC	
BRONZE UPRIGHT HEADS AND SEMI RECESSED IN OPEN OR EXPOSED CEILING AREAS	GC	GC	PROVIDE NEW AS REQ'D FOR NEW LAYOUT

REMARKS:

NOTE:

1. THE RESPONSIBILITY MATRIX ONLY DELINEATES ITEMS SUPPLIED AND/OR INSTALLED BY OWNER AND/OR LANDLORD. ANY WORK SHOWN IN THE CONSTRUCTION DOCUMENTS NOT DEFINED AS RESPONSIBILITY OF OWNER OR LANDLORD IS FURNISHED AND INSTALLED BY GENERAL CONTRACTOR. SEE BID CLARIFICATION LETTER FOR ANY VARIATION BY SCOPE OF WORK RESPONSIBILITY.
2. GENERAL CONTRACTOR IS RESPONSIBLE FOR THE UNLOADING OF ANY OWNER SUPPLIED CONSTRUCTION ITEMS.

REVISIONS:

DRAWN BY:

A/E JOB NUMBER: 65013029/1742070

TITLE SHEET:  
**FIRE SPRINKLER PLAN**

SHEET NUMBER:  
**F1-0**