

**ELECTRICAL GENERAL NOTES**

1. THE ABBREVIATION G.C., WHEREVER IT APPEARS IN THESE ELECTRICAL DRAWING, SHALL REFER TO 'GENERAL CONTRACTOR'.
2. THE CONTRACTOR FOR THIS WORK IS REQUIRED TO READ THE SPECIFICATIONS AND REVIEW DRAWINGS OF ALL DIVISIONS OF WORK AND IS RESPONSIBLE FOR THE COORDINATION OF THIS WORK AND THE WORK OF ALL SUBCONTRACTORS WITH ALL DIVISIONS OF WORK. IT IS THE CONTRACTOR'S RESPONSIBILITY TO PROVIDE ALL SUBCONTRACTORS WITH A COMPLETE SET OF BID DOCUMENTS.
3. AIM AND ADJUST ALL TRACK FIXTURES AS DIRECTED BY GAP, INC.
4. ALL LIGHTING AND RECEPTACLE CIRCUITS UP TO 60'-0" IN LENGTH SHALL UTILIZE #12 CONDUCTORS MINIMUM, CIRCUITS FROM 61'-0" THRU 100'-0" IN LENGTH SHALL UTILIZE #10 CONDUCTORS MINIMUM AND FROM 101'-0" THRU 150'-0" IN LENGTH SHALL UTILIZE #8 CONDUCTORS MINIMUM, UNLESS OTHERWISE NOTED.
5. IN DRYWALL CEILING AREAS, ARRANGE CIRCUITS TO AVOID THE USE OF JUNCTION BOXES IN INACCESSIBLE LOCATIONS. THE USE OF JUNCTION BOXES ABOVE DRYWALL CEILINGS SHALL BE LIMITED TO LOCATIONS NEAR ACCESS PANELS AS LOCATED ON PLANS. FIELD COORDINATE WITH G.C. PRIOR TO ROUGH-IN TO AVOID ANY CONFLICTS.
6. PLACEMENT OF ALL RECEPTACLES IN THE "SALES" AREA SHALL BE INTENTIONAL (I.E. - CENTERED ON COLUMNS, WALL FEATURES OR TIGHT TO CORNERS AND FLUSH MOUNTED AT GYP BOARD WALL ONLY). FIELD VERIFY EXACT PLACEMENT OF RECEPTACLE WITH G.C. PRIOR TO ROUGH-IN.

**ELECTRICAL SYMBOLS**

- ▼ TELEPHONE OUTLET
- ▼ TELEPHONE OUTLET, FLOOR MOUNTED
- TELEPHONE OUTLET, CEILING MOUNTED
- ▽ DATA OUTLET
- ▽ DATA OUTLET, FLOOR MOUNTED
- DATA OUTLET, CEILING MOUNTED
- ▽ PHONE/DATA OUTLET, FLOOR MOUNTED
- PHONE/DATA OUTLET, CEILING MOUNTED
- ▽ PHONE/DATA OUTLET
- DUPLEX RECEPTACLE
- CEILING MOUNTED RECEPTACLE
- DUPLEX RECEPTACLE, FLOOR MOUNTED
- POWERSTRUT MOUNTED RECEPTACLE
- CEILING MOUNTED QUADRUPLX RECEPTACLE
- QUADRUPLX RECEPTACLE
- GF1 DUPLEX RECEPTACLE WITH GROUND FAULT CIRCUIT INTERRUPTER
- W DUPLEX, WHITE RECEPTACLE AND COVERPLATE
- WS DUPLEX, WHITE RECEPTACLE AND STAINLESS STEEL COVERPLATE
- SF DUPLEX RECEPTACLE, STOREFRONT
- SINGLE RECEPTACLE
- QUADRUPLX RECEPTACLE WITH ISOLATED GROUND
- DUPLEX RECEPTACLE WITH ISOLATED GROUND
- DUPLEX RECEPTACLE WITH USB PORTS
- JUNCTION BOX
- \$ SWITCH, 1-POLE, REFER TO ARCHITECTURAL FOR MOUNTING HEIGHT
- \$3 SWITCH, 3-WAY, REFER TO ARCHITECTURAL FOR MOUNTING HEIGHT
- \$T MOTOR RATED SWITCH WITH THERMAL OVERLOAD PROTECTION
- \$D DIMMER SWITCH
- MS MOTION SENSOR
- BB BYPASS BUTON
- RB REMOTE BALLAST
- R RELAY
- NON-FUSED DISCONNECT SWITCH
- FUSED DISCONNECT SWITCH
- MS MAGNETIC STARTER
- ELECTRICAL PANELBOARD (SHOWN TO SCALE ON PLANS)
- DRY TYPE TRANSFORMER
- BUZZER OR BELL
- BUZZER OR BELL
- ADA PUSHBUTTON
- INTERCOM CALL BUTTON
- ADT CONTROL PANEL
- SPEAKER VOLUME CONTROL
- S SPEAKER
- b.1 BASS MODULE MOUNTED ABOVE CEILING
- ACCESS PANEL. SEE ARCHITECTURAL DRAWINGS.
- HOMERUN CIRCUIT
- POWERSTRUT SUSPENDED FROM STRUCTURE
- UNISTRUT
- FACP FIRE ALARM CONTROL PANEL
- ANNUN FIRE ALARM ANNUNCIATOR
- P PHOTO CELL
- M MANUAL PULL STATION
- S CEILING MOUNTED AREA SMOKE DETECTOR
- X-S DUCT MOUNTED SMOKE DETECTOR
- 120V POWER FROM RTU REC/LT CCT IF REQUIRED
- INTERNAL CONTACTOR
- CR CONTROL RELAY
- TS TAMPER SWITCH
- FS WATER FLOW SWITCH
- AV HORN WITH STROBE LIGHT WALL MOUNTED @ 80" AFF
- V HORN WALL MOUNTED @ 80" AFF
- A HORN WALL MOUNTED @ 80" AFF
- V STROBE LIGHT, CEILING MOUNTED.
- AV HORN WITH STROBE LIGHT CEILING MOUNTED
- S HVAC TEMPERATURE SENSOR
- T HVAC THERMOSTAT
- ⬡ ELECTRICALLY POWERED EQUIPMENT
- AFF ABOVE FINISH FLOOR
- EAS ELECTRONIC ARTICLE SURVEILLANCE
- EBBH ELECTRIC BASEBOARD HEATER
- EC ELECTRICAL CONTRACTOR
- EM EMERGENCY
- EWC ELECTRIC WATER COOLER - COORDINATE RECEPTACLE LOCATION WITH PLUMBING CONTRACTOR
- IG ISOLATED GROUND
- NL NIGHT LIGHTING
- WP WEATHER PROOF
- (X) X = QUANTITY OF CONDUCTORS
- NOTE: NOT ALL SYMBOLS NECESSARILY USED ON PLAN.

**RESPONSIBILITY MATRIX LEGEND**

STOREFRONT EXTRUSION	O	GC	FACTORY FINISHED
ITEM			COMMENTS
FURNISHED BY			L = LANDLORD O = OWNER GC = GENERAL CONTRACTOR
INSTALLED BY			

**RESPONSIBILITY MATRIX**

ITEM	FURNISHED BY	INSTALLED BY	COMMENTS
MAIN OVERCURRENT DEVICE AT LANDLORD'S SERVICE POINT	EXISTING	EXISTING	
METER AT LANDLORD'S SERVICE POINT	EXISTING	EXISTING	
C/T'S AT LANDLORD'S SERVICE POINT	EXISTING	EXISTING	
C/T CABINET AT LANDLORD'S SERVICE POINT	EXISTING	EXISTING	
SERVICE ENTRANCE CONDUIT(S) TO LEASE SPACE	EXISTING	EXISTING	
SERVICE ENTRANCE FEEDER(S)	EXISTING	EXISTING	
277/480 VOLT PANEL(S)	EXISTING	EXISTING	
120/208 VOLT PANEL(S)	EXISTING	EXISTING	
LIGHTING FIXTURES AND LAMP	O	GC	2
MUSIC SYSTEM/SPEAKERS/CABINET	O	O	1,2
MUSIC SYSTEM WIRING	O	O	1,2,3
TV SYSTEM	O	O	1,2,3
PULL-UP DOWN	EXISTING	EXISTING	
EXTERIOR AND INTERIOR LIGHT FIXTURES AS SPECIFIED	GC	GC	
ADA PUSHBUTTON SYSTEM	GC	GC	
CONDUIT AND J-BOX FOR EAS SYSTEM IN VESTIBULE	GC	GC	
FIRE ALARM PANEL	O	GC	4,5

- REMARKS:
1. ALL FINAL EQUIPMENT WIRING AND EQUIPMENT INSTALLATION BY OTHERS
  2. GENERAL CONTRACTOR TO COORDINATE SCHEDULE AND DELIVERY WITH SUPPLIER. STANDARD SHIPPING PROVIDED BY GAP, INC. ANY EXPEDITED SHIPPING COSTS ARE THE RESPONSIBILITY OF THE GENERAL CONTRACTOR.
  3. ROUGH-IN BY GC
  4. MONITORED BY LANDLORD
  5. MUST USE LANDLORD'S FA VENDOR

NOTES:  
THE RESPONSIBILITY MATRIX ONLY DELINEATES ITEMS SUPPLIED AND/OR INSTALLED BY OWNER AND/OR LANDLORD. ANY WORK SHOWN IN THE CONSTRUCTION DOCUMENTS NOT DEFINED AS RESPONSIBILITY OF OWNER OR LANDLORD IS FURNISHED AND INSTALLED BY GENERAL CONTRACTOR. SEE BID CLARIFICATION LETTER FOR ANY VARIATION BY SCOPE OF WORK RESPONSIBILITY.

GENERAL CONTRACTOR IS RESPONSIBLE FOR THE UNLOADING OF ANY OWNER SUPPLIED CONSTRUCTION ITEMS.

**LOEB ELECTRIC CONTACT INFORMATION**

JOHN CALLICOAT  
1800 E. 5TH AVENUE  
COLUMBUS, OHIO 43219  
  
PHONE: 614-4221-5058  
FAX: 614-299-6268  
EMAIL: TheGap@loelectric.com

**DRAWING SCHEDULE**

NUMBER	TITLE
E0-1	ELECTRICAL NOTES AND LEGEND
E0-2	ENERGY CALCULATIONS
E1-0	POWER PLAN
E1-1	LIGHTING PLAN
E1-2	TRACK LAYOUT PLAN
E4-0	LIGHT FIXTURE SCHEDULE
E5-0	EAS DETAILS
E6-0	CASHWRAP DETAILS
E8-0	ELECTRICAL DETAILS
E9-0	POWER RISER AND SCHEDULES
E9-1	PANEL SCHEDULES
E9-3	LIGHTING CONTROL DETAILS
E9-4	ELECTRICAL DETAILS
E9-5	ELECTRICAL DETAILS
E11-0	ELECTRICAL DETAILS
E13-0	ELECTRICAL SPECIFICATIONS
E13-1	ELECTRICAL SPECIFICATIONS

**REMODEL STORE**



GAP, INC.  
STORE DEVELOPMENT  
FOLSOM STREET  
SAN FRANCISCO, CA 94105

REPS. I.D.: 0000131847  
STORE NUMBER: 5724  
STORE LOCATION: BUCKHEAD STATION  
1 BUCKHEAD LOOP NE  
ATLANTA, GA 30326

DESIGN TYPE: P3  
GENERATION: 18012  
PROTOTYPE DATE: 08/31/17  
OPENING: 2018

CONSULTANT INFO:

**M-Engineering**  
750 Brookside Blvd.  
Westerville, Ohio 43081  
Phone: 614-533-4533  
Fax: 614-338-2222  
www.m-engineering-us.com

PROFESSIONAL STAMP:

ARCHITECT INFO:

ARCHITECT OF RECORD:  
BOYD W. BAU  
6700 ANTIPOCH PLAZA  
SUITE 300  
MEMPHIS, TN 38124  
www.brrarch.com  
TEL: 913-263-9095  
FAX: 913-262-9044

ISSUE TYPE:  
BID/PERMIT 01/05/18

REVISIONS:

DRAWN BY: AMH  
A/E JOB NUMBER: 65013029/1742070

TITLE SHEET:  
ELECTRICAL NOTES  
AND LEGEND

SHEET NUMBER:  
**E0-1**

Order Plans @ WWW.LDLINE.COM