



CAP INC.  
STORE DEVELOPMENT  
FOLSOM STREET  
SAN FRANCISCO, CA 94105

REPS. I.D.: 00000131847  
STORE NUMBER: 5724  
STORE LOCATION: BUCKHEAD STATION  
1 BUCKHEAD LOOP NE  
ATLANTA, GA 30326

DESIGN TYPE: P3  
GENERATION: 18012  
PROTOTYPE DATE: 08/31/17  
OPENING: 2018

CONSULTANT INFO:  
  
M-Engineering  
750 Brookside Dr.  
Westerville, Ohio 43081  
phone: 614-533-4039  
fax: 614-339-2222  
www.mengineering.us.com

PROFESSIONAL STAMP:  
  
ARCHITECT OF RECORD:  
BOYD W. RAU  
6700 ANTIOCH PLAZA  
SUITE 200  
MERRIMAN, AS 66204  
www.brrarch.com  
TEL: 913-262-9095  
FAX: 913-262-9044

ISSUE TYPE:  
BID/PERMIT 01/05/18

REVISIONS:

DRAWN BY: AMH  
A/E JOB NUMBER: 65013029/1742070  
TITLE SHEET:  
LIGHT FIXTURE  
SCHEDULE  
SHEET NUMBER:  
E4-0

**LIGHT FIXTURE SCHEDULE**

TAG	PROVIDED BY		DESCRIPTION	MANUFACTURER CATALOG NUMBER	LAMP	BALLAST MANUFACTURER CATALOG NUMBER	WATTS	VOLTS	MOUNTING LOCATION	REMARKS
	OWNER	LANDLORD								
D1	X		UNISTRUT MOUNTED DUAL CIRCUIT TRACK, LENGTH AS INDICATED PER DRAWINGS.	CON-TECH LT28P-SERIES	N/A	N/A	N/A	120	SALES FLOOR DISPLAY WINDOWS	3
D9W	X		UNIVERSAL LAMPHOLDER, ADJUSTABLE SIDE SWIVEL LABELED FOR 20W MAX WHITE FINISH	CON-TECH CLT603P -20W	EIKO (1) LED15WPAR38/NFL/840 or PHILIPS 17PAR38/F25 4000	N/A	20	120	TRACK (SALES/FITTING)	
F1A-4	X		1 ROW 4' FLUORESCENT STRIP WITH ACRYLIC SNAP A WRAP COVER	MERCURY MM-132-OCT-ELB SAW1L4FOOT	PHILIPS (1) F32T8/TL841/ALTO	ADVANCE ICN-1P32N	37	120	FITTING ROOM BEHIND MIRROR PROVIDED BY FIT RM MFG	2
F1-8U	X		8' SURFACE-MOUNTED FLUORESCENT LIGHT FIXT INTEGRAL ELECTRONIC BALLAST WITH TRACK ADAPTORS, WHITE FINISH AND LOUVERS	CON-TECH CTL8132TNP	PHILIPS 32W T8 (2) F32T8/TL841/ALTO	ADVANCE ICN-2P32N	57	120 / 277	SALES FLOOR MOUNTED TO TRACK FACING DOWN	2
F14ASY	X		4' SURFACE-MOUNTED FLUORESCENT LIGHT FIXT WITH ASSYMETRICAL REFLECTOR WHITE FINISH	MERCURY MM132-OCT-ELB-UNI/MMR132A	PHILIPS 32W T8 (1) F32T8/TL841/ALTO	ADVANCE ICN-1P32N	37	120 / 277	SALES FLOOR MOUNTED TO TOP OF UNISTRUT REFLECTOR FLASHING LIGHT TO WALL	2
F18ASY	X		8' SURFACE-MOUNTED FLUORESCENT LIGHT FIXT WITH ASSYMETRICAL REFLECTOR WHITE FINISH	MERCURY MM132-OCT/8T-ELB-UNI/(2)MMR132A	PHILIPS 32W T8 (2) F32T8/TL841/ALTO	ADVANCE ICN-2P32N	57	120 / 277	SALES FLOOR MOUNTED TO TOP OF UNISTRUT REFLECTOR FLASHING LIGHT TO WALL	2
F2-4W	X		2 ROW 4' FLUORESCENT STRIP WITH FLUORESCENT CHANNEL WITH WIRE GUARD	MERCURY MM-232-OCT-ELB-UNI -WGM240	PHILIPS (2) F32T8/TL841/ALTO	ADVANCE ICN-2P32N		120 / 277	PENDANT (SALES/FITTING)	2
F2-8W	X		2 ROW 8' FLUORESCENT STRIP FLUORESCENT CHANNEL WITH WIRE GUARD	MERCURY MM-232-OCT / 8T-ELB- UNI (2)WGM240	PHILIPS (4) F32T8/TL841/ALTO	ADVANCE ICN-4P32N	111	120 / 277	PENDANT (SALES/FITTING)	2
F2E-8W	X		2 ROW 8' FLUORESCENT STRIP FLUORESCENT CHANNEL WITH WIRE GUARD, AND 1300 LUMN EMERGENCY PACK	MERCURY MM-232-OCT / 8T-C-ELB-UNI-EM (2) WGM240	PHILIPS (4) F32T8/TL841/ALTO	ADVANCE ICN-4P32N		120 / 277	PENDANT (SALES/FITTING)	1,2
L-EM	X		4' LED STRIP 0-10V DIMMING BALLAST AND EMERGENCY PACK	CREE LS4-40L-40K-10V-EB14	INCLUDED WITH FIXTURE		44	120 / 277	PENDANT (SALES/FITTING)	1,2
P17	X		17" BARE LAMP PENDANT SILVER EXTERIOR AND WHITE INTERIOR FINISH	HI-LITE H-157-11-CW10-93-10-LBL	GREEN CREATIVE (1) 8.5A19G4DIM/840	N/A	10	120	EMPLOYEE AREA IN STOCKROOM	
P18	X		18" DIAMETER PENDANT WITH WHITE 15' CORD WHITE FINISH, 10 WATT MAX LABEL, WHITE CANOPY, DIMMABLE, LABELED 10W MAX	HI-LITE H-16118-93-CW15-93-10-LBL	GREEN CREATIVE (1) 8.5A19G4DIM/840	N/A	10	120	SALES AND CASHWRAP	
P18B	X		18" DIAMETER PENDANT CUSTOM BLUE EXTERIOR WHITE CORD AND CANOPY, 10 WATT MAX LABEL, WHITE CANOPY,	HI-LITE H-168CC5	GREEN CREATIVE (1) 8.5A19G4DIM/840	N/A	10	120	FIT ROOM AREA	
R9	X		RECESSED LED DOWNLIGHT 4" APERTURE SPECULAR REFLECTOR WIDE BEAM CLEAR RELFECTOR INTEGRAL LED DRIVER INTEGRAL LED 2000 LUMENS 4000K, 29 WATT, 120 VOLT 0-10V DIMMING	CON-TECH R4NC340K12D-C4322W-CLR	N/A	INTEGRAL	29	120	HALLWAY FOR 277 USE 27D2	
R9E	X		RECESSED LED DOWNLIGHT 4" APERTURE SPECULAR REFLECTOR WIDE BEAM CLEAR RELFECTOR INTEGRAL LED DRIVER INTEGRAL LED 2000 LUMENS 4000K, 29 WATT, 120 VOLT 0-10V DIMMING WITH EM BATTERY PACK	CON-TECH R4NC340K12DER-C4322W-CLR	N/A	INTEGRAL	29	120	RESTROOM FOR 277 USE 27D2	
RF2	X		RECESSED 2'X2' FLUORESCENT TROFFER , WITH 9 CELL, SEMI-SPECULAR PARABOLIC LOUVER, 0-10V DIMMING BALLAST	TEXAS FLUORESCENT PARA9C232U/MV	PHILLIPS (2) FB32T8/TL841/6/EA/AL TO 25 WATT	ADVANCE ICN2P32N	44	120	RECESSED CONFERENCE ROOMS AND OFFICES (SUSPENDED CEILINGS)	
RF2E	X		RECESSED 2'X2' FLUORESCENT TROFFER , WITH 9 CELL, SEMI-SPECULAR PARABOLIC LOUVER, EMERGENCY PACK	TEXAS FLUORESCENT PARA9C232U/MV-EM	PHILLIPS (2) FB32T8/TL841/6/EA/AL TO 25 WATT	ADVANCE ICN2P32N	44	120	RECESSED CONFERENCE ROOMS AND OFFICES (SUSPENDED CEILINGS)	
S1-1	X		LED WALL PACK,20W,1513 LUMENS,120/277/3000K	HUBBEL NRG-356L-4K-U-PC	INCLUDED WITH FIXTURE	N/A	20	120 / 277	WALL (EXTERIOR ABOVE REAR EXIT DOOR)	
S9	X		WALL MOUNTED FIXTURE WITH FROSTED GLASS LABEL, 10W MAX	HI-LITE H-CGU-1B-93-FR-10-LBL	GREEN CREATIVE (1) 8.5A19G4DIM/840	RB3	10	120 / 277	RESTROOM WALL	
X1	X		LED EXIT SIGN WITH 90 MINUTE BATTERY BACK-UP	LIGHTALARMS QLXN500R-N (RED LETTERS) QLXN500G-N (GREEN LETTERS) * LETTER COLOR PER CODE REQUIREMENT	INCLUDED WITH FIXTURE	N/A	5	120 / 277	EXIT SIGNS	
X1E	X		LED EXIT SIGN WITH 90 MINUTE BATTERY BACK-UP WITH CAPACITY TO POWER (2) REMOTE MOUNTED LAMP HEADS	LIGHTALARMS UQLXN500R * LETTER COLOR PER CODE REQUIREMENT	N/A	N/A	5	120 / 277	EXIT SIGNS AT DOORS (SPECIAL CONDITIONS AS REQUIRED BY CODE)	
X2	X		REMOTE MOUNTED LAMP HEADS	LIGHTALARMS ELF647/4042-M	12 WATT INCLUDED WITH FIXTURE	N/A	12	6	WALL (EXTERIOR ABOVE EXIT DOORS)	

REMARKS:  
1. EMERGENCY PACK TO BE A MINIMUM OF 1300 LUMENS.  
2. LINEAR FLUORESCENT FIXTURES SHALL HAVE AN INTERNAL DISCONNECTING MEANS FOR SERVICE OF THE BALLAST AS PER CODE.  
3. CONTRACTOR SHALL PROVIDE ALL NECESSARY COMPONENTS TO COMPRISE A FULLY FUNCTIONING SYSTEM.  
4. PROVIDED BY FIT ROOM MANUFACTURER.

- UNISTRUT GENERAL NOTES**
- PATCH AND REPAIR (E) FIREPROOFING AS REQUIRED TO MATCH (E) RATING
  - ALL UNISTRUT AND ASSEMBLY TO BE PAINTED IN FIELD.
  - PROVIDE SEISMIC BRACING ONLY WHEN REQUIRED BY CODE.
  - UNISTRUT TO RUN LENGTH OF TRACK AT TRACK LOCATIONS. DO NOT RUN UNISTRUT OR POWER STRUT PAST ENDS OF FIXTURES.
  - THE CEILING CONNECTION SHOWN IS PREFERRED. IF BEAM-CLAMP IS NOT ACCEPTABLE UNDER SITE-SPECIFIC CONDITIONS, USE UNISTRUT AS JOIST CONNECTION. DIRECTLY ATTACHING THREADED ROD OR POWER STRUT TO UNDERSIDE OF ROOF DECK IS NOT ACCEPTABLE.

Order Plans @

WWW.LDILLINE.COM