

REFLECTED CEILING PLAN SHEET NOTES

- SEE SHEET A002 FOR WALL TYPES AND HEIGHT OF WALLS ABOVE CEILING.
- SEE FINISH SCHEDULE FOR CEILING TYPES & MATERIALS IN EACH ROOM / AREA.
- PERIMETER TRACK FOR ALL ACoustICAL CEILING GRIDS TO BE 2" WIDE, INSTALLED IN ACCORDANCE WITH IBC AND CISCA GUIDELINES.
- DIMENSIONS ARE TO FACE OF STUD.
- CEILING GRIDS TO BE CENTERED IN ALL ROOMS UNLESS NOTED OTHERWISE. PARTIAL TILES AT ROOM PERIMETERS SHALL NOT BE LESS THAN 6" IN EITHER DIMENSION.
- SEE ELECTRICAL, FIRE ALARM AND FIRE PROTECTION DRAWINGS FOR SPECIAL SYSTEMS, SMOKE DETECTORS, LIGHTING AND WALL MOUNTED FIXTURES NOT SHOWN ON THIS SHEET. COORDINATE LOCATIONS OF ALL FIXTURES NOT INDICATED WITH LAYOUT INDICATED ON THIS SHEET.
- LIGHT FIXTURES AND MECHANICAL DIFFUSERS ARE SHOWN FOR POSITIONING IN FINISH CEILING SYSTEM. COORDINATE WITH MECHANICAL AND ELECTRICAL DRAWINGS FOR FIXTURE TYPES, MECHANICAL DIFFUSERS, WALL MOUNTED FIXTURES AND INSTALLATION OF FIXTURES IN SPACES WITHOUT CEILINGS. LIGHTING AND HVAC DIFFUSERS ARE SHOWN FOR COORDINATION ONLY. SEE MECHANICAL AND ELECTRICAL DRAWINGS FOR SPECIFIC INFORMATION.
- SEE MECHANICAL FLOOR PLANS FOR EXTENT OF EXPOSED DUCTWORK IN EXPOSED STRUCTURE AREAS WITHOUT CEILINGS.
- EXTEND PERIMETER WALLS AND FINISH TO STRUCTURE ABOVE AT EXPOSED STRUCTURE AREAS. PAINT ALL EXPOSED DUCTWORK, PIPING, AND HANGERS TO MATCH CEILING.
- SEE MECHANICAL AND ELECTRICAL DRAWINGS FOR MOUNTING OF STUDS OF WHICH NO CEILING IS INDICATED.
- CENTER LIGHTS, DIFFUSERS, EXIT SIGNS, SMOKE DETECTORS, SPEAKERS, GENERAL ALARM SPEAKERS, STROBES & MISC DEVICES IN CEILING TILES WHERE THEY ARE LOCATED. ALIGN MULTIPLE ITEM CENTER OR EDGES.
- LOCATE MECHANICAL GRILLES AND DIFFUSERS SHOWN IN CORRIDORS OR NEAR WALL TO 12" OFF WALLS, UNO.
- INSTALL ACCESS PANELS IN GYPSUM BOARD CEILINGS AT DUCTWORK LOCATIONS. DUCT MOUNTED SMOKE DETECTORS AND DUCT CONTROLS SHALL BE INSTALLED IN THE CEILING WHERE THEY OCCUR.



227 WEST TRADE STREET SUITE 700
CHARLOTTE, NORTH CAROLINA 28202
TEL. 704.333.6686 FAX 704.333.2926
WWW.LS3P.COM



MEMBERS OF THE AMERICAN INSTITUTE OF ARCHITECTS

COPYRIGHT 2016 ALL RIGHTS RESERVED
PRINTED OR ELECTRONIC DRAWINGS AND DOCUMENTATION MAY NOT BE REPRODUCED IN ANY FORM WITHOUT WRITTEN PERMISSION FROM LSP ASSOCIATES LTD.


REVISIONS:

No.	Description	Date


PROJECT: 9202-16979
DATE: 12/18
DRAWN BY: ZS
CHECKED BY: WSB

REFLECTED CEILING PLAN


A-121




E1 CLOUD SECTION DIAGRAM 1
1/8" = 1'-0"




E3 CLOUD SECTION DIAGRAM 2
1/8" = 1'-0"




E4 LAY-IN CEILING PERIMETER DETAIL
0" = 1'-0"




E5 HORIZONTAL RESTRAINT
3" = 1'-0"




D1 DINING LAB CLOUD DIAGRAM
3/16" = 1'-0"



D3 TYPICAL FLOATING CEILING PANEL
1/2" = 1'-0"



D2 CEILING PANEL DETAIL
0" = 1'-0"



A1 FIRST FLOOR REFLECTED CEILING PLAN
3/16" = 1'-0"

RCP LEGEND

	2x2 LAY-IN CEILING PANEL		HEIGHT (FEET, INCHES) ABOVE FINISHED FLOOR, 10' 0" U.N.O.
	2x2 LAY-IN VINYL FACED CEILING PANEL		1 X 4 LED FIXTURE
	GYPSUM BOARD		2 X 4 LED FIXTURE
	EXPOSED STRUCTURE		SUPPLY AIR DIFFUSER
	FIRE ALARM DEVICE (ALTERNATE #1)		RETURN AIR DIFFUSER
			EXHAUST FAN

PARTITION LEGEND

- ALL EXTERIOR WALLS TO BE W1 U.N.O.
 - ALL INTERIOR METAL STUD PARTITIONS TO BE ANX U.N.O.
- -
 -
- NOTE: SEE SHEET A002 FOR CONSTRUCTION OF PARTITION TYPES.

EQUIPMENT LEGEND

- NOTE: ALL ITEMS ARE TO BE CONTRACTOR FURNISHED, CONTRACTOR INSTALLED UNO
- -
 -
 -
 -
 -
 -
 -
 -
 -

P:_EDU\2020\9202-16979\Wilkes Community College Culinary Lab\2.0 Design\Drawings\WCC CULINARY LAB_16.rvt 1/5/2018 11:15:00 AM

Order Plans @ www.lsp.com