



- PLAN NOTES:**
- COORDINATE LOCATION OF OUTLET IN CENTER OF SHORT THROW PROJECTOR ON THE WALL. VERIFY HEIGHT AND LOCATION WITH ARCHITECT PRIOR TO ROUGH-IN.
  - SEE DETAIL FOR POWER OUTLETS CONTAINED WITHIN TEACHER STATION, AND SIMILAR SPACES. CONTRACTOR SHALL VERIFY THE EXACT LOCATION OF ALL CASEWORK PRIOR TO ROUGH-IN OF ALL OUTLETS.
  - PROVIDE AND INSTALL OCCUPANCY SENSOR SUCH THAT, PER ASHRAE 90.1-2010, AT LEAST 50% OF RECEPTS. IN A SPACE ARE TURNED OFF WITHIN 30 MINUTES OF ALL OCCUPANTS VACATING SPACE.
  - CONNECT PREFABRICATED FURNITURE TO CIRCUIT INDICATED. COORDINATE ELECTRICAL REQUIREMENTS AND OUTLET MOUNTING LOCATION WITH MANUFACTURER PRIOR TO ROUGH-IN.
  - ISMET GAS, WATER, ETC VALVE/SOLENOID ENCLOSURE. RUN 3/4" WITH CONTROL WIRING TO RESPECTIVE UTILITY CONTROLLER. LOCATE BELOW OR ADJACENT TO CONTROL PANEL.
  - ISMET UTILITY CONTROLLER (CONTROL PNL) WITH PUSHBUTTON FOR SHUTDOWN OF GAS, WATER, POWER, ETC VIA FIRE ALARM SHUTDOWN RELAY OR PUSHBUTTON. REFERENCE MANUFACTURERS WIRING DETAILS FOR FIRE ALARM SYSTEM INTERFACE VIA NORMALLY OPEN FIRE ALARM RELAY. SEE 'F' SERIES SHEETS FOR ADDITIONAL INFORMATION. CONNECT ALL RECEPTACLES IN SPACE THROUGH CONTACTOR. SEE 'CONTACTOR SCHEDULE'.
  - ELECTRICAL WATER COOLER (EWC). LOCATE RECEPTACLE(S) WITHIN EWC ENCLOSURE.
  - 'NOT USED'.
  - PROVIDE AND INSTALL AN INDUSTRIAL QUALITY, CEILING MOUNTED PULL DOWN/RETRACTABLE DROP CORD 'SO' TYPE WITH 2/12, 1/8" TO A 20A/120V/1PH RECEPTACLE. PROVIDE CORD GRIP CONNECTORS AT EACH END, WITH STRAIN-RELIEF AT CEILING CONNECTION. RECEPTACLE SHALL BE AT 6'-0" AFF. EXACT LOCATION TO BE COORDINATED WITH OWNER, SEE DETAIL.

1 FIRST FLOOR POWER PLAN  
 E2.2 SCALE: 1/8" = 1'-0"

Order Plans.com

Harvard Jolly Architecture

**HARVARD • JOLLY ARCHITECTURE**  
 2047 VISTA PARKWAY, SUITE 100 | WEST PALM BEACH, FL 33411 | www.harvardjolly.com | AAC000119

**JLD** JOHNSON, LEVINSON, RAGAN, DAVILA, INC.  
 1450 Centrepark Boulevard, Suite 350  
 West Palm Beach, Florida 33401  
 (561) 689-2103 (561) 689-2102 Fax  
 www.jld.com  
 Certification Number 60959  
 Michael P. Landrum, P.E. 30594  
 Charles C. Chalkers, P.E. 21936

**STEM BUILDING  
 THE BENJAMIN SCHOOL - LOWER MIDDLE SCHOOL**  
 11000 Ellison Wilson Road, North Palm Beach, FL 33408  
 CONSTRUCTION DOCUMENTS

Correl. No: 16117.00  
 Job No: 117030  
 Date: 10-23-17

Revisions		
No.	Date	Note

TO THE BEST OF MY KNOWLEDGE, THE PLANS AND SPECIFICATIONS COMPLY WITH THE MINIMUM BUILDING CODES.

© 2017 HARVARD JOLLY, INC.

JLD Project #117030

E2.2