

THIS DOCUMENT, TOGETHER WITH THE CONCEPTS AND DESIGNS PRESENTED HEREIN, AS AN INSTRUMENT OF SERVICE, IS INTENDED ONLY FOR THE SPECIFIC PURPOSE AND CLIENT FOR WHICH IT WAS PREPARED. REUSE OF AND IMPROPER RELIANCE ON THIS DOCUMENT WITHOUT WRITTEN AUTHORIZATION AND ADAPTATION BY BOWMAN CONSULTING SHALL BE WITHOUT LIABILITY TO BOWMAN CONSULTING.

**General:**

- Construct utilities in accordance to TWA approved plans and shop drawings. Any deviation from the approved plans shall be approved by the DEVELOPER'S ENGINEER and TWA.
- A preconstruction meeting with the TWA's staff is required prior to initiating construction.
- All required permits shall be obtained prior to initiating construction.
- A minimum 12 foot wide access road shall be provided for all TWA owned utilities, which are located outside of roadways. The top 8" of the access road shall be stabilized to a Florida Bearing Value of 75 psi, and compacted to 98% of AASHTO T-180.
- Pipe deflection cannot exceed 50% of the pipe manufacturer's recommendation.
- Reference TWA's Standards, Specifications and Details, latest Edition for issues not specifically addressed below or on the TWA Accepted construction plans.
- Current edition of TWA's Standards, Specifications and Details, at time of TWA plan acceptance shall supersede Accepted Plans. It is the contractor's responsibility to ensure TWA Standards, Specifications and Details are adhered to in construction.

**Permits, Plans, Shop Drawings:**

- Permits or Letters of Determination from FDEP shall be obtained for the sanitary sewer collection system and water distribution system prior to commencement of construction.
- A stamped approved set of plans by TWA shall be present on the site at all times. Approved plans are valid for 12 months from the date of approval. If construction does not begin within the 12 month period, the DEVELOPER must contact TWA for a project status review and approval extension.
- A minimum of three sets of shop drawings shall be submitted to TWA for review and approval prior to construction.
- Installation of materials and/or structures prior to shop drawing approval is done at the Contractor's own risk.
- Two hard copies and one electronic copy of record drawings shall be submitted to TWA at or before the final inspection. Record drawings shall conform to sections 11.6 of TWA Standards, Specifications and Details.

**Water - Testing:**

- Water line shall be installed, cleaned, flushed, disinfected and bacteriologically tested and cleared for service in accordance with the latest AWWA standards and FDEP rules and regulations.
  - All water distribution systems shall be flushed clean of all deleterious material prior to any testing. Full diameter flushing is required. Lines 4" and greater shall be pigged.
- Water line shall be pressure tested in accordance with AWWA-C600 (ductile iron pipe) and AWWA-C605/M23 (PVC pipe) specifications at 150 psi and witnessed by TWA personnel. No leakage shall be allowed. Schedule test a minimum of 72 hours in advance.
- All water mains shall be disinfected in accordance with the latest version of AWWA C651 and witnessed by TWA personnel.

- All bacteriological samples shall be witnessed by TWA personnel.

**Water - Materials:**

- PVC pipe:** four (4) inches through twelve (12) inches shall be AWWA C-900, latest edition. Fourteen (14) inches through thirty-six (36) inches shall be AWWA C-905, latest edition.
- DIP pipe:** four (4)" through fifty-four (54)" shall be ANSI/AWWA A21.51/C151 with a minimum working pressure class 150 pipe.
  - Any fittings required shall be mechanical joint ductile iron conforming to ANSI/AWWA A21.10/C110, 250 psi minimum pressure rating, or ductile iron compact fittings in accordance with ANSI/AWWA A21.53/C153.

Where ductile iron pipe and fittings are to be below ground or installed in a casing pipe the coating shall be a minimum 1.0 mil thick in accordance with ANSI/AWWA A21.51/C151.

Where ductile iron pipe and fittings are to be installed above ground, pipe, fittings and valves shall be thoroughly cleaned and given one field coat (minimum 1.5 mils dry thickness) of rust inhibitor primer, and two finish coats (minimum 1.5 mils dry thickness each).

All ductile iron pipe and fittings shall have an interior protective lining of cement-mortar with a seal coat of asphaltic material in accordance with ANSI/AWWA A21.4/C104.

The pipe shall be polyethylene encased (8 mil) where shown on the PLANS, in accordance with ANSI/AWWA A21.51/C105.

- Polyethylene pipe:** four (4)" through twelve (12)" shall be AWWA standard C906, PE3408 latest edition. The polyethylene pipe shall have a minimum working pressure rating of 160 psi and shall have a standard dimension ratio (SDR) of 11. Pipe shall be the same ID as ductile iron pipe.
  - Polyethylene pipe shall have fusion bonded joints.

Fittings used with polyethylene pipe shall be fusion fittings in accordance with AWWA Standard C906.

- Service pipes:** All service lines shall be 1", 1-1/2" or 2" blue, PC200, SDR9, polyethylene tubing conforming to specifications in AWWA C901, PE3608. 4" and larger service pipe shall be C-900 PVC or DIP. 3" service pipe shall not be permitted.
- Valves shall be resilient wedge gate valves.
- Valves shall be located at not more than 500 foot intervals in commercial, industrial and high density residential areas and at not more than 1000 foot intervals in all other areas. Appropriate valving shall also be provided at the downstream sides of tees and crosses and both sides of a directional bore or jack and bore. This shall include all sides of tees and crosses within looped systems, where flow is potentially multidirectional.
- All meters shall be installed by TWA after all payment of applicable fees and charges. All meters 2" and less in size shall be installed underground in an approved meter box. Meters larger than 2" shall be installed above ground. In general, meters 2 inch and larger shall be located in a meter easement located adjacent to the public right of way and outside of paved areas.

**Reuse - Testing:**

- Reuse line shall be installed, cleaned, flushed, disinfected and bacteriologically tested and cleared for service in accordance with the latest AWWA standards and FDEP rules and regulations.
  - All reuse distribution systems shall be flushed clean of all deleterious material prior to any testing. Full diameter flushing is required. Lines 4" and greater shall be pigged.
- Reuse lines shall be pressure tested in accordance with AWWA-C600 (ductile iron pipe) and AWWA-C605/M23 (PVC pipe) specifications at 150 psi and witnessed by TWA personnel. No leakage shall be allowed. Schedule test a minimum of 72 hours in advance.
- All reuse mains shall be disinfected in accordance with the latest version of AWWA C651 and witnessed by TWA personnel.
- All bacteriological samples shall be witnessed by TWA personnel.

**Reuse - Materials:**

- PVC pipe:** four (4) inches through twelve (12) inches shall be AWWA C-900, latest edition. Fourteen (14) inches through thirty-six (36) inches shall be AWWA C-905, latest edition.
- DIP pipe:** four (4)" through fifty-four (54)" shall be ANSI/AWWA A21.51/C151 with a minimum working pressure class 150 pipe.
  - Any fittings required shall be mechanical joint ductile iron conforming to ANSI/AWWA A21.10/C110, 250 psi minimum pressure rating, or ductile iron compact fittings in accordance with ANSI/AWWA A21.53/C153.

Joints for ductile iron pipe shall be push-on or mechanical joints conforming to ANSI/AWWA A21.11/C111. Above ground joints shall be flanged with T5 cadmium plated bolts, nuts and washers. Flanged joints shall conform to ANSI Standard B 16.1-125 LB.

Where ductile iron pipe and fittings are to be below ground or installed in a casing pipe the coating shall be a minimum 1.0 mil thick in accordance with ANSI/AWWA A21.51/C151.

Where ductile iron pipe and fittings are to be installed above ground, pipe, fittings and valves shall be thoroughly cleaned and given one field coat (minimum 1.5 mils dry thickness) of rust inhibitor primer, and two finish coats (minimum 1.5 mils dry thickness each).

All ductile iron pipe and fittings shall have an interior protective lining of cement-mortar with a seal coat of asphaltic material in accordance with ANSI/AWWA A21.4/C104.

The pipe shall be polyethylene encased (8 mil) where shown on the PLANS, in accordance with ANSI/AWWA A21.51/C105.

- Polyethylene pipe:** four (4)" through twelve (12)" shall be AWWA standard C906, PE3408 latest edition. The polyethylene pipe shall have a minimum working pressure rating of 160 psi and shall have a standard dimension ratio (SDR) of 11. Pipe shall be the same ID as ductile iron pipe.
  - Polyethylene pipe shall have fusion bonded joints.

Fittings used with polyethylene pipe shall be fusion fittings in accordance with AWWA Standard C906.

- Service pipes:** All service lines shall be 1", 1-1/2" or 2" purple, PC200, SDR9, polyethylene tubing conforming to specifications in AWWA C901, PE3608. 4" and larger service pipe shall be C-900 PVC or DIP. 3" service pipe shall not be permitted.
- Valves shall be resilient wedge gate valves.
- Valves shall be located at not more than 500 foot intervals in commercial, industrial and high density residential areas and at not more than 1000 foot intervals in all other areas. Appropriate valving shall also be provided at the downstream sides of tees and crosses and both sides of a directional bore or jack and bore. This shall include all sides of tees and crosses within looped systems, where flow is potentially multidirectional.
- All meters shall be installed by the TWA after all payment of applicable fees and charges. All meters 2" and less in size shall be installed underground in an approved meter box. Meters larger than 2" shall be installed above ground. In general, meters 2 inch and larger shall be located in a meter easement located adjacent to the public right of way and outside of paved areas.

**Sewer - Testing:**

Prior to any testing to be witnessed, all passing soil density tests and slope surveys shall be submitted to the TWA Engineer and to the TWA Inspector.

- All sanitary manholes shall be inspected by TWA personnel.
- Sanitary sewers shall be video inspected and cleaned by TWA personnel.
- Sanitary sewers shall be pressure tested with no allowable loss and witnessed by TWA personnel. Schedule test a minimum of 72 hours in advance.

**Gravity Sewer - Materials:**

- PVC pipe:** four (4)" through fifteen (15)" shall be ASTM D3034, SDR 35. The joints shall be integral bell elastomeric gasket joints manufactured in accordance with ASTM D3212 and ASTM F477. Applicable UNI-Bell Plastic Pipe Association standard is UNI B-4.
- PVC pipe:** eighteen (18)" through twenty-seven (27)" shall be ASTM F679, SDR 35. The joints shall be integral bell elastomeric gasket joints manufactured in accordance with ASTM D3212 and ASTM F477. Applicable UNI-Bell Plastic Pipe Association standard is UNI B-7.

All PVC pipe shall bear the NSF-DW seal. The minimum standard length of pipe shall be thirteen (13) feet. PVC pipe with less than 15 ft of cover shall be SDR 35; 15 to 20 ft shall be SDR 26; and 20 to 30 ft shall be SDR 18.

- DIP pipe:** ANSI/AWWA A21.51/C151, class thickness designed per ANSI/AWWA A21.50/C150, with push on joints. An interior protective lining of "Protecto 401" epoxy, or equal, with a minimum dry film thickness 40 mils.
- Joint Materials:**
  - PVC sewer pipe joints shall be flexible elastomeric seals per ASTM D3212.
  - DIP and fitting joints shall be "push-on" or mechanical joints conforming to ANSI A21.11.
  - Joints between pipes of different materials shall be made with a rigid, PVC, adaptor coupling. Fernco adaptors are not allowed.

**Sewer Force Mains - Testing:**

- Force main piping shall be installed and pigged until clean.
- Force main shall be pressure tested in accordance with AWWA-C600 (ductile iron pipe) and AWWA-C605/M23 (PVC pipe) specifications at 100 psi or 1.5 times the operating pressure, whichever is greater for a minimum of 2 hours and witnessed by TWA personnel. No leakage shall be allowed. Schedule test a minimum of 72 hours in advance.

**Sewer Force Mains - Materials:**

- PVC pipe:** four (4)" through twelve (12)" shall be AWWA standard C900 and a dimension ratio (DR) of 25.
  - PVC pipe shall be integral bell, push-on type joints.
- DIP pipe:** four (4)" through fifty-four (54)" shall be ANSI/AWWA A21.51/C151 with a minimum of pressure class 150 and lined with Protecto 401 or equal.
  - All fittings shall be mechanical joint ductile iron conforming to ANSI/AWWA A21.10/C110, 250 psi minimum pressure rating, four (4) through twelve (12)".

Joints for DIP shall be push-on or mechanical joints and joints for fittings shall be mechanical joints conforming to ANSI/AWWA A21.11/C111.

Above ground joints shall be flanged with T5 cadmium plated bolts, nuts, and washers. Flanged joints shall conform to ANSI Standard B16.1-125 LB.

Where ductile iron pipe and fittings are to be below ground or installed in a casing pipe the coating shall be a minimum 1.0 mil thick in accordance with ANSI/AWWA A21.51/C151.

Where ductile iron pipe and fittings are to be installed above ground, pipe, fittings and valves shall be thoroughly cleaned and given one field coat (minimum 1.5 mils dry thickness) of rust inhibitor primer, and two finish coats (minimum 1.5 mils dry thickness each).

All ductile iron pipe and fittings shall have an interior protective lining of "Protecto 401" epoxy or equal with a minimum dry film thickness of 40 mils.

The pipe shall be polyethylene encased (8 mil) where shown on the PLANS, in accordance with ANSI/AWWA A21.51/C105.

- Polyethylene (PE3408) pipe:** four (4)" through twelve (12)" shall be in accordance with AWWA standard C906, latest edition. The polyethylene pipe shall have a minimum working pressure rating of 160 psi and shall have a dimension ratio (DR) of 11.
  - Polyethylene pipe shall have fusion bonded joints.
  - Fittings used with polyethylene pipe shall be fusion fittings in accordance with AWWA Standard C906.


- Wastewater force mains shall be equipped with air release valves located at piping high points immediately upstream of dips or other elevation declines.
- Valves shall be resilient wedge gate valves.
- Valves shall be located at not more than 2,000 foot intervals in all areas.

**Separation Requirements:**

Per F.O.E.P. requirements and subject to TWA approval.

**Miscellaneous:**


- All tie-ins to existing manholes shall be core drilled. Connect to manhole using a flexible connector or approved A-lok.
- All mechanical joints shall be restrained. Thrust blocks are not allowed for TWA maintained infrastructures.
- Maintain a minimum of 36" of cover measured from the bottom of the sub-grade over all pipes. If less than 36" of cover, use DIP and notify engineer for evaluation.
- Galvanized pipe is not allowed and if encountered shall be replaced with approved materials.
- Marking tape shall be installed 12" to 18" over all pipe. All PVC pipe shall be green in color (for sewer), blue in color for water, and red in color (for reuse). DIP shall have a continuous 2" wide, permanent green/black stripe (oil based enamel) on the top of the pipe.
- A continuous, insulated 14 gauge copper wire shall be installed under the pipe and be accessible at each manhole box. Directional bores shall use 8 gauge steel core copper and 8 gauge copper wire. One (1) each for a minimum.
- Only rigid materials shall be permitted unless transitioning to clay pipe.
  - In general, one compaction test shall be taken for each 12" layer of fill from the springline of the pipe to the finish grade for each 300 feet of pipe and for every 100 square feet of backfill around structures.
- All existing water, reuse and sanitary appurtenances on a project site or affected by project WORK shall be protected during construction and shall be brought to finished grade per the STANDARD CONSTRUCTION DETAILS.
- All tree and shrub root balls shall be placed with a minimum of 5' horizontal separation from Toho maintained utilities.
- If the underground contractor de-mobilizes between phases of a project and the water distribution system has been cleared for use by FDEP, the contractor will be required to install automatic flushing devices on all water main dead-ends whether intended as stub-outs or as incomplete construction. If the site has not been cleared for use by FDEP, the contractor will be required to physically disconnect all un-cleared mains from the points-of-connection to cleared mains.
- When required by another regulatory agency, masonry walls around lift stations shall require barbed wire at the top of the wall. At TWA's discretion, alternative anti-climb measures may also be utilized in place of barbed wire, however, signage will be required on all exterior walls indicating the use of anti-climb measures that may not be visible.
- All permanent structures including, but not limited to: building foundations, walls, and light poles shall be placed with a minimum 10' horizontal separation from all TWA owned infrastructure.



Bowman Consulting Group, Ltd.  
 4450 W. Eau Gallie Blvd  
 Suite 252  
 Melbourne, FL 32934  
 Phone: (321) 255-5454  
 Fax: (321) 255-1751  
 www.bowmanconsulting.com  
 © Bowman Consulting Group, Ltd.  
 Certificate of Authorization License No. 90462

FLORIDA

TWA-STANDARD CONSTRUCTION NOTES  
 KISSIMMEE 7-ELEVEN #38227  
 SW C/O CARROLL ST. AND DYER BLVD.  
 KISSIMMEE, FL 34741  
 OSCEOLA COUNTY



ANDREW J. PETERSEN  
 LICENSE NO. 75493  
 01/03/2018  
 PLAN STATUS

| DATE      | DESCRIPTION                   |
|-----------|-------------------------------|
| AW DESIGN | EC DRAWN                      |
|           | AJP CHKD                      |
| SCALE     | NONE                          |
| JOB No.   | 010063-02-087                 |
| DATE      | 01/03/2018                    |
| FILED     | 0063-02-0-CP-087-10-010-02100 |
| SHEET     | D1.0                          |

DRC #17-00138