



Symbol	Qty	Label	Arrangement	LLF	Description	Arr. Watts	Arr. Lum. Lumens
SG3D1_18	1	SG3D1_18	SINGLE	1.000	1.000 SG3D1-18 1-Color	257	19900
2ft Batten	1	2ft Batten	SINGLE	1.000	1.000 GE 24 4100K Batten Strip GEW1109641BAT-SY	8.34	768
D3G3D1	5	D3G3D1	2 @ 90 DEGREES_1	1.000	2-ERS2-0-G3D1-1-50-1-	514	39800
ECBBB	30	ECBBB	SINGLE	1.000	1.000 ECBB085F55-AWHITE	64	8110
4ft batten	1	4ft batten	SINGLE	1.000	1.000 GE 48 4100K Batten Strip GEW1104841BAT-SY	16.68	1536
8ft Batten	4	8ft Batten	SINGLE	1.000	1.000 GE 96 4100K Batten Strip GEW1109641BAT-SY	33	3073
EM	2	EM	SINGLE	1.000	1.000 LEDPRS-BR-CL (Phillips)	20	32
EWS3 E3	6	EWS3 E3	SINGLE	1.000	1.000 EWS3_E3D150	90	8600
EWS3 A7	4	EWS3 A7	SINGLE	1.000	1.000 EWS3_A7D150-120-277V	25	2900

Label	Calc Type	Units	Avg	Max	Min	Avg/Min	Max/Min
Air Pump	Illuminance	Fc	10.10	10.1	10.1	1.00	1.00
Dump	Illuminance	Fc	10.20	15.2	5.8	1.76	2.62
Entrance 1	Illuminance	Fc	10.28	16.1	5.0	2.06	3.22
Entrance 2	Illuminance	Fc	10.58	18.2	3.8	2.78	4.79
Gas Canopy	Illuminance	Fc	30.96	43.3	19.7	1.57	2.20
General Approach	Illuminance	Fc	5.60	26.0	0.3	18.67	86.67
Parking 1	Illuminance	Fc	10.58	22.5	3.4	3.11	6.62
Parking 2	Illuminance	Fc	10.63	25.2	3.0	3.54	8.40
Parking 3	Illuminance	Fc	10.55	24.6	2.4	4.40	10.25
Property Line	Illuminance	Fc	1.36	12.4	0.0	N.A.	N.A.

bates
 106 N 37TH STREET, SUITE C
 ROGERS, ARKANSAS 72756
 WWW.BATESPROJECTS.COM
 TEL: 479.633.3333

Florida Certified Authority #12366
 Copyright © 2017 Bates Projects, Inc. All rights reserved. No part of this document may be reproduced, stored in a retrieval system, or transmitted in any form or by any means, electronic, mechanical, photocopying, recording, or by any information storage and retrieval system, without the prior written permission of Bates Projects, Inc. This document is the property of Bates Projects, Inc. and is loaned to you for your use only. It is not to be used on other projects or for any other purpose without the prior written permission of Bates Projects, Inc. Bates Projects, Inc. is not responsible for construction errors, omissions, or delays, or for safety precautions and other matters not shown on this drawing.

STORE #:
38227

CONSTRUCTION MANAGER
 CREGHTON CONSTRUCTION & MANAGEMENT, LLC
 900 SW PINE ISLAND ROAD, SUITE 202
 CAPE CORAL, FL 33991

TENANT
 7-ELEVEN INC.
 3200 HACKBERRY ROAD
 IRVING, TX 75063
 CONTACT: DANIEL TUBB
 STRUCTURAL CONSULTANT
 SELECT STRUCTURAL
 12573 NEW BRITANNY BLVD FORT MYERS, FL 33907

PROTO:08-21-2017

7-ELEVEN STORE
 SW CO CARROLL ST. & DYER BLVD.
 KISSIMMEE, FL 34741

CREGHTON CONSTRUCTION & MANAGEMENT, LLC
 900 SW PINE ISLAND ROAD, SUITE 202
 CAPE CORAL, FL 33991

Engineer Name - ANDREW D FINNEGAN
 Engineer Number - 80051

THE SEAL AND SIGNATURE APPLY ONLY TO THE DOCUMENT TO WHICH THEY ARE APPLIED AND WE EXPRESSLY DISCLAIM ANY RESPONSIBILITY FOR ALL OTHER PLANS, SPECIFICATIONS, ESTIMATES, REPORTS OR OTHER DOCUMENTS OR INSTRUMENTS RELATING TO OR INTENDED TO BE USED FOR ANY PART OF THE PROJECT.

REVISIONS	
NO.	DESCRIPTION

PROJECT NUMBER: 17111
 RELEASE DATE: 12/19/2017

SITE PHOTOMETRICS

E02

Order Plans @ www.dolline.com

1 SITE PHOTOMETRICS
 E02 N.T.S.