

**LIGHTING GENERAL NOTES:**

- REFER TO ARCHITECTURAL DRAWINGS FOR EXACT LIGHT FIXTURE AND TRACK LOCATIONS.
- ALL NIGHT LIGHTS AND EMERGENCY LIGHTS SHALL BE UNSWITCHED.
- 20A, 120V RECEPTACLE AND LIGHTING CIRCUIT CONDUCTORS OVER 75 FT. LONG SHALL BE #10 AWG. CONDUCTORS IN LIEU OF #12 AWG.
- ALL LIGHT FIXTURES, EXCEPT THE EXIT SIGNS, SHALL BE FURNISHED BY THE OWNER FOR INSTALLATION BY THE ELECTRICAL CONTRACTOR. ELECTRICAL CONTRACTOR SHALL BE RESPONSIBLE FOR THE COMPLETE INSTALLATION OF ALL LIGHT FIXTURES. THIS SHALL INCLUDE, BUT IS NOT LIMITED TO, PROVIDING ALL SUPPORTS, CLIPS, POWER CONNECTIONS, AND SEISMIC BRACING AS REQUIRED BY THE JURISDICTION.
- CAPITOL LIGHT SHALL PROVIDE ALL EXIT SIGNS REQUIRED FOR THIS PROJECT TO BE INSTALLED BY G.C. THIS SHALL INCLUDE ALL EXIT SIGNS SHOWN ON THE PLANS, ALL ADDITIONAL EXIT SIGNS THAT MAY BE REQUIRED BY THE JURISDICTION, NOT SHOWN ON THE PLANS. THE CONTRACTOR SHALL BE RESPONSIBLE FOR VERIFYING WITH THE JURISDICTION, THE REQUIRED LENS COLOR FOR EXIT SIGNS AND THE REQUIRED QUANTITY AND LOCATION FOR EXIT SIGNS.
- INSTALL EXIT SIGNS OVER DOORWAYS TO MAINTAIN 4" SPACING BETWEEN BOTTOM OF SIGN AND TOP OF JAMB, OR AT THE DIRECTION OF THE FIRE DISTRICT.
- ELECTRICAL CONTRACTOR SHALL FULLY COORDINATE AND ADJUST THE LIGHT FIXTURE INSTALLATION SCHEDULE AS REQUIRED TO ACCOMMODATE THE DATE OF DELIVERY OF THE OWNER FURNISHED LIGHT FIXTURES. CONTRACTOR SHALL IMMEDIATELY IDENTIFY AND REPORT ANY SHORTAGE OF FURNISHED MATERIALS TO THE GENERAL CONTRACTOR.
- ELECTRICAL CONTRACTOR SHALL INSTALL ALL TRACK HEADS AT LOCATIONS SHOWN ON PLANS AND ADJUST HEADS AS DIRECTED BY OWNER.
- SEE ARCHITECTURAL DRAWINGS FOR MOUNTING DIMENSIONS AND / OR DETAILS. ARCHITECTURAL SPRINKLERS, SENSORS, AND OTHER CEILING MOUNTED DEVICES, ETC. IF THERE IS ANY CONFLICT NOTIFY THE ARCHITECT IMMEDIATELY. DRAWINGS SUPERSEDE ALL OTHERS. LIGHT FIXTURE POSITIONS TAKE PRECEDENCE OVER DIFFUSERS.
- ELECTRICAL CONTRACTOR SHALL VERIFY AND COORDINATE WITH THE ARCHITECT AND LIGHTING DESIGNER FIXTURE MOUNTING DETAILS AND SIZES BASED ON FIELD CONDITIONS.
- ALL FIXTURES SHALL BE U.L. OR ETL LISTED AND LABELED.
- ELECTRICAL CONTRACTOR TO COORDINATE VOLTAGES.
- ARCHITECT TO VERIFY ALL SPECIFIED FINISHES.
- ELECTRICAL CONTRACTOR SHALL VERIFY AND COORDINATE WITH ARCHITECT AND LIGHTING DESIGNER FIXTURE QUANTITIES AND REPORT THIS INFORMATION TO LIGHTING SUPPLIER.
- FIXTURES SHALL INCLUDE ACCESSORIES FOR INSTALLATION ACCORDING TO LOCAL AND NATIONAL CODES.
- PRIOR TO ORDERING LIGHTING EQUIPMENT, THE CONTRACTOR SHALL VERIFY LOCATIONS AND RECESS DEPTHS.
- LAMPS SHALL BE INSTALLED ACCORDING TO THE ATTACHED FIXTURE SCHEDULE.
- CONTRACTOR SHALL VERIFY FINAL VOLTAGES AND CEILING TRIM COMPATIBILITY PRIOR TO ORDERING FIXTURES.
- PROVIDE APPROVED FIRE-RATED ENCLOSURES FOR LIGHTING FIXTURES LOCATED IN A FIRE-RATED CEILING.
- IN AREAS VISIBLE TO CUSTOMERS, BATTERY ASSEMBLY FOR EMERGENCY AND EXIT LIGHTS SHALL BE CONCEALED AND REMOTE TYPE LIGHT FIXTURES USED.
- CIRCUITS SERVING SIGNS SHALL BE CONNECTED BY A TIME SWITCH.
- PROVIDE PROPER SUPPORT AND MOUNTING ACCESSORIES TO ALL LIGHTING FIXTURES. A #12 GAUGE GALVANIZED TIE WIRE PERMANENTLY ATTACHED TO THE STRUCTURE SHALL BE PROVIDED AT FOUR CORNERS OF EACH FIXTURE MOUNTED IN A GRID OR GYPSUM BOARD TYPE CEILING.

**LED LIGHTING NOTES:**

REMOVE LENS FROM ALL LED LAMPS, INCLUDING TRACK HEADS, CASEWORK LIGHTING ETC.

IN SALES AREA BATTERY PACKS FOR EXIT AND EMERGENCY LIGHTS MUST BE REMOTE OR RECESSED. HUNT EXPOSED SURFACES TO MATCH ADJACENT FINISH.

LIGHTING FIXTURE SCHEDULE							
FIXTURE SYMBOL	FIXTURE	DESCRIPTION	MANUFACT.	LAMP	WATTS	VOLTS	REMARKS
=====	TA	SUSPENDED TRACK, SINGLE CIRCUIT, NATURAL FINISH, LENGTHS PER DRAWINGS, PROVIDE ALL NECESSARY COMPONENTS TO COMPRISE A FULLY FUNCTIONAL SYSTEM.	JUNO T-"LENGTH"-NA		---		SEE NOTE #7, FOR QUANTITY SEE FLOOR PLAN.
▽	TC	JUNO TRACK MOUNTED PAR 30 LED GIMBAL RING SPOT LIGHT NATURAL FINISH	JUNO LIGHTING T363NA	(1) TCP DIMMABLE LED12P30SD27KSP95	12W	120V	SEE NOTES #5, #6, #8 AND #10.
▽	TD	JUNO TRACK MOUNTED PAR 30 LED GIMBAL RING FLOOD LIGHT NATURAL FINISH	JUNO LIGHTING T363NA	(1) TCP DIMMABLE LED12P30SD27KNFL95	12W	120V	SEE NOTES #5, #6, #8 AND #10.
-----	TA2	SUSPENDED TRACK, SINGLE CIRCUIT, WHITE FINISH, LENGTHS PER DRAWINGS, PROVIDE ALL NECESSARY COMPONENTS TO COMPRISE A FULLY FUNCTIONAL SYSTEM.	JUNO T-"LENGTH"-WH		---		SEE NOTE #7, FOR QUANTITY SEE FLOOR PLAN.
○	TC2	JUNO TRACK MOUNTED PAR 30 LED GIMBAL RING SPOT LIGHT WHITE FINISH	JUNO LIGHTING T363WH	(1) TCP DIMMABLE LED12P30SD27KSP95	12W	120V	SEE NOTES #5, #6, #8 AND #10.
●	TD2	JUNO TRACK MOUNTED PAR 30 LED GIMBAL RING FLOOD LIGHT WHITE FINISH	JUNO LIGHTING T363WH	(1) TCP DIMMABLE LED12P30SD27KNFL95	12W	120V	SEE NOTES #5, #6, #8 AND #10.
○	A1	POTTERY BARN BENCHWRIGHT SINGLE SCONCE, OIL RUBBED BRONZE	POTTERY BARN # 6319839	(1) 60W	60W	120V	OWNER PROVIDED POTTERY BARN PRODUCT
○	A2	POTTERY BARN MERCER FLUSHMOUNT, ANTIQUE BRONZE.	POTTERY BARN #1435874	(1) 60W	60W	120V	POLISHED CHROME FINISH 16" DIAMETER x 9.5"D NOMINAL
=====	FA	SUSPENDED 8' FLUORESCENT STRIP WITH WIRE GUARD, 1-LAMP IN CROSS SECTION, 2 LAMPS TOTAL, ELECTRONIC BALLAST, SUSPEND 18" ABOVE CASEWORK	MERcury MM-132-OCT-A-ELB-UNI	(2) F032/830XPS/ECO BY OSRAM SYLVANIA	62W	120V	
=====	FB	SIMILAR TO TYPE FA EXCEPT FURNISHED WITH A EMERGENCY BATTERY PACK CAPABLE OF PROVIDING 1300 LUMENS ON ONE LAMP.	MERcury MM-132-OCT-A-C2.75-ELB-UNI-EMPR/1320	(2) F032/830XPS/ECO BY OSRAM SYLVANIA	62W	120V	
=====	FD	SURFACE MOUNTED FLUORESCENT LAMP AROUND 2-LAMP 1/8" C ACRYLIC PRISMATIC CLEAR LENS NOM. 4'-0" LENGTH, ELECTRONIC BALLAST AND EMERGENCY BATTERY PACK CAPABLE OF PROVIDING 1300 LUMENS ON ONE LAMP.	MERcury M105-23-OCT-A-ELB-UNI-EMPR/1320	(2) F032/830XPS/ECO BY OSRAM SYLVANIA	62W	120V	
○	RC1	RECESSED SINGLE LAMP LED DOWNLIGHT	DMF LIGHTING DRDHNIC4, DRD2M7927, DRD2TR4SWH	DME-6-927-QC LED MODULE	12W	120V	
○	RC2	RECESSED SINGLE LAMP LED DOWNLIGHT PROVIDE WITH EMERGENCY BATTERY BACKUP.	DMF LIGHTING DRDHNIC47TEM, DRD2M7927A, DRD2TR4SWH	DME-6-927-QC LED MODULE	12W	120V	
⚡	E	EMERGENCY LIGHT	MULE LIGHTING MRD-HO-12-54-20	(2) 20W	54W	120V	EMERGENCY ONLY
⚡	EL2	RECESSED EMERGENCY LIGHT W 2-25W HALOGEN LAMPS AND INTEGRAL BATTERY	EVENLITE APR-25-NC-UI-SD	(2) 25W SUPERLUX MR-11 HALOGEN SUPPLIED W/ FIXTURE	50W	120V	DIRECT PURCHASE BY OWNER FROM CAPITOL LIGHT. (CUSTOM COLOR AT ALL WOOD CEILINGS AND WHITE AT ALL GYP. BOARD CEILINGS).
⚡	EX1	SINGLE- OR DOUBLE-FACED EDGE-LIT EXIT SIGN WITH EMERGENCY BATTERY (FOR SALES AREAS, WALL MOUNT)	ASTRA LITE ELX-LNVRG-(1 OR 2) RM-WHT-EM	ALLOW 5 WATTS	5W	120V	
⚡	EX2	SINGLE- OR DOUBLE-FACED EDGE-LIT EXIT SIGN WITH EMERGENCY BATTERY (FOR NON-SALES AREAS, WALL MOUNT)	LIGHT ALARMS QLXN500-RN	ALLOW 5 WATTS	5W	120V	
⊕	PB	CLIFT OVERSIZED GLASS PENDANT.	POTTERY BARN # 6718050	(1) PAR38 40" FLOOD LAMP @ 2700K	13W	120V	OWNER PROVIDED POTTERY BARN PRODUCT
⊕	PD	PB CLASSIC PENDANT - METAL BELL, LARGE BRONZE SHADE AND CORD KIT	POTTERY BARN # 3861903	(1) PAR38 40" FLOOD LAMP @ 2700K	13W	120V	OWNER PROVIDED POTTERY BARN PRODUCT
●	WS	EMMET PENDANT, OIL RUBBED BRONZE	WILLIAMS SONOMA 30-922435	(1) PAR38 40" FLOOD LAMP @ 2700K LED	26W	120V	OWNER PROVIDED POTTERY BARN PRODUCT

GENERAL NOTE: FIXTURE FINISHES TO BE DETERMINED BY ARCHITECT.

OWNER:  
**WILLIAMS-SONOMA, INC.**  
 3250 Van Ness Avenue  
 San Francisco, CA 94109  
 T 415 616 8602  
 F 415 439 8164  
 www.williams-sonomainc.com



EEA Consulting Engineers  
 6615 Vaught Ranch Road, Suite 100  
 Austin, Texas 78730-2314 USA  
 512.744.4400 main 512.744.4444 fax  
 www.eeace.com  
 State of Registration VIRGINIA  
 Firm Registration No. 0407 004734  
 EEA Project No. 20166524

DRAWN BY: BMW  
 CHECKED BY: SAH

**BID DOCUMENT ONLY**  
 Not Intended for Construction or Permit  
 This document is released under the  
 authority of:  
 Registrant's Name: SARA A. HAMILL  
 Serial No. 0402052431

**POTTERY BARN**  
**WILLIAMS-SONOMA**  
 Town Center Virginia Beach  
 173/177 Central Park Avenue  
 Virginia Beach, VA 23462  
 PROJECT #006-151817-00/#006-151412-00

ISSUED / REVISED	DATE
FEASIBILITY SET	08/10/17
PRELIMINARY SET	09/28/17
LL CD SET	11/30/17
PERMIT SET	12/18/17
BID SET	01/04/18

LIGHTING  
 FIXTURE SCHEDULE

**E-002**

Order Plans @