

- POWER GENERAL NOTES**
- A. PROVIDE AND INSTALL RACEWAY AND BOX FOR LV SYSTEMS.
 - B. REFER TO MECHANICAL PLAN SET FOR MECHANICAL EQUIPMENT INFORMATION.
 - C. REFER TO LIGHTING CONTROL PANEL SCHEDULE ON SHEET E-003 FOR CONTROLLED RECEPTACLE CIRCUITS.
 - D. REMOVE ALL EXISTING ELECTRICAL EQUIPMENT NOT SHOWN ON ELECTRICAL PLANS. REMOVE ALL CONDUIT AND CONDUCTORS BACK TO PANEL.


FIRE ALARM SYSTEM SHOWN ON ELECTRICAL DRAWINGS ARE FOR SCHEMATIC AND BIDDING PURPOSES ONLY. FIRE ALARM SYSTEM CONTRACTOR SHALL SUBMIT FIRE DRAWINGS, EQUIPMENT CUT SHEETS, ETC... PER LOCAL CODE AND NFPA72 TO LOCAL AUTHORITIES HAVING JURISDICTION AND OWNER'S INSURANCE COMPANY FOR APPROVAL PRIOR TO ORDERING EQUIPMENT. ENGINEER WILL NOT APPROVE FIRE ALARM DRAWINGS, EQUIPMENT CUT SHEETS, ETC. INCLUDE IN BID ALL COSTS FOR PERMITS AND FEES. ALL PANELS AND PERIPHERAL DEVICES SHALL BE STANDARD PRODUCT OF SINGLE MANUFACTURER AND SHALL DISPLAY THE MANUFACTURER'S NAME ON EACH COMPONENT. CONFIRM FIRE ALARM MODEL WITH LANDLORD.

ALL ABANDONED AND/OR UNUSED COMPONENTS CREATED OR EXPOSED DURING CONSTRUCTION, INCLUDING BUT NOT LIMITED TO HVAC, CABLES, PIPING, WIRING, AND ASSOCIATED SUPPORTS AND/OR ATTACHMENTS SHALL BE REMOVED.

THE FIRE ALARM PLANS ARE A DEFERRED SUBMITTAL AND WILL BE SUBMITTED BY A LICENSED FIRE ALARM CONTRACTOR SUBMITTED BY THE GENERAL CONTRACTOR.

COORDINATE EXACT LOCATION OF FLOOR BOXES WITH ARCHITECTURAL DRAWINGS PRIOR TO ROUGH-IN.

- POWER KEYED NOTES**
- 1 GENERAL PURPOSE RECEPTACLE MOUNTED AT 18" A.F.F.
 - 2 JUNCTION BOX FOR TRAFFIC COUNTER SYSTEM. ROUTE CONDUIT TO TELEPHONE BACKBOARD.
 - 3 NOT USED.
 - 4 REFER TO DETAIL 5 ON SHEET E-202 FOR CORRESPONDING CONDUIT SIZES.
 - 5 - 8 NOT USED.
 - 9 GENERAL PURPOSE RECEPTACLE HORIZONTALLY FLUSH MOUNTED ON WALL AT 42" A.F.F. AT COOKING COUNTER
 - 10 - 12 NOT USED.
 - 13 FIRE ALARM DEVICE. DEVICES TO BE CEILING MOUNTED IN SALES FLOOR AREA.
 - 14 NOT USED.
 - 15 JUNCTION BOX WITH 2" EMPTY CONDUIT FOR WIRELESS MOTION SENSOR COORDINATE MOUNTING HEIGHT WITH ARCHITECT.
 - 16 SMALL CONNECTION SWITCH FOR INSTANTANEOUS ELECTRIC WATER HEATER. PROVIDE FLEXIBLE SEAL TIGHT CONNECTION TO WATER HEATER. SWITCH TO BE LOCATED BELOW SINK ADJACENT TO WATER HEATER. LABEL SWITCH WATER HEATER DISCONNECT.
 - 17 NOT USED.
 - 18 RECEPTACLES AT COOKING COUNTER ARE TO BE INSTALLED WITH A BLACK COVERPLATE.
 - 19 PROVIDE RECESSED DUPLEX RECEPTACLE ABOVE TOP WINDOW MULLION, WITH CENTER AT 18" ABOVE TOP MULLION. IF THE RECEPTACLE NEEDS TO BE LOCATED ON THE WALL, DUE TO SOFFIT / CEILING HEIGHT, THEN THE OUTLETS NEED TO BE PLACED AT THE ENDS OF THE WINDOW AND NOT IN THE CENTER. COORDINATE COLOR WITH GC.
 - 20 NOT USED.
 - 21 ELECTRICAL CONTRACTOR IS TO FURNISH AND INSTALL DOOR BUZZERS, LOW VOLTAGE TRANSFORMER, PUSHBUTTON AND WIRING FOR DOOR BUZZER SYSTEM SEE SPECIFICATIONS. SIZE TRANSFORMERS AS REQUIRED.
 - 22 NOT USED.
 - 23 J-BOX FOR SECURITY KEYPAD. COORDINATE EXACT LOCATION WITH G.C. PRIOR TO ROUGH-IN. PROVIDE 1" C. BACK TO TELEPHONE BACKBOARD.
 - 24 HVAC SENSOR LOCATIONS.
 - 25 PROVIDE FLUSH FLOOR BOX, COMMERCIAL ROLL FORMED PRODUCTS 2000, #C2606-25 (COORDINATE FLOORBOX COLOR WITH ARCHITECT) AND NEMA 5-20R RECEPTACLE. SEE ARCHITECTURAL PLANS FOR EXACT LOCATIONS.
 - 26 FOR DEVICE SHOWN, RUN 1/2" CONDUIT IN FLOOR UNDER LAYMENT SPACE. DO NOT RUN CONDUIT PARALLEL WITH WOOD FLOORING. COORDINATE CONDUIT ROUTING WITH FLOORING CONTRACTOR AND ARCHITECT PRIOR TO LAYOUT TO ACCOMMODATE CONDUIT CUT-OUTS IN PLYWOOD. SEE SPECIFICATION SECTION 3.02.B.5.
 - 27 - 29 NOT USED.
 - 30 BURGLAR ALARM KEYPAD AT 44" A.F.F.
 - 31 - 35 NOT USED.
 - 36 CONDUIT FOR COFFEE BAR TO BE RUN IN DEMISING WALL.



SCALE: 1/4" = 1'-0" @ FULL SIZE

OWNER:
WILLIAMS-SONOMA, INC.
3250 Van Ness Avenue
San Francisco, CA 94109
T 415 616 8602
F 415 439 8164
www.williams-sonoma.com

EEA
EEA Consulting Engineers
6615 Vaught Ranch Road, Suite 100
Austin, Texas 78730-2314 USA
512.744.4400 main 512.744.4444 fax
www.eeace.com
State of Registration VIRGINIA
Firm Registration No. 0407 004734
EEA Project No. 20166524

DRAWN BY: BMW
CHECKED BY: SAH

BID DOCUMENT ONLY
Not Intended for Construction or Permit
This document is released under the
authority of:
Registrant's Name: SARA A. HAMILL
Serial No. 0402052431

P O T T E R Y B A R R I
WILLIAMS-SONOMA
Town Center Virginia Beach
173/177 Central Park Avenue
Virginia Beach, VA 23462
PROJECT #006-151817-00/#006-151412-00

ISSUED / REVISED	DATE
FEASIBILITY SET	08/10/17
PRELIMINARY SET	09/28/17
LL CD SET	11/30/17
PERMIT SET	12/18/17
BID SET	01/04/18

KEYPLAN
N.T.S.
PARTIAL POWER PLAN

E-111

Order Plans