

PANELBOARD HP2 NEMA ENCLOSURE 1 AIC RATING EXISTING
PANEL TYPE AE MOUNTING SURFACE
NOTES EXISTING PANEL TO REMAIN
EXISTING BREAKERS TO REMAIN UNLESS NOTED.

PANELBOARD LP3 NEMA ENCLOSURE 1 AIC RATING EXISTING
PANEL TYPE AQ MOUNTING SURFACE
NOTES EXISTING PANEL TO REMAIN
EXISTING BREAKERS TO REMAIN UNLESS NOTED.

TRANSFORMER LOAD SUMMARY
DESCRIPTION ACTUAL CONNECTED KVA DEMAND FACTOR ACTUAL DEMAND KVA
TRACK 1.25 4.83
LIGHTING 4.11
GEN. PURPOSE RECEPTACLE 20.4

PANEL SCHEDULE KEYED NOTES
NEW BREAKERS TO BE INSTALLED.

NOTE: IT IS THE ELECTRICAL CONTRACTORS RESPONSIBILITY TO PROPERLY BALANCE ALL BRANCH CIRCUITS BETWEEN THE PHASES OF THE SYSTEM, REGARDLESS OF CIRCUITING INDICATED.

PANEL SCHEDULE LEGEND
BREAKER OPTIONS
LO HANDLE LOCK-ON DEVICE
LF HANDLE LOCK-OFF DEVICE

OWNER: WILLIAMS-SONOMA, INC.
3250 Van Ness Avenue
San Francisco, CA 94109
T 415 616 8602
F 415 439 8164
www.williams-sonomainc.com

EEA
EEA Consulting Engineers
6615 Vaughn Ranch Road, Suite 100
Austin, Texas 78730-2314 USA
512.744.4400 main 512.744.4444 fax
www.eeace.com

BID DOCUMENT ONLY
Not Intended for Construction or Permit
This document is released under the authority of:
Registrant's Name: SARA A. HAMILL
Serial No. 0402052431

POTTER HAMIL
WILLIAMS-SONOMA
Town Center Virginia Beach
173/177 Central Park Avenue
Virginia Beach, VA 23462
PROJECT #006-151817-00/#006-151412-00

ISSUED / REVISED DATE
FEASIBILITY SET 08/10/17
PRELIMINARY SET 09/28/17
LL CD SET 11/30/17
PERMIT SET 12/18/17
BID SET 01/04/18