

36	35	34	33	32	31	30	29	28	27	26	25	24	23	22	21	20	19	18	17	16	15	14	13	12	11	10	09	08	07	06	05	04	03	02	01																																																																								
SECTION 09260 - GYPSUM BOARD ASSEMBLIES, CONTINUED PART 3 - EXECUTION 3.1 NON-LOAD-BEARING STEEL FRAMING INSTALLATION A. GENERAL: COMPLY WITH ASTM C 754, AND ASTM C 840 REQUIREMENTS THAT APPLY TO FRAMING INSTALLATION. B. SUSPENDED CEILING AND SOFFIT FRAMING: 1. SUSPEND CEILING HANGERS PLUMB AND FREE FROM CONTACT WITH INSULATION OR OTHER OBJECTS WITHIN CEILING PLENUM THAT ARE NOT PART OF SUPPORTING STRUCTURAL OR CEILING SUSPENSION SYSTEM. SPAY HANGERS ONLY WHERE REQUIRED TO MISS OBSTRUCTIONS AND OFFSET RESULTING HORIZONTAL FORCES BY BRACING, COUNTER-SPLAYING, OR OTHER EQUALLY EFFECTIVE MEANS. 2. WHERE WIDTH OF DUCTS AND OTHER CONSTRUCTION WITHIN CEILING PLENUM PRODUCES HANGER SPACINGS THAT INTERFERE WITH THE LOCATION OF HANGERS REQUIRED TO SUPPORT STANDARD SUSPENSION SYSTEM MEMBERS, INSTALL SUPPLEMENTAL SUSPENSION MEMBERS AND HANGERS IN FORM OF TRAPEZES OR EQUIVALENT DEVICES. SIZE SUPPLEMENTAL SUSPENSION MEMBERS AND HANGERS TO SUPPORT CEILING LOADS WITHIN PERFORMANCE LIMITS ESTABLISHED BY REFERENCED STANDARDS. 3. ATTACH HANGERS TO STRUCTURAL MEMBERS. DO NOT SUPPORT CEILINGS FROM OR ATTACH HANGERS TO PERMANENT METAL FORMS, STEEL DECK TABS, STEEL ROOF DECKS, DUCTS, PIPES, OR CONDUIT. C. PARTITION AND SOFFIT FRAMING: 1. WHERE STUDS ARE INSTALLED DIRECTLY AGAINST EXTERIOR WALLS, INSTALL ISOLATION STRIP BETWEEN STUDS AND WALL. 2. EXTEND PARTITION FRAMING FULL HEIGHT TO STRUCTURAL SUPPORTS OR SUBSTRATES ABOVE SUSPENDED CEILINGS, EXCEPT WHERE PARTITIONS ARE INDICATED TO TERMINATE AT SUSPENDED CEILINGS. CONTINUE FRAMING OVER FRAMES FOR DOORS AND OPENINGS AND FRAME AROUND DUCTS PENETRATING PARTITIONS ABOVE CEILING TO PROVIDE SUPPORT FOR GYPSUM BOARD. 3. FRAME DOOR OPENINGS TO COMPLY WITH GA-600 AND WITH GYPSUM BOARD MANUFACTURER'S APPLICABLE WRITTEN RECOMMENDATIONS, UNLESS OTHERWISE INDICATED. SCREW VERTICAL STUDS AT JAMBS TO JAMB ANCHOR CLIPS ON DOOR FRAMES; INSTALL RUNNER TRACK SECTION (FOR CRIPPLE STUDS) AT HEAD AND CLIP TO JAMB STUDS. a. INSTALL TWO STUDS AT EACH JAMB, UNLESS OTHERWISE INDICATED. 4. FRAME OPENINGS OTHER THAN DOOR OPENINGS THE SAME AS REQUIRED FOR DOOR OPENINGS, UNLESS OTHERWISE INDICATED. INSTALL FRAMING BELOW SILLS OF OPENINGS TO MATCH FRAMING REQUIRED ABOVE DOOR HEADS. NO UNFINISHED GYP. WORK AND WOOD WORK ALLOWED, INCLUDING BEHIND FURNITURE & ANY EQUIPMENT ITEMS. ALL GYPSUM BOARD PARTITIONS SHALL BE TAPED, SPACKLED, AND SANDED SMOOTH WITH NO VISIBLE JOINTS. PAINT AS SPECIFIED. PROVIDE GALVANIZED METAL CORNER BEADS AND SIMILAR CONCEALED TRIM AT ALL EXPOSED EDGES; USE EXPOSED TRIM ONLY AS APPROVED BY ARCHITECT. D. Z-FURRING MEMBERS: ERECT INSULATION VERTICALLY AND HOLD IN PLACE WITH Z-FURRING MEMBERS. 3.2 PANEL PRODUCT INSTALLATION A. GYPSUM BOARD: COMPLY WITH ASTM C 840 AND GA-216.																		SECTION 09650 - RESILIENT FLOORING 1.1 GENERAL A. PROVIDE RESILIENT FLOORING WHERE INDICATED IN THE DRAWINGS AS REQUIRED HEREIN, AND AS NECESSARY FOR A COMPLETE AND PROPER INSTALLATION. THE WORK INCLUDES CALCULATION OF MATERIAL QUANTITY REQUIRED, LEVELING AND PATCHING OF CONCRETE FLOORS, INSTALLATION OF RESILIENT FLOORING AND ACCESSORIES. 1.2 SUBMITTALS A. PRODUCT DATA: FOR EACH PRODUCT INDICATED. PART 2 - PRODUCTS 2.1 MATERIALS A. VINYL COMPOSITION TILE: 12X12X1/8 VCT OR 36"X36" VINYL FLOORING PER FINISH SCHEDULE. B. TRANSITION AND EDGE STRIPS: RUBBER, THICKNESS TO MATCH ADJACENT TILE, TAPERED, OR BULLNOSE EDGE. COLOR PER FINISH SCHEDULE. C. LEVELING COMPOUND: ARDEX SD-1 D. ADHESIVE: WATER RESISTANT, NON-STAINING AS RECOMMENDED BY VCT MANUFACTURER. 2.2 INSTALLATION A. IF FLOOR LEVELING OR PREPARATION IS REQUIRED TO MAKE FLOOR SURFACE READY FOR FINISH WORK, CONTRACTOR SHALL PREPARE FLOOR ARE PER MANUFACTURER'S REQUIREMENTS. B. INSTALL WALL TO WALL AND TO FIXED CABINETS AND UNDER FREESTANDING EQUIPMENT. C. LAY OUT SQUARE, PARALLEL WITH STRAIGHT UNBROKEN JOINT LINES. FIT TIGHTLY AND ACCURATELY TO VERTICAL SURFACE, FLOOR PLATES, THRESHOLDS, EDGING STRIPS WITH CLEAR CUTS. 2.3 CLEANING AND FINISHING A. CLEAN ALL RESILIENT FLOORING THOROUGHLY AND APPLY WAX OF FINISHING MATERIALS IN ACCORD WITH MANUFACTURER'S RECOMMENDATIONS. B. POLISH THOROUGHLY. DELAY CLEANING AND FINISHING UNTIL JUST PRIOR TO DATE OF SUBSTANTIAL COMPLETION.																		SECTION 09681 - TILE CARPETING 1.1 GENERAL A. PROVIDE RESILIENT FLOORING WHERE INDICATED IN THE DRAWINGS AS REQUIRED HEREIN, AND AS NECESSARY FOR A COMPLETE AND PROPER INSTALLATION. THE WORK INCLUDES CALCULATION OF MATERIAL QUANTITY REQUIRED, LEVELING AND PATCHING OF CONCRETE FLOORS, INSTALLATION OF TILE CARPET FLOORING AND ACCESSORIES. PART 2 - PRODUCTS 2.1 MATERIALS A. CARPET TILE TYPE <CT>: AS SCHEDULED, MANUFACTURED IN ONE COLOR DYE LOT. 2.2 ACCESSORIES A. ADHESIVES: ACCEPTABLE TO CARPET TILE MANUFACTURER, COMPATIBLE WITH MATERIALS BEING ADHERED, MAXIMUM VOC CONTENT AS SPECIFIED IN SECTION 01 6116. PART 3 - EXECUTION 3.1 INSTALLATION A. BLEND CARPET FROM DIFFERENT CARTONS TO ENSURE MINIMAL VARIATION IN COLOR MATCH. B. CUT CARPET TILE CLEAN. FIT CARPET TIGHT TO INTERSECTION WITH VERTICAL SURFACES WITHOUT GAPS. C. LAY CARPET TILE IN PATTERN INDICATED.																		SECTION 09653 - RESILIENT BASE 1.1 GENERAL A. PROVIDE RESILIENT BASE WHERE INDICATED IN THE DRAWINGS, AS REQUIRED HEREIN, AND AS NECESSARY FOR A COMPLETE AND PROPER INSTALLATION. THE WORK INCLUDES CALCULATION OF MATERIAL QUANTITY REQUIRED. B. REPLACEMENT MATERIALS: AFTER COMPLETION OF WORK, DELIVER NOT LESS THAN 10 FEET OF EXTRA STOCK TO TENANT. EXTRAS SHALL BE FROM THE SAME BATCH AS THOSE INSTALLED. 1.2 SUBMITTALS A. PRODUCT DATA: FOR EACH PRODUCT INDICATED. PART 2 - PRODUCTS 2.1 MATERIALS A. RESILIENT BASE PER FINISH SCHEDULE. B. ADHESIVE: WATER RESISTANT, NON-STAINING AS RECOMMENDED BY MANUFACTURER. 2.2 INSTALLATION A. INSTALL AROUND CABINETS AND OTHER STANDING EQUIPMENT. B. SET STRAIGHT AND EVEN, JOINTS CLOSELY FITTED AND FLUSH, TOP AND BOTTOM, EDGES IN FIRM, FULL CONTACT WITH FLOOR AND WALL, OR TREADS AND ENTIRE BACKSIDE BONDED TO SUBSTRATE. PREVENT STAINING OF ADJACENT SURFACES. 2.3 CLEANING AND FINISHING: A. CLEAN ALL RESILIENT BASE THOROUGHLY IN ACCORD WITH MANUFACTURER'S RECOMMENDATIONS. B. REMOVE STAINS AND EXCESS ADHESIVE FROM BASE AND ADJACENT SURFACES WITHOUT INJURY TO SURFACES. C. REMOVE ALL SCRAPS AND RUBBISH. SECTION 09775 - FIBER REINFORCED PANEL 1.1 GENERAL A. THIS SECTION INCLUDES FIBER REINFORCED PANEL FOR RESTROOM WALLS AND MOP SINK WALLS. PART 2 - PRODUCT 2.1 MATERIALS A. FRP PANELS TO BE NUDD, INC (OR APPROVED EQUAL) LP-F9-FR .090" THICKNESS. 48" HIGH SHEETS WITH APPROPRIATE ACCESSORIES FOR A COMPLETE INSTALLATION. PART 3 - EXECUTION A. 2 PIECE DIVISION BARS SHALL BE USED AT ALL PANEL ABUTMENTS. B. CORNER ANGLES SHALL BE USED AT ALL CORNERS. C. PANEL CAPS SHALL BE USED THE LENGTH OF THE MATERIAL. D. APPLY SEALANT ALONG TOP EDGES OF PANEL CAPS AT GYP. BOARD TRANSITION. SECTION 09912 - PAINTING PART 1 - GENERAL 1.1 SUMMARY A. HIS SECTION INCLUDES SURFACE PREPARATION AND FIELD PAINTING OF EXPOSED ITEMS AND SURFACES. 1.2 PROJECT CONDITIONS A. STORE MATERIALS NOT IN USE IN TIGHTLY COVERED CONTAINERS IN A WELL-VENTILATED AREA AT A MINIMUM AMBIENT TEMPERATURE OF 45 DEG F. MAINTAIN STORAGE CONTAINERS IN A CLEAN CONDITION, FREE OF FOREIGN MATERIALS AND RESIDUE. B. APPLY WATERBORNE PAINTS ONLY WHEN TEMPERATURES OF SURFACES TO BE PAINTED AND SURROUNDING AIR ARE BETWEEN 50 AND 90 DEG. C. APPLY SOLVENT-THINNED PAINTS ONLY WHEN TEMPERATURES OF SURFACES TO BE PAINTED AND SURROUNDING AIR ARE BETWEEN 45 AND 95 DEGREES FAHRENHEIT. D. FOR SUSTAINABILITY PAINT IS TO BE A PRODUCT AND FROM A MANUFACTURER ACCEPTED BY THE CALIFORNIA HIGH PERFORMANCE SCHOOLS PROGRAM. WEBSITE IS HTTP://WWW.CHPS.NET 1.3 EXTRA MATERIALS A. FURNISH EXTRA PAINT MATERIALS FROM THE SAME PRODUCTION RUN AS THE MATERIALS APPLIED AND IN THE QUANTITIES DESCRIBED BELOW. PACKAGE WITH PROTECTIVE COVERING FOR STORAGE AND IDENTIFY WITH LABELS DESCRIBING CONTENTS. DELIVER EXTRA MATERIALS TO OWNER. 1. QUANTITY: THREE PERCENT, BUT NOT LESS THAN 1 GAL OF EACH MATERIAL AND COLOR APPLIED. PART 2 - PRODUCTS 2.1 MANUFACTURERS A. PRODUCTS: AS LISTED IN THE FINISH SCHEDULE. 1. BENJAMIN MOORE & CO. (BENJAMIN MOORE). 2. SHERWIN-WILLIAMS CO. (SHERWIN-WILLIAMS). 3. GLIDDEN CO. (THE GLIDDEN COMPANY). 4. PPG INDUSTRIES INC. (PPG). 5. OR EQUAL AS APPROVED BY SPRINT PROJECT MANAGER 2.2 PAINT MATERIALS, GENERAL A. MATERIAL COMPATIBILITY: PROVIDE BLOCK FILLERS, PRIMERS, AND FINISH-COAT MATERIALS THAT ARE COMPATIBLE WITH ONE ANOTHER AND WITH THE SUBSTRATE INDICATED UNDER CONDITIONS OF SERVICE AND APPLICATION, AS DEMONSTRATED BY MANUFACTURER BASED ON TESTING AND EXPERIENCE. B. MATERIAL QUALITY: PROVIDE MANUFACTURER'S BEST-QUALITY PAINT MATERIALS OF VARIOUS COATING TYPES SPECIFIED THAT ARE FACTORY FORMULATED AND RECOMMENDED BY THE MANUFACTURER FOR APPLICATION INDICATED. PAINT-MATERIAL CONTAINERS NOT DISPLAYING MANUFACTURER'S PRODUCT IDENTIFICATION WILL NOT BE ACCEPTABLE. C. COLORS: AS CALLED OUT IN FINISH SCHEDULE. 2.3 INTERIOR FINISH COATS A. INTERIOR SEMI-GLOSS ALKID ENAMEL: 1. AS CALLED OUT IN FINISH SCHEDULE. 2.4 PREPARATORY COATS PART 3 - EXECUTION 3.1 APPLICATION A. EXAMINE SUBSTRATES, AREAS, AND CONDITIONS, WHEN APPLICABLE PRESENT, FOR COMPLIANCE WITH REQUIREMENTS FOR PAINT APPLICATION. B. COORDINATION OF WORK: REVIEW OTHER SECTIONS IN WHICH PRIMERS ARE PROVIDED TO ENSURE COMPATIBILITY OF THE TOTAL SYSTEM FOR VARIOUS SUBSTRATES. ON REQUEST, FURNISH INFORMATION ON CHARACTERISTICS OF FINISH MATERIALS TO ENSURE USE OF COMPATIBLE PRIMERS. C. REMOVE HARDWARE AND ACCESSORIES, PLATES, MACHINED SURFACES, LIGHTING FIXTURES, AND MILLWORK ALREADY INSTALLED THAT ARE NOT TO BE PAINTED. IF REMOVAL IS IMPRACTICAL, AS POSSIBLE BECAUSE OF SIZE OR WEIGHT OF THE ITEM, PROVIDE SURFACE-APPLIED PROTECTION BEFORE SURFACE PREPARATION AND PAINTING. 1. AFTER COMPLETION OF PAINTING OPERATIONS IN EACH SPACE OR AREA, REINSTATE ITEMS REMOVED USING WORKERS EMPLOYED IN THE TRADES INVOLVED. D. SURFACE PREPARATION: CLEAN AND PREPARE SURFACES TO BE PAINTED ACCORDING TO MANUFACTURER'S WRITTEN INSTRUCTIONS FOR EACH PARTICULAR SUBSTRATE CONDITION AND AS SPECIFIED. 1. PRIME BARRIER COATS OVER INCOMPATIBLE PRIMERS OR REMOVE AND REPRIME. 2. FERROUS METALS: CLEAN UNGALVANIZED FERROUS-METAL SURFACES THAT HAVE NOT BEEN SHOP PRIME COATED, REMOVE OIL, GREASE, DIRT, LOOSE MILL SCALE, AND OTHER FOREIGN SUBSTANCES. USE SOLVENT OR MECHANICAL CLEANING METHODS THAT COMPLY WITH SSPC'S RECOMMENDATIONS. a. TREAT BARE AREAS AND SHOP-APPLIED PRIME COATS THAT HAVE BEEN DAMAGED. b. TOUCH UP BARE AREAS AND SHOP-APPLIED PRIME COATS THAT HAVE BEEN DAMAGED. WIRE-BRUSH, CLEAN WITH SOLVENTS RECOMMENDED BY PAINT MANUFACTURER, AND TOUCH UP WITH SAME PRIMER AS THE SHOP COAT. 3. GALVANIZED SURFACES: CLEAN GALVANIZED SURFACES WITH NONPETROLEUM-BASED SOLVENTS SO SURFACE IS FREE OF OIL AND SURFACE CONTAMINANTS. REMOVE PRETREATMENT FROM GALVANIZED SHEET METAL FABRICATED FROM COIL STOCK BY MECHANICAL METHODS. E. MATERIAL PREPARATION: 1. MAINTAIN CONTAINERS USED IN MIXING AND APPLYING PAINT IN A CLEAN CONDITION, FREE OF FOREIGN MATERIALS AND RESIDUE. 2. STIR MATERIAL BEFORE APPLICATION TO PRODUCE A MIXTURE OF UNIFORM DENSITY. STIR AS REQUIRED DURING APPLICATION. DO NOT STIR SURFACE FILM INTO MATERIAL. IF NECESSARY, REMOVE SURFACE FILM AND STRAIN MATERIAL BEFORE USING. F. EXPOSED SURFACES: INCLUDE AREAS VISIBLE WHEN PERMANENT OR BUILT-IN FIXTURES, GRILLES, CONVECTOR COVERS, AND SIMILAR COMPONENTS ARE IN PLACE. EXTEND COATINGS IN THESE AREAS, AS REQUIRED, TO MAINTAIN SYSTEM INTEGRITY AND PROVIDE DESIRED PROTECTION. 1. PAINT SURFACES BEHIND MOVABLE EQUIPMENT AND FURNITURE THE SAME AS SIMILAR EXPOSED SURFACES BEFORE FINAL INSTALLATION OF EQUIPMENT, PAINT SURFACES BEHIND PERMANENTLY FIXED EQUIPMENT OR FURNITURE WITH PRIME COAT ONLY. 2. PAINT INTERIOR SURFACES OF DUCTS WITH A FLAT, NON-SPECULAR BLACK PAINT WHERE VISIBLE THROUGH REGISTERS OR GRILLES. 3. PAINT BACK SIDES OF ACCESS PANELS AND REMOVABLE OR HINGED COVERS TO MATCH EXPOSED SURFACES. 4. FINISH EXTERIOR DOORS ON TOPS, BOTTOMS, AND SIDE EDGES THE SAME AS EXTERIOR FACES.																		G. SCHEDULING PAINTING: APPLY FIRST COAT TO SURFACES THAT HAVE BEEN CLEANED, PRETREATED, OR OTHERWISE PREPARED FOR PAINTING AS SOON AS PRACTICABLE AFTER PREPARATION AND BEFORE SUBSEQUENT SURFACE DETERIORATION. 1. OMIT PRIMER OVER METAL SURFACES THAT HAVE BEEN SHOP PRIMED AND TOUCH-UP PAINTED. 2. IF UNDERCOATS, STAINS, OR OTHER CONDITIONS SHOW THROUGH FINAL COAT OF PAINT, APPLY ADDITIONAL COATS UNTIL PAINT FILM IS OF UNIFORM FINISH, COLOR, AND APPEARANCE. H. APPLICATION PROCEDURES: APPLY PAINTS AND COATINGS BY BRUSH, ROLLER, SPRAY, OR OTHER APPLICATORS ACCORDING TO MANUFACTURER'S WRITTEN INSTRUCTIONS. I. MINIMUM COATING THICKNESS: APPLY PAINT MATERIALS NO THINNER THAN MANUFACTURER'S RECOMMENDED SPREADING RATE. PROVIDE TOTAL DRY FILM THICKNESS OF THE ENTIRE SYSTEM AS RECOMMENDED BY MANUFACTURER. J. PRIME COATS: BEFORE APPLYING FINISH COATS, APPLY A PRIME COAT, AS RECOMMENDED BY MANUFACTURER, TO MATERIAL THAT IS REQUIRED TO BE PAINTED OR FINISHED AND THAT HAS NOT BEEN PRIME COATED BY OTHERS. RECOAT PRIMED AND SEALED SURFACES WHERE EVIDENCE OF SUCTION SPOTS OR UNSEALED AREAS IN FIRST COAT APPEARS, TO ENSURE A FINISH COAT WITH NO BURN-THROUGH OR OTHER DEFECTS DUE TO INSUFFICIENT SEALING. 3.2 CLEANING AND PROTECTING A. AT THE END OF EACH WORKDAY, REMOVE EMPTY CANS, RAGS, RUBBISH, AND OTHER DISCARDED PAINT MATERIALS FROM PROJECT SITE. B. PROTECT WORK OF OTHER TRADES, WHETHER BEING PAINTED OR NOT, AGAINST DAMAGE FROM PAINTING. CORRECT DAMAGE BY CLEANING, REPAIRING OR REPLACING, AND REPAINTING, AS APPROVED BY ARCHITECT. C. PROVIDE "WET PAINT" SIGNS TO PROTECT NEWLY PAINTED FINISHES. AFTER COMPLETING PAINTING OPERATIONS, REMOVE TEMPORARY PROTECTIVE WRAPPINGS PROVIDED BY OTHERS TO PROTECT THEIR WORK. 1. AFTER WORK OF OTHER TRADES IS COMPLETE, TOUCH UP AND RESTORE DAMAGED OR DEFACED PAINTED SURFACES, COMPLY WITH PROCEDURES SPECIFIED IN PDCA P1. 3.3 INTERIOR PAINT SCHEDULE A. WOOD: 1ST COAT PRIMER/FILLER/AS REQUIRED 2ND COAT INTERIOR SEMI-GLOSS ENAMEL B. METAL: 1ST COAT PRIMER 2ND COAT INTERIOR SEMI-GLOSS ENAMEL 3RD COAT INTERIOR SEMI-GLOSS ENAMEL C. CONCRETE: 1ST COAT CONCRETE SEALER D. WOOD DOORS: 1ST COAT PRIMER/FILLER/AS REQUIRED 2ND COAT INTERIOR SEMI-GLOSS ENAMEL E. GYPSUM BOARD: 1ST COAT PRIMER 2ND/3RD COAT INTERIOR SEMI-GLOSS ENAMEL SECTION 10000 - MISCELLANEOUS SPECIALTIES 1.1 SIGNS A. OWNER SHALL PROVIDE EXTERNAL SIGNAGE AND INSTALLATION. SIGN SUBCONTRACTOR RESPONSIBLE FOR ALL PERMITS AND ZONING ISSUES AS REQUIRED. CONTRACTOR TO COORDINATE LOCATION OF POWER FOR SIGNAGE. B. INTERIOR ACCESSIBILITY SIGNS PER DRAWINGS. 1.2 FIRE EXTINGUISHER A. GENERAL CONTRACTOR TO PROVIDE SURFACE MOUNTED FIRE EXTINGUISHER (5 LBS. TYPE ABC, MANUFACTURER - KIDD, GRANGIER OR EQUAL) MUST HAVE CURRENT INSPECTION TAGS ATTACHED. SECTION 10801 - TOILET AND BATH ACCESSORIES 1.1 MANUFACTURERS A. BOBRICK OR APPROVED EQUAL AS APPROVED BY THE SPRINT PROJECT MANAGER. TYPE 304 STAINLESS STEEL, TYPICAL. B. WALL MOUNTED PAPER TOWEL DISPENSER SHALL BE GEORGIA PACIFIC MODEL NO. 59462 (CALL STAPLES CUSTOMER SERVICE AT 800-368-1001, REFERENCE ACCOUNT #070011689NAT) C. SOAP DISPENSER SHALL BE BOBRICK MODEL NO. B-221. D. NAPKIN DISPENSER SHALL BE BOBRICK MODEL NO. B-684. E. TOILET TISSUE DISPENSER SHALL BE BOBRICK MODEL NO. B-221. F. GRAB BARS SHALL BE BOBRICK MODEL NO. B-206 X 18, 36 AND 48 INCH. ALL GRAB BARS SHALL BE SECURELY ANCHORED WITH THE MANUFACTURER'S RECOMMENDED MOUNTING KIT FOR APPROPRIATE TYPE OF CONSTRUCTION AND WILL SUPPORT LOADS IN EXCESS OF 900 POUNDS. MIRRORS SHALL BE BOBRICK MODEL NO. B-293 SERIES TILT MIRROR 1836 OR APPROVED EQUAL. H. TUB COVER SHALL BE BOBRICK MODEL NO. B-221. I. TUB HOOK SHALL BE BOBRICK MODEL NO. B-233. J. MIRROR BRIM HOLDER SHALL BE BOBRICK MODEL NO. B-223. 1.2 INSTALLATION A. INSTALL WHEREVER USING FASTENERS APPROPRIATE TO SUBSTRATE INDICATED AND RECOMMENDED BY UNIT MANUFACTURER. INSTALL UNITS LEVEL, PLUMB, AND FIRMLY ANCHORED IN LOCATIONS AND AT HEIGHTS INDICATED. B. ADJUST ACCESSORIES FOR UNENCUMBERED, SMOOTH OPERATION AND VERIFY THAT MECHANISMS FUNCTION PROPERLY. REPLACE DAMAGED OR DEFECTIVE ITEMS. REMOVE TEMPORARY LABELS AND PROTECTIVE COATINGS. SECTION 12000 - FURNISHINGS 1.4 GENERAL A. CONTRACTOR SHALL COORDINATE THE DELIVERY AND INSTALLATION OF FIXTURES AND OTHER ITEMS SUPPLIED, AND INSTALLED BY THE TENANTS VENDORS. B. CONTRACTOR SHALL ASSEMBLE AND INSTALL FURNISHINGS PROVIDED BY SPRINT PCS, INCLUDING FURNITURE, SHELVING SYSTEM, TELEVISIONS, DVDS, AND TECH BENCHES.																		A ARCHITECTURAL AB ANCHOR BOLT AC ACOUSTICAL CEILING AFF ABOVE FINISH FLOOR ACOUS ACOUSTICAL ADJ ADJACENT ADJUSTABLE ALUM ALUMINUM ALT ALTERNATE AP ACCESS PANEL APPROX APPROXIMATE ARCH ARCHITECTURAL BD BOARD BLDG BUILDING BLK BLOCK BLKG BLOCKING BM BEAM BO BOTTOM OF BOT BOTTOM CAB CABINET CEM CEMENT CER CERAMIC CG CORNER GUARD CJ CONTROL JOINT CL CLOSET CLKG CAULKING CLNG CEILING CLR CLEAR CMU CONCRETE CON CONCRETE CONC CONSTRUCTION CONR CONCRETE CORR CORRUGATED CT CARPET TILE CTR CENTER CD CENTER LINE DESIGN CONTROL DRAWINGS DET, DTL DETAIL DIA DIAMETER DIFF DIFFUSER DIM DIMENSION DISP DISPENSER DN DOWN DOOR DOOR OPENING DOOR DOOR DWG(S) DRAWING, DRAWINGS DWR DRAWER E EAST EAST EAST EA EACH EXT EXTERIOR EIFS EXTERIOR INSULATION FINISH SYSTEM EJ EXPANSION JOINT ELEV ELEVATION ELEC ELECTRIC, ELECTRICAL EMER EMERGENCY ENCL ENCLOSURE EQ EQUAL EQUIP EQUIPMENT EWC ELECTRIC WATER COOLER EXH EXHAUST EXIST EXISTING EXP EXPANDED EXT EXTERIOR FA FIRE ALARM FD FLOOR DRAIN FDN FOUNDATION FE FIRE EXTINGUISHER FEC FIRE EXTINGUISHER CABINET FIN FINISH FIXT FIXTURE FLR FLOOR FLASH FLASHING FLUOR FLUORESCENT FOC FACE OF CONCRETE FOF FACE OF FINISH FOS FACE OF STUDS FOW FACE OF WALL FR FIRE FRP RATED/RETARDANT FIBERGLASS REINFORCED POLYESTER FIRE RETARDANT TREAT WOOD FT FOOT, FEET FURR FURRING G GROUND GALV GALVANIZED GB GRAB BAR GFR GENERAL CONTRACTOR GLASS GLASS GRND GROUND GWB GYPSUM WALLBOARD H HOLE HOB HOSE BIBB HC HANDICAPPED HD HEAD HDWR HARDWOOD HARDWARE HM HOLLOW METAL HORIZ HORIZONTAL HR HOUR HT HEIGHT HVAC HEATING, VENTILATING, AIR CONDITIONING ID INSIDE DIAMETER INCH INCH INSUL INSULATION INT INTERIOR JAN JANITOR JOIST JOIST JOINT JOINT KIT FIRST AID KIT KP KICK PLATE LAM LAMINATE LAVATORY LAVATORY LVT LIGHT MACH MACHINE MATL MATERIAL MAX MAXIMUM MECH MECHANICAL MEMB MEMBRANE MFR MANUFACTURER MIN MINIMUM MR MIRROR MISC MISCELLANEOUS MASONRY MASONRY OPENING MOUNTED MOUNTED MTG MEETING MNTG MOUNTING MTL METAL MUL MULLION NEO NEOPRENE NIC NOT IN CONTRACT NO NUMBER NOM NOMINAL NTS NOT TO SCALE OC ON CENTER OD OUTSIDE DIAMETER OFF OFFICE OPNG OPENING OPP OPPOSITE P PAINT PL PLATE PLY LAM PLYWOOD LAMINATE PNL PANEL PNLW PANEL PANEL BOARD PAIR PAIR PROJ PROJECT PROP PROPERTY PWR POWER QT QUANTITY R RISE RAD RADIUS RD ROOF DRAIN RE REFER TO REFL REFLECTED REINF REINFORCED REQ REQUIRED RF RESILIENT FLOORING RM ROOM ROUGH OPENING S SOUTH SC SOLID CORE SCHED SCHEDULE SD SOAP DISPENSER SECT SECTION SF SQUARE FEET SH SHELF SHT SHEET SIM SIMILAR SPEC SPECIFICATION SQ SQUARE SS STAINLESS STEEL STD STANDARD STL STEEL STOR STORAGE STRUCT STRUCTURAL SUSP SUSPENDED T TEMPERED TILE TILE TEL TELEPHONE TO TOP OF TOILET TISSUE DISPENSER TYP TYPICAL UNO UNUS NOTED OTHERWISE OTHERWISE VCT VINYL COMPOSITION TILE VERT VERTICAL VEST VESTIBULE W WITH W/O WITHOUT WC WATER CLOSET WD WOOD WP WATERPROOF WT WEIGHT																	



2000 SHAWNEE MISSION PARKWAY
STE 100 MISSION WOODS, KS 66205
TEL 816 502 1500 FAX 816 842 1878

Sprint

#1641 WHITEHAVEN PLAZA
4088 ELVIS PRESLEY BLVD.
SUITE 104
MEMPHIS, TENNESSEE 38116

MATTHEW MASLONS - ARCHITECT
TENNESSEE # 102605

I have prepared the drawings and assume responsibility for the sheets numbered with an "A" prefix for the project named below. I do not take responsibility for the compliance of these areas with the laws of the above governmental entities. The architect is not responsible for materials, components or equipment, as well as the method in which they are installed on the project by others. The architect is not liable or responsible for construction, during construction or upon completion of construction. The architect is not responsible for improper operation due to faulty installation or product failure during construction or after completion of construction when operation has begun for the landlord or tenant.

The licensed professional whose stamp appears on sheets other than those specifically noted above shall be responsible for those items in paragraph three.

ABBREVIATIONS J01

1	WALL TYPE	100'-0"	ELEVATION INDICATOR	NEW WALL
A	FURNITURE, FIXTURE OR EQUIPMENT TYPE		DETAIL INDICATOR	EXISTING WALL TO REMAIN
X30 A101	INTERIOR SECTION NUMBER SHEET NUMBER		ELEVATION TAG	EXISTING WALL TO BE REMOVED
A	WINDOW TYPE	X30 A101	INTERIOR ELEVATION NUMBER SHEET NUMBER	101 DOOR NUMBER
A	SPECIALTY TYPE	A1 A2 A3	INTERIOR ELEVATION NUMBER SHEET NUMBER	NEW DOOR
A	REVISION NUMBER	X30 A101	DETAIL NUMBER SHEET NUMBER	EXISTING DOOR TO REMAIN
OFFICE 101	ROOM NAME AND NUMBER	X30 A101	EXTERIOR ELEVATION NUMBER SHEET NUMBER	EXISTING DOOR TO BE REMOVED
	BREAK LINE			NORTH ARROW
ε	CENTER LINE			
A	COLUMN NUMBER	X30 A101	EXTERIOR SECTION NUMBER SHEET NUMBER	
○ DN	STAIR DIRECTION INDICATOR			

SYMBOLS LEGEND A01

SPECIFICATIONS

SHEET TITLE

PROJECT NUMBER: 2017014066

SHEET AUTHOR: RM

DATE: JANUARY 5, 2017

SHEET NUMBER: **A03**

RMTA.BIZ