Store No.: GA414
KMA: ATLANTA

DESIGN AMBIENT: 100 ALTITUDE: 417
VOLTAGE: 208V

BY: E BEARS 10/27/17 10/19/17
REV. 1: E BEARS 1/15/18 1/15/18

UNIT	QNTY	L	W	H	CASE/COIL MODEL	DESCRIPTION	DEPT	START	eMMD TEMP	EVAP TEMP	LOAD (BTUH)	SUCTION CONN.	DEFROST TYPE	DEFROST REFRIG	TOTAL LOAD	CONTROLLED UNIT INFORMATION: CONFIGURATION	HP	SHOT TEMP	CAPACITY	TYPE	EFFICIENCY LOADED
PA																R448A					
	1	3	QTY		RSM6L7S4-UEZ0-S	5 DOOR GLS., LOW TEMP, NARROW	GROC.	EA		-11	16.4		1	ELECTEMP							
	2	3	QTY		RSM6L7S4-UEQ0-S	5 DOOR GLS., LOW TEMP, NARROW	GROC.	EA		-11	16.4		1	ELECTEMP							
	1	1	QTY		RSM6L7S4-UEQ0-S	5 DOOR GLS., LOW TEMP, NARROW	GROC.	EA		-11	3.3		1	ELECTEMP							
	3				2A6A1B SPARE																
	4	2	QTY		RLM6L4F-UEQ0-S	5 DOOR GLS., ICE CREAM TEMP, NARROW	GROC.	EA		-19	11.8		1	ELECTEMP							
	5	4	QTY		RLM6L4F-UEQ0-S	5 DOOR GLS., ICE CREAM TEMP, NARROW	GROC.	EA		-19	23.2		1	ELECTEMP							
	6	1	QTY		RLM6L3F-UEQ0-S	5 DOOR GLS., ICE CREAM TEMP, NARROW	GROC.	EA		-16	3.5		1	ELECTEMP							
	7	1	QTY		RLM6L4S-UEQ0-S	5 DOOR GLS., ICE CREAM TEMP, NARROW	GROC.	EA		-18	5.5		1	ELECTEMP							
	8	1	QTY		RLM6L4F-UEQ0-S	5 DOOR GLS., ICE CREAM TEMP, NARROW	GROC.	EA		-19	3.5		1	ELECTEMP							
	9	1	QTY		RLM6L3F-UEQ0-S	5 DOOR GLS., ICE CREAM TEMP, NARROW	GROC.	EA		-16	3.5		1	ELECTEMP							
	10	1	QTY		FNM6T-ES-12	12' NARROW ISLAND, MED TEMP	DAIRY	NEW		19	3.3	ORBITREVR	1	ELECTEMP							
	11	1	QTY		FNM6T-ES-12	12' NARROW ISLAND, MED TEMP	DAIRY	NEW		19	3.3	ORBITREVR	1	ELECTEMP							
	12	2	QTY		FNM6T-ES-12	12' NARROW ISLAND, MED TEMP	DAIRY	NEW		19	6.6	ORBITREVR	1	ELECTEMP							
															97.8				126.6		77.2%
																ESS SNC Air Cooled Condenser					
																HUB084ANN-LAVK-232150, 16.19 nominal/up to capacity, 68 compressor, 11.11 TD footpoint					
B																R448A					
	1A	1	QTY		RSM6L7S4-UEQ0-S	5 DOOR GLS., LOW TEMP, NARROW	GROC.	EA		-11	3.3		1	ELECTEMP							
	1B	1	QTY		RSM6L7S4-UEZ0-S	5 DOOR GLS., LOW TEMP, NARROW	GROC.	EA		-11	5.5		1	ELECTEMP							
	2A	1	QTY		RSM6L7S4-UEQ0-S	5 DOOR GLS., LOW TEMP, NARROW	GROC.	EA		-11	5.5		1	ELECTEMP							
	2B	1	QTY		RSM6L7S4-UEZ0-S	5 DOOR GLS., LOW TEMP, NARROW	GROC.	EA		-11	5.5		1	ELECTEMP							
	3A	1	QTY		RSM6L7S4-UEZ0-S	5 DOOR GLS., LOW TEMP, NARROW	GROC.	EA		-11	5.5		1	ELECTEMP							
	3B	1	QTY		RSM6L7S4-UEQ0-S	5 DOOR GLS., LOW TEMP, NARROW	GROC.	EA		-11	5.5		1	ELECTEMP							
	4A	1	QTY		RSM6L7S4-UEQ0-S	5 DOOR GLS., LOW TEMP, NARROW	GROC.	EA		-11	5.5		1	ELECTEMP							
	4B	1	QTY		RSM6L7S4-UEQ0-S	5 DOOR GLS., LOW TEMP, NARROW	GROC.	EA		-11	5.5		1	ELECTEMP							
	5A	1	QTY		RSM6L7S4-UEQ0-S	5 DOOR GLS., LOW TEMP, NARROW	GROC.	EA		-11	5.5		1	ELECTEMP							
	5B	1	QTY		RSM6L7S4-UEZ0-S	5 DOOR GLS., LOW TEMP, NARROW	GROC.	EA		-11	5.5		1	ELECTEMP							
	6A	1	QTY		RSM6L7S4-UEQ0-S	5 DOOR GLS., LOW TEMP, NARROW	GROC.	EA		-11	5.5		1	ELECTEMP							
	6B	1	QTY		RSM6L7S4-UEZ0-S	5 DOOR GLS., LOW TEMP, NARROW	GROC.	EA		-11	5.5		1	ELECTEMP							
																NEW DISTRIBUTED UNIT Without Ground Attenuation Kit					
																Configuration: Vertical					
																Racsam: As Req RISU-12A					
																Connector: CPC Standard KXK-600; Connecting Units C & D					
																Control Voltage: 208V					
																Control Valve Voltage: 208V					
																Compressor Voltage: 208V					
																Modify existing distributed unit electric as required to accomplish remodel					
																ZF38K4E	-22	32.1	38.1		
																ZF38K4E	-22	20.1	38.1		
																ZF38K4E	-22	26.1	38.1		
																ZF38K4E	-22	20.1	38.1		
																ZF38K4E	-22	26.1	38.1		
																ZF38K4E	-22	26.1	38.1		
															97.8				126.6		77.2%
																ESS SNC Air Cooled Condenser					
																HUB084ANN-LAVK-232150, 16.19 nominal/up to capacity, 68 compressor, 11.11 TD footpoint					
C																R448A					
	1	1	QTY		FNM6T-ES-12	12' NARROW ISLAND, DUAL TEMP	MEAT	NEW		-20	4.6	SC BY DEM	1	ELECTEMP		NEW DISTRIBUTED UNIT Without Ground Attenuation Kit					
	2A	1	QTY		FNDT-ES-12	12' NARROW ISLAND, DUAL TEMP	MEAT	NEW		-26	4.6		1	ELECTEMP		Configuration: Vertical					
	2B	1	QTY		FNDT-ES-12	12' NARROW ISLAND, DUAL TEMP	MEAT	NEW		-26	4.6	SC BY DEM	1	ELECTEMP		Racsam: As Req RISU-12A					
	3A	1	QTY		FNDT-ES-12	12' NARROW ISLAND, DUAL TEMP	MEAT	NEW		-20	4.6		1	ELECTEMP		Connector: CPC Standard KXK-600; Connecting Units C & D					
	3B	1	QTY		WL742308	1/2 FREEZER	GROC.	NEW	0L0466807	-22	20.1			ELECTEMP		Control Valve Voltage: 208V					
	4A	1	QTY		RLM6L7S4-UEQ0-S	5 DOOR GLS., LOW TEMP, NARROW	REAF.	NEW		-11	5.9	ORBITREVR	1	ELECTEMP		Compressor Voltage: 208V					
	4B	1	QTY		RLM6L7S4-UEQ0-S	5 DOOR GLS., LOW TEMP, NARROW	REAF.	NEW		-11	5.9		1	ELECTEMP		Lights, fans, and anti-sweat heaters to be fed from building electric panels.					
	5A	1	QTY		FNL6LT-ES-12	12' NARROW ISLAND, LOW TEMP W/ LID	REAF.	NEW		-12	1.8	SC BY DEM	1	ELECTEMP		Condenser and any defrost heaters to be fed from distributed unit					
	5B	1	QTY		FNL6LT-ES-12	12' NARROW ISLAND, LOW TEMP W/ LID	REAF.	NEW		-12	2.5		1	ELECTEMP		Exception - Fans of cooling coils for EL defrost to be fed from distributed unit)					
	6A	1	QTY		FWD2DT-ES	WIDE ISLAND END , DUAL TEMP	MEAT	NEW		-26	2.1	SC BY DEM	1	ELECTEMP							
	6B	1	QTY		FWD2DT-ES-R(12)	(1/2) - 6' WIDE ISLAND, DUAL TEMP	MEAT	NEW		-26	2.2		1	ELECTEMP		Ambient Temperature: 105° Midpoint, 0.0° Dewpoint (85.1 PSIG Saturated)					
	6C	1	QTY		FWD2DT-ES-R(12)	(1/2) - 6' WIDE ISLAND, DUAL TEMP	MEAT	NEW		-26	2.2		1	ELECTEMP		Condensing Temperature: 142° Midpoint					
	6D	1	QTY		FWD2DT-ES-R(12)	(1/2) - 6' WIDE ISLAND, DUAL TEMP	MEAT	NEW		-26	2.2		1	ELECTEMP							
	7	240	SQ FT	10	WL742308	FREEZER (0.466742)	BAK.	EA		-20	20.3	EVR		ELECTEMP		ZF72K3VLE Digital, Economized 60°		28.9	42.0		
	8A	1	QTY		CWZD-S	SINGLE DECK	BAK.	NEW		-17	1.6	ORBITREVR	2	ELECTEMP		ZF38K4VE Economized 63°		31.1	51.7		
	8B	1	QTY		CWZD-S	SINGLE DECK	BAK.	NEW		-17	1.6		2	ELECTEMP		ZF38K4VE Economized 60°		31.1	51.7		
	8C	1	QTY		CWSD-S	SINGLE DECK	BAK.	NEW		-17	1.9		2	ELECTEMP	120.0	ZF38K4VE Economized 63°		31.1	51.7		
	9	1	QTY		RCM2C-S-UEZ0-S	2 DOOR GLS., ICE CREAM TEMP, NARROW	BAK.	EA		-19	2.3	EVR	1	ELECTEMP		ZF38K3VLE Digital, Economized 63°		31.1	51.7		
	10	50	SQ FT	10	LAE-502	FREEZER (0.502756)	DELI	EA		-22	11.6	EVR									
															120.0				151.5	250.9	79.5%
GR																					
	1	439	SQFT		LFA1606	FREEZER MODIFIED	MEAT	EA		10	50.0	EVR		ORITEMP		Suction Temperature: 20° Midpoint, 34.0° Dewpoint (61.3 PSIG Saturated)					
	2A	700	SQFT		LFA1606	1/2 FREEZER (0.606704)	PROD	EA		00	50.2	EVR		ORITEMP		Condensing Temperature: 142° Midpoint					
	2B				LFA1606	1/2 FREEZER (0.606704)	PROD	EA		00	50.2			ORITEMP	28.1	ZF72K3VLE Digital, Economized 63°		28.9	42.0	66.5%	
	3A	1	QTY		DDSXL-F-8	8' FIVE DECK WITH DOORS	MEAT	NEW		32	2.2	ORBITREVR	1	ORITEMP							
	3B	1	QTY		DDSXL-F-8	8' FIVE DECK WITH DOORS	MEAT	NEW		32	2.2		1	ORITEMP		HEAT RECLAIM COIL DESIGN DATA					
	3C	1	QTY		DDSXL-F-12	12' FIVE DECK WITH DOORS	MEAT	NEW		32	3.3		1	ORITEMP		Mass Flow: 3960 lb/hr					
	3D	1	QTY		DDSXL-F-12	12' FIVE DECK WITH DOORS	MEAT	NEW		32	3.3		1	ORITEMP		Leaving Temp: 101.4 Min					
	3E	1	QTY		DDSXL-F-12	12' FIVE DECK WITH DOORS	MEAT	NEW		32	3.3		1	ORITEMP		See GA414R1.2 drawing for compressor piping					
	4A	1	QTY		DDSXL-F-12	12' FIVE DECK WITH DOORS	PROD.	NEW		32	3.3	ORBITREVR	1	ORITEMP							
	4B	1	QTY		DDSXL-F-8	8' FIVE DECK WITH DOORS	PROD.	NEW		32	2.2		1	ORITEMP		TOTAL THR UNIT C:		369.6			
	4C	1	QTY		DDSXL-F-8	8' FIVE DECK WITH DOORS	PROD.	NEW		32	2.2		1	ORITEMP							
	4D	1	QTY		DDSXL-F-8	8' FIVE DECK WITH DOORS	PROD.	NEW		32	1.8		1	ORITEMP		NEW Model 4P Cooled Condenser with Receiver & Valve Package					
	5A	1	QTY		DDSXL-F-12	12' FIVE DECK WITH DOORS	PROD.	NEW		32	3.3	ORBITREVR	1	ORITEMP		HUB084ANN-LAVK-232150, 16.19 nominal/up to capacity, 68 compressor, 11.11 TD footpoint					
	5B	1	QTY		DDSXL-F-12	12' FIVE DECK WITH DOORS	PROD.	NEW		32	3.3		1	ORITEMP							
																NEMA 1 VFD: Danfoss 175U2365 (#-0365941)					
																Prefabricated Pipe Rack - (APR Industries 42462)					
																Condenser Equipment Support - Quantity (2) - (APR Industries 42447)					
D																R448A					
	1	1	QTY		NSXEPDJEZ1-8	8' FIVE DECK	REAF.	NEW		26	10.8	EVR	3	ORITEMP		NEW DISTRIBUTED UNIT Without Ground Attenuation Kit					
	2	1	QTY		DSFM-12	12' SERVICE	REAF.	NEW		24	3.6	EVR	3	ORITEMP		Configuration: Vertical					
	3A	1	QTY		GS-MS-12 (HRVV)	NSPRICE SINGLE-DECK GRAVITY COIL (NO SHELF)	MEAT	NEW		26	1.8	SC BY DEM	1	ORITEMP		Racsam: As Req RISU-12A					
	3B	1	QTY		GS-MS-12 (NSPP)	NSPRICE SINGLE-DECK NSPRICETOC COIL (NO SHELF)	MEAT	NEW		26	1.8		1	ORITEMP		Connector: CPC Standard KXK-600; Connecting Units C & D					
	4	100	S	S	KP-66	COOLER (0.521500)	REAF.	EA		25	5.5	EVR		ORITEMP		Control Voltage: 208V					
	5A	1	QTY		NSXEPDJEZ1-12	12' FIVE DECK	MEAT	NEW		26	16.2	EVR	4	ORITEMP		Control Valve Voltage: 208V					
	5B	1	QTY		NSXEPDJEZ1-12	12' FIVE DECK	MEAT	NEW		26	16.2		4	ORITEMP		Compressor Voltage: 208V					
	5C	1	QTY		NSXEPDJEZ1-12	12' FIVE DECK	MEAT	NEW		26	16.2		4	ORITEMP		Lights, fans, and anti-sweat heaters to be fed from building electric panels.					
	5D	1	QTY		NSXEPDJEZ1-12	12' FIVE DECK	MEAT	NEW		26	16.2		4	ORITEMP		Condenser and any defrost heaters to be fed from distributed unit					
	5E	1	QTY		NSXEPDJEZ0-8	8' FIVE DECK	MEAT	NEW		26	10.9		4	ORITEMP		Exception - Fans of cooling coils for EL defrost to be fed from distributed unit)					
	6A	32	15	10	LFA6606	1/2 COOLER (0.607109)	MEAT	EA		25	26.1	EVR		ELECTEMP		Suction Temperature: 15° Midpoint, 22.5° Dewpoint (45.1 PSIG Saturated)					
	6B				LFA6606	1/2 COOLER (0.607109)	MEAT	EA		25	26.1			ELECTEMP		Condensing Temperature: 115° Midpoint					
	7	32	10	10	LCA6606	COOLER (0.607109)	PROD	EA		30	30.6	EVR		ORITEMP							
	8A	1	QTY		HM-64-DSDEL(1)	MULTI-DECK SELF SERVICE END	DELI.	NEW		28	3.4	ORBITREVR	6	ORITEMP		ZF72K3VLE Digital, Economized Med°		29.5	100.1		
	8B	1	QTY		HM-64-C12-(NDSEL) 1/2	(1/2) 12' UNFILLED MULTI-DECK ISLAND	DELI.	NEW		28	8.3		6	ORITEMP		ZF38K3VE Economized Med°		86.7	119.1		
	8C	1	QTY		HM-64-DSDEL(1)	MULTI-DECK SELF SERVICE END	DELI.	NEW		28	3.4		6	ORITEMP		ZF38K4VE Economized Med°		86.7	119.1		
	8D	1	QTY		HM-64-C12-(NDSEL) 1/2	(1/2) 12' UNFILLED MULTI-DECK ISLAND	DELI.	NEW		28	8.3		6	ORITEMP		ZF38K4VE Economized Med°		86.7	119.1		
	9A	1	QTY		SLF-MSS	SELF SERVICE	BAK.	NEW		29	5.7	ORBITREVR	4	ORITEMP		ZF38K3VE Economized Med°		86.7	119.1		
	9B	1	QTY		SLF SSSR	SELF SERVICE	BAK.	NEW		29	5.7		4	ORITEMP		ZF38K4VE Economized Med°		86.7	119.1		
	10A	1	QTY		HM-64-DSDEL(1)	MULTI-DECK SELF SERVICE END	DELI.	NEW		28	3.4	ORBITREVR	6	ORITEMP							
	10B	1	QTY		HM-64-C12-(NDSEL) 1/2	(1/2) 12' UNFILLED MULTI-DECK ISLAND	DELI.	NEW		28	8.3		6	ORITEMP	292.5			309.9	693.0	77.8%	
	10C	1	QTY		HM-64-DSDEL(1)	MULTI-DECK SELF SERVICE END	DELI.	NEW		28	3.4		6	ORITEMP							
	11A	1	QTY		HM-64-C12-(NDSEL) 1/2	(1/2) 12' UNFILLED MULTI-DECK ISLAND	DELI.	NEW		28	8.3		6	ORITEMP							
	11B	1	QTY		DLFC-10R	10' SELF SERVICE	DELI.	NEW		26	8.4	EVR	6	ORITEMP		HEAT RECLAIM COIL DESIGN DATA					
	11C	1	QTY		DLFC-06SW	90 DEGREE SELF SERVICE CASE WEDGE	DELI.	NEW		26	2.6		6	ORITEMP		Mass Flow: 7340 lb/hr					
	11D	1	QTY		DLFC-08R	8' SELF SERVICE	DELI.	NEW		26	3.8		6	ORITEMP		See GA414R1.2 drawing for compressor piping					
	12	1	QTY		GS-MS-12	SELF SERVICE MULTI-DECK	DELI.	NEW		20	10.2	EVR	2	ORITEMP							
	13A	1	QTY		DSRDXL-L-12	12' FIVE DECK LOW FRONT WITH DOORS	SS REV.	NEW		32	3.3	ORBITREVR	1	ORITEMP		NEW 208V Air Cooled Condenser with Receiver & Valve Package					
	13B	1	QTY		DRMDXL-L-8	8' FIVE DECK LOW FRONT WITH DOORS	SS REV.	NEW		32	2.5		1	ORITEMP		HUB105ANN-LAVK-251150, 40.00 nominal/up to capacity, 105 compressor, 10.01 TD footpoint					
	13C	1	QTY		DSRDXL-L-8	8' FIVE DECK LOW FRONT WITH DOORS	SS REV.	NEW		32	2.2		1	ORITEMP							
	13D	1	QTY		DDSXL-F-8	8' FIVE DECK WITH DOORS	PROD.	NEW		32	1.6		1	ORITEMP		NEMA 1 VFD: Danfoss 175U2357 (#-0357143)					
	14A	1	QTY		DSXLEP-12	12' FIVE DECK, LOW FRONT	PROD.	NEW		26	10.2	EVR	3	ORITEMP							
	14B	1	QTY		DSXLEP-12	12' FIVE DECK, LOW FRONT	PROD.	NEW		26	10.2		3	ORITEMP		Prefabricated Pipe Rack - (APR Industries 42462)					
	14C	1	QTY		DSXLEP-12	12' FIVE DECK, LOW FRONT	PROD.	NEW		26	15.3		3	ORITEMP		Condenser Equipment Support - Quantity (3) - (APR Industries 42447)					
	14D	1	QTY		DSXLEP-12	12' FIVE DECK, LOW FRONT	PROD.	NEW		26	15.3		3	ORITEMP							
	15	1	QTY		SSI-28	2 DECK GLASS DOOR	BAK.	EX		20	4.4	EVR									
	16A	1	QTY		SSRDX-S	12' SERVICE	DELI.	NEW		30	4.2	EVR	2	ORITEMP							
	16B	1	QTY		SSRDX-12	12' SERVICE	DELI.	NEW		29	4.5		2	ORITEMP							
	17	10	10	10	AS-66	COOLER (0.606759)	DELI.	EX		00	9.3	EVR		ORITEMP							
	18	16	10-0	S	HFA1606	COOLER (0.606759)	DELI.	EX		00	12.7	EVR		ORITEMP							
	19A	1	QTY		SF3-8 (SANDWICH-OVER)	MADE TO ORDER SERVICE	DELI.	NEW		26	3.1	EVR	6	ORITEMP							
	19B	1	QTY		SF3-8 (SANDWICH-UNDER)	MADE TO ORDER SERVICE	DELI.	NEW		26	5.2		6	ORITEMP							
	20	1	QTY		SF-8R-SWR-SS-SU	8' SSLF SERVICE WORK STORE (SUSW)	DELI.	NEW		30	9.2	EVR	4	ORITEMP							
	21	1	QTY		DSXSLP-8	8' FIVE DECK WITH DOORS	SS REV.	NEW		32	2.2	ORBITREVR	1	ORITEMP							
	22A	1	QTY		FLSXE-LEP-8	8' MULTI DECK, LOW FRONT, NARROW	FLOR.	NEW		25	10.6	ORBITREVR	3	ORITEMP							
	22B	1	QTY		FLSXE-LEP-8	8' MULTI DECK, LOW FRONT, NARROW	FLOR.	NEW		26	10.6	ORBITREVR	3	ORITEMP							
	23	55	SQ FT	19	AC66788	COOLER	FLOR.	NEW	K-6666919	29	8.0	ORBITREVR		ORITEMP							
						ALL EXISTING PARALLEL RACKS & AIR COOLED SINGLES TO BE REMOVED AND REMOVED PER THE KROGER PROJECT MANAGER'S DIRECTION																

Order Plans @ WWW.LDLine.com

D&E DOLLAR & EWERS
ARCHITECTURE, INC.
E. Jackson Avenue • Evans, Georgia 30809
(706) 863-5400 • fax: 706-673-0028
e-mail: dollar-ewers.com

STATE OF GEORGIA
BRANDT EWERS
REGISTERED ARCHITECT
1/24/18

NO.	REVISIONS
1	
2	
3	
4	
5	
6	
7	
8	

A With-in-the-Walls Remodel for:

KROGER STORE #GA-414

4355 WASHINGTON ROAD, EVANS, GEORGIA 30809

REFRIGERATION EQUIPMENT SCHEDULES

COPYRIGHT
ALL DRAWINGS, SPECIFICATIONS AND COPIES THEREOF FURNISHED BY DOLLAR & EWERS ARCHITECTURE, INC. ARE AND SHALL REMAIN THE PROPERTY OF DOLLAR & EWERS ARCHITECTURE, INC. THEY ARE NOT TO BE USED IN WHOLE OR IN PART ON ANY OTHER PROJECT AND ARE NOT TO BE LOANED WITH ANY OTHER PERSONS OR ENTITIES WITHOUT THE WRITTEN PERMISSION OF DOLLAR & EWERS ARCHITECTURE, INC. ALL COMMON LAW COPYRIGHTS AND OTHER PROPERTY RIGHTS ARE RESERVED BY DOLLAR & EWERS ARCHITECTURE, INC. THESE DRAWINGS AND SPECIFICATIONS ARE NOT TO BE CHANGED OR COPIED IN ANY FORM OR MANNER WHATSOEVER, NOR ARE THEY TO BE ASSIGNED TO ANY THIRD PARTY, WITHOUT FIRST OBTAINING THE EXPRESS WRITTEN PERMISSION AND CONSENT OF DOLLAR & EWERS ARCHITECTURE, INC. ANY UNAUTHORIZED USE WILL BE CONSIDERED A VIOLATION OF COMMON LAW COPYRIGHT AND OTHER PROPERTY RIGHTS.
COPYRIGHT

ISSUE DATE: JANUARY 29, 2018
PROJECT NO.: 217156
SHEET NUMBER: R6.1