


NOTE:
1. INSTALL ENCLOSURE ON A VIBRATION FREE SURFACE. MARK HOLE LOCATIONS. USE APPROPRIATE HARDWARE FOR MOUNTING TO STRUCTURE.
2. FOLLOW ALL NATIONAL AND LOCAL ELECTRICAL CODES WHEN INSTALLING.
3. WHEN INSERTING WIRING, BE SURE HIGH AND LOW VOLTAGE ARE KEPT ISOLATED.
4. ALL REMOVED KNOCKOUTS MUST HAVE CONDUIT FITTINGS INSTALLED.


REFRIGERANT LEAK DETECTION CONTROL PANEL:
- ONE (1) ENCLOSURE (INSTALLER SUPPLIED & MOUNTED)
- CPC POWER SUPPLY (INSTALLER MOUNTED)
- TWO (2) 8AI/8RO COMBO BOARD (INSTALLER MOUNTED)



1 REFRIGERANT LEAK DETECTION UNIT - HGM MZ

2 CONTROL SYSTEM - DANFOSS LEAK DETECTION CONTROL PANEL

SCALE: NONE




NOTES:
1. HORN & STROBE CONTACTS CONTROLLED BY SAME RELAY POINT.
2. SP 1 SET TO 24 VDC.
3. SW1 SET TO DOWN.
4. SW2 SET TO UP.
5. SW3 SET TO UP.
6. SW4 SET TO UP.

REFRIGERANT LEAK ALARM

EVACUATE THIS SPACE
CONTACT FACILITY MAINTENANCE

EXAMPLE: REFRIGERANT LEAK ALARM WITH HORN & STROBE ALARM. HORN & STROBE ALARM MUST BE INSTALLED WITH WHITE ENGRAVED LETTERING FOR IDENTIFICATION.



NOTE:
- USE SPECIAL WASHDOWN J-BOX (OWNER SUPPLIED) TO MOUNT FILTER END FOR ZONES IN PREP AREAS, DAIRY COOLER AND OUTDOOR PURGE ZONE.
- WHERE DAMAGE TO FILTER END MAY OCCUR, REMOVE THE J-BOX KNOCKOUTS AND INSTALL COVERPLATE.
- FREEZERS TO UTILIZE WALL MOUNT LOCATION.
- COOLERS AND PREP ROOMS TO UTILIZE WALL MOUNT OR CEILING MOUNT DEPENDING ON COIL CONFIGURATION.
- SALES FLOOR ZONES TO UTILIZE THE COLUMN MOUNT.

3 CONTROL SYSTEM - REFRIGERANT LEAK HORN & STROBE DETAIL

4 CONTROL SYSTEM - REFRIGERANT LEAK HORN/STROBE MOUNTING DETAIL

5 CONTROL SYSTEM - REFRIGERANT LEAK DETECTION FILTER MOUNTING / INSTALL DETAIL

SCALE: NONE

Order Plans @ www.LDOnline.com

A With-in-the-Walls Remodel for:
KROGER STORE #GA-414
4355 WASHINGTON ROAD, EVANS, GEORGIA 30809

REFRIGERATION LEAK DETECTION DETAILS

COPYRIGHT
ALL RIGHTS RESERVED. NO PART OF THIS DOCUMENT MAY BE REPRODUCED OR TRANSMITTED IN ANY FORM OR BY ANY MEANS, ELECTRONIC OR MECHANICAL, INCLUDING PHOTOCOPYING, RECORDING, OR BY ANY INFORMATION STORAGE AND RETRIEVAL SYSTEM, WITHOUT THE EXPRESS WRITTEN PERMISSION OF D&E ARCHITECTURAL, INC. THIS DOCUMENT IS THE PROPERTY OF D&E ARCHITECTURAL, INC. AND IS TO BE USED ONLY FOR THE PROJECT AND SITE SPECIFICALLY IDENTIFIED HEREIN. ANY OTHER USE IS STRICTLY PROHIBITED. © 2011 D&E ARCHITECTURAL, INC.

ISSUE DATE: JANUARY 29, 2018
PROJECT NO: 217156

SHEET NUMBER
RLD1.2