



**FIRE ALARM PLAN - DEMOLITION WORK**  
SCALE: 1/8" = 1'-0"

**ENLARGED EQUIPMENT ROOM FIRE ALARM PLAN - DEMOLITION WORK**  
SCALE: 1/4" = 1'-0"

**ENLARGED FIRE SPRINKLER RISER AREA FIRE ALARM PLAN - DEMOLITION WORK**  
SCALE: 1/4" = 1'-0"

**ELEVATION FIRE SPRINKLER RISER FIRE ALARM PLAN - DEMOLITION WORK**  
SCALE: NOT TO SCALE

- KEYED NOTES**
- THE EXISTING FIRE ALARM CONTROL PANEL, AUXILIARY POWER SUPPLIES, CONTINUOUS POWER SUPPLY AND ASSOCIATED EQUIPMENT LOCATED IN THE EQUIPMENT ROOM SHALL REMAIN AS CURRENTLY CONFIGURED. THE EXISTING FIRE ALARM CONTROL PANEL, AUXILIARY POWER SUPPLIES, AND CONTINUOUS POWER SUPPLY TO BE RE-USED TO OPERATE AND MONITOR THE FIRE ALARM EQUIPMENT THROUGHOUT TRU AND FUTURE BRU SPACE.
  - THE EXISTING SMOKE DETECTOR LOCATED IN THE EQUIPMENT ROOM SHALL REMAIN AS CURRENTLY CONFIGURED AND KEPT IN GOOD WORKING CONDITION.
  - THE EXISTING ADDRESSABLE INPUT MODULE, TRANSIENT SUPPRESSION MODULE AND CABLING MONITORING TOYS R US FIRE SPRINKLER, WATERFLOW SWITCH AND TAMPER SWITCH LOCATED IN THE COMMON FIRE SPRINKLER RISER ROOM SHALL REMAIN AS CURRENTLY CONFIGURED AND KEPT IN GOOD WORKING CONDITION.
  - THE EXISTING ADDRESSABLE INPUT MODULE, TRANSIENT SUPPRESSION MODULE AND CABLING MONITORING THE FORMER ADJACENT TENANT SPACE FIRE SPRINKLER WATERFLOW SWITCH AND TAMPER SWITCH LOCATED IN THE COMMON FIRE SPRINKLER RISER ROOM SHALL BE DISCONNECTED AND REMOVED.
  - THE FIRE ALARM CONTRACTOR SHALL DISCONNECT THE EXISTING MANUAL PULL STATION. THE EXISTING MANUAL PULL STATION SHALL BE KEPT IN GOOD WORKING CONDITION AND BE RE-USED WITHIN BABES R US. THE ASSOCIATED CABLING AND CONDUIT CONNECTED TO THE MANUAL PULL STATION SHALL BE REMOVED AND BE RE-USED/ EXTENDED TO THE NEW LOCATION.
  - THE EXISTING DUCT SMOKE DETECTOR, REMOTE TEST STATION AND ASSOCIATED MODULES AND CABLING SHALL REMAIN AS CURRENTLY CONFIGURED AND KEPT IN GOOD WORKING CONDITION.
  - THE FIRE ALARM CONTRACTOR SHALL DISCONNECT THE EXISTING CEILING MOUNTED NOTIFICATION APPLIANCE. THE EXISTING CEILING MOUNTED NOTIFICATION APPLIANCE SHALL BE KEPT IN GOOD WORKING CONDITION AND BE RE-USED WITHIN BABES R US SPACE. THE ASSOCIATED CABLING AND CONDUIT CONNECTED TO THE NOTIFICATION APPLIANCE SHALL BE DISCONNECTED AND REMOVED.
  - THE EXISTING EXTERIOR AUDIBLE/VISUAL NOTIFICATION APPLIANCE ABOVE THE FIRE DEPARTMENT CONNECTION SHALL REMAIN AS CURRENTLY CONFIGURED AND KEPT IN GOOD WORKING CONDITION.

**FIRE ALARM SYMBOL KEY**

	EXISTING ADDRESSABLE INPUT MODULE TO BE DISCONNECTED AND REMOVED
	EXISTING TRANSIENT SUPPRESSION MODULE TO BE DISCONNECTED AND REMOVED
	EXISTING WATERFLOW SWITCH TO BE DISCONNECTED AND REMOVED
	EXISTING TAMPER SWITCH TO BE DISCONNECTED AND REMOVED
	EXISTING FIRE ALARM CONTROL PANEL (BOSCH FPD-7024)
	EXISTING FIRE ALARM ANNUNCIATOR (BOSCH FMR-7036)
	EXISTING ADDRESSABLE INPUT MODULE (BOSCH D7044 OR D7062)
	EXISTING ADDRESSABLE INPUT/OUTPUT MODULE (BOSCH D7050)
	EXISTING AUXILIARY POWER SUPPLY (WHEELLOCK PS-4)
	EXISTING CONTINUOUS POWER SUPPLY (FRELITE FCP-24FS)
	EXISTING MANUAL PULL STATION (BOSCH FM-7045-0)
	EXISTING TRANSIENT SUPPRESSION MODULE
	EXISTING PHOTOELECTRIC SMOKE DETECTOR (BOSCH PFS-1)
	EXISTING DUCT-TYPE PHOTOELECTRIC SMOKE DETECTOR (BOSCH D400 CONVENTIONAL DETECTOR) (R = RATED) AND (S = SUPPLY)
	EXISTING WATERFLOW SWITCH
	EXISTING TAMPER SWITCH TO REMAIN
	EXISTING REMOTE NOTIFICATION / ANNUNCIATOR SYSTEM SENSOR
	EXISTING CEILING MOUNTED RED AUDIBLE/VISUAL APPLIANCE
	EXISTING CEILING MOUNTED RED VISUAL APPLIANCE
	EXISTING WALL MOUNTED RED AUDIBLE/VISUAL APPLIANCE
	EXISTING EXTERIOR WALL MOUNTED RED AUDIBLE/VISUAL APPLIANCE
	NEW FIRE ALARM ANNUNCIATOR (BOSCH FMR-7036)
	RELOCATED / NEW CEILING MOUNTED RED AUDIBLE/VISUAL APPLIANCE (XX = INDICATES CANDELA RATING) (WHEELLOCK EXCEEDER HSRIC)
	RELOCATED / NEW CEILING MOUNTED RED VISUAL APPLIANCE (XX = INDICATES CANDELA RATING) (WHEELLOCK EXCEEDER STRC)
	NEW FIRE ALARM PLENUM RATED CONDUCTORS (RED IN COLOR)
	EXISTING FIRE ALARM CONDUCTORS TO REMAIN
	END OF LINE RESISTOR
	END OF LINE RELAY
	OUT OF SCOPE

**REVISIONS**

No.	Date	Description
01	01/22/18	90% OWNER REVIEW
02	01/26/18	PERMIT

**NO SUBSTITUTIONS SHALL BE ALLOWED UNLESS OTHERWISE NOTED (REFER TO SPECIFICATIONS)**



**CODE CONSULTANTS, INC.**  
2043 WOODLAND PKWY, SUITE 200  
ST. LOUIS, MISSOURI 63146-4235  
314-991-2833  
www.codeconsultants.com



**CASCO**  
10877 WATSON ROAD  
ST. LOUIS, MO 63127  
PROJECT MANAGERS

BD DATE: 1/18  
CAG NAME: 1602807.FXP PROJECT NO.: 1602807.07.000  
DRAWN BY: JLS CHECKED BY: PIK  
PROTOTYPE

**FIRE PROTECTION ENGINEER OF RECORD:**  
JACOB P. HERMEL, PE  
LICENSE NO. 08105

STATE OF FLORIDA  
PROFESSIONAL ENGINEER  
No. 08105

This form has been electronically signed and sealed by Jacob P. Hermel, P.E. on 01/22/2018 using a digital signature.  
Printed copies of this document are not considered signed and sealed and the signature must be verified on any electronic copy.

**BABIES R US**

GLOBAL RESOURCE CENTER  
ONE GEOFFREY WAY  
WAYNE, NJ 07470  
(973) 637-3500

THIS DRAWING IS THE EXCLUSIVE PROPERTY OF TOYS "R" US. THE INFORMATION SHOWN MAY NOT BE USED NOR THE DRAWINGS REPRODUCED WITHOUT PERMISSION OF TOYS "R" US.

Location  
**LAKELAND, FLORIDA**  
3770 US HIGHWAY 98 NORTH-33809

Drawing Title  
**FIRE ALARM PLAN - DEMOLITION WORK**

Scale AS NOTED Date 1/22/18

Sheet No.  
**FAD101**

Order Plans @

WWW.LDLINE.COM